

**Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Annual Nitrite/Nitrate
Water Quality Test Results
August 2022**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 August 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22H0642
Project: Drinking Water Dassa McKinney - Annual
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101	22H0642-01	Drinking Water	08/04/2022 11:15	8/4/22 17:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 08/11/2022 12:21

Lab Sample ID#: 22H0642-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Entry Point 101

Sample Date: 08/04/2022 11:15
Receipt Date: 08/04/2022 17:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: EPA300.0 2.1				Prep Method: No Prep - WetChem		
Nitrate	<0.100	mg/L		0.100	TLL	08/06/22 02:34	08/06/22 02:34
Nitrite	<0.100	mg/L		0.100	TLL	08/06/22 02:34	08/06/22 02:34

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___ 1 ___ OF ___ 1 ___

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
EP 101 TREATMENT ROOM	22H0642			DW	1	Plastic Pint None	Nitrate, Nitrite

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: *Drinking Water Dassa McKinney - Annual*

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: _____
 Phone Number: **724-406-4426**
 Cell Phone: _____
 Email Address: **jcampbell@moniteau.org**
 Billing Address: _____
 PWSID: **5100316**

Sampled By: (Signature) *[Signature]* Date/ Time **8-4-22 11:05**
 Relinquished By: (Signature) *[Signature]* Date/ Time **8-4-22 14:50**

Received By: (Signature) *[Signature]* Date/ Time **8/4/22 17:30**
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations **Y / N / NA** Correct Containers **Y / N / NA** Receipt Temperature _____

Sample Receipt Criteria		Chain of custody documents included with samples?	YES	NO
Comments:		COC form is properly signed in relinquished/received sections?	YES	NO
Comments/Qualifiers (Required for Non-Conforming Items)		Sample containers intact and sealed?	YES	NO
Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other:		Number of containers received matches number indicated on COC?	YES	NO
Sample IDs and Containers Affected:		Sample IDs on COC match date and time on bottles?	YES	NO
Sample IDs and Containers Affected:		Date and time on COC match date and time on bottles?	YES	NO
Sample IDs and Containers Affected:		Sample IDs and Containers Affected?	YES	NO
Sample IDs and Containers Affected:		Sample IDs and Containers Affected?	YES	NO
Sample IDs and Containers Affected:		For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.	YES	NO
Sample IDs and Containers Affected:		Adequate sample volume received?	YES	NO
Sample IDs and Containers Affected:		VOA vials free of headspace (defined as < 6 mm bubble)?	YES	NO
Sample IDs and Containers Affected:		Other Comments:	YES	NO
Deficiency Log Created:			YES	NO

PART C: Receipt Details Completed (if different from above):

Sample State of Collection: PA NY OH WV Other:	Sample Receipt Temperature: 5.9 °C	IR Gun ID: 3	PWSID Compliance Drinking Water Samples: YES NO
Method of Delivery: UPS FedEx	Date/Time Received: 8/14/12 1730	Client Drop off: ESL courier	Received by/Lab ID: JK/CC382
Date/Time Received: 8/14/12	Samples Received on Ice? YES NO	Date Sampled: 8/14/12	

PART B: GENERAL INFORMATION - INDIANA LABORATORY

Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	Sample Receipt Temperature: °C	IR Gun ID:
Method of Delivery: Client Drop-Off ESL Courier Other:	Date/Time Received: / /	Received on Ice? YES NO

PART A: GENERAL INFORMATION - SATELLITE LABORATORY

Client: Monahan School District	Work Order:
---------------------------------	-------------



SAMPLE RECEIPT AND REVIEW FORM





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.98	080422	802		080422	D	1120	32382	22H0701-01	BROWNKA_274
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080522	802		080422	D	1120	32382	22H0701-01	BROWNKA_275

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080622	101		080422	E	1115	32382	22H0642-01	BROWNKA_25
5100316	1041	NITRITE	120	0.0	0.10000		080622	101		080422	E	1115	32382	22H0642-01	BROWNKA_26