

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for December 2022

MONTEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	DEC	2022	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Thurs	51.5	11.51	7,363,565	0.60	0.65	7.0	0.00	0	0.99	Jeff C	9:00 AM
2	Fri	48.7	9.12	7,363,565	0.60	0.66	7.0	0.00	0	0.98	Jeff C	3:00 PM
3	SAT											
4	SUN											
5	Mon	49.7	7.19	7,363,565	0.60	0.66	7.0	0.00	0	0.99	Jeff C	2:00 PM
6	Tues	50.0	8.49	7,377,706	0.58	0.63	7.1	0.00	0	1.27	Jeff C	3:00 PM
7	Wed	54.4	10.54	7,388,948	0.60	0.65	7.1	0.00	0	1.19	Jeff C	1:00 PM
8	Thurs	53.8	9.76	7,388,948	0.63	0.66	7.1	0.00	0	1.18	Jeff C	9:00 AM
9	Fri	56.3	10.95	7,400,274	0.65	0.70	7.1	0.00	0	0.97	Jeff C	4:00 PM
10	SAT											
11	SUN											
12	Mon	50.0	10.35	7,402,591	0.59	0.64	7.0	0.00	0	1.07	Jeff C	10:00 AM
13	Tues	49.9	9.04	7,402,591	0.59	0.64	7.0	0.00	0	1.09	Jeff C	9:00 AM
14	Wed											
15	Thurs	48.0	9.80	7,413,008	0.59	0.65	7.1	0.03	0	1.25	Jeff R	11:30 AM
16	Fri	47.9	8.34	7,413,008	0.60	0.64	7.0	0.03	0	1.22	Jeff R	11:30 AM
17	SAT											
18	SUN											
19	Mon	43.7	10.64	7,424,745	0.61	0.65	7.1	0.00	0	1.74	Jeff C	10:00 AM
20	Tues	44.6	9.17	7,424,745	0.60	0.65	7.1	0.00	0	1.72	Jeff C	10:00 AM
21	Wed	45.1	8.64	7,424,745	0.60	0.64	7.1	0.00	0	1.73	Jeff C	11:00 AM
22	Thurs	44.2	7.11	7,424,745	0.60	0.65	7.1	0.00	0	1.70	Jeff C	1:00 PM
23	Fri	47.7	10.28	7,445,671	0.47	0.51	7.1	0.01	0	1.20	Jeff C	10:30 AM
24	SAT											
25	SUN											
26	Mon											
27	Tues	38.9	9.21	7,445,671	0.46	0.50	7.1	0.00	0	1.21	Jeff C	8:00 AM
28	Wed	38.7	8.83	7,445,671	0.45	0.49	7.1	0.00	0	1.19	Jeff C	8:00 AM
29	Thurs	37.4	8.48	7,445,671	0.46	0.50	7.1	0.00	0	1.17	Jeff C	1:00 PM
30	Fri	37.1	8.21	7,445,671	0.45	0.50	7.1	0.00	0	1.16	Jeff C	8:00 AM
31	SAT											

11/30/22 Meter Reading

7/349/863

Sewage Samples Water Samples



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

30 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L2557
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	22L2557-01	Drinking Water	12/29/2022 09:40	12/29/22 11:33	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/30/2022 09:48

Lab Sample ID#: 22L2557-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 12/29/2022 09:40
Receipt Date: 12/29/2022 11:33

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.540	mg/L		0.200	PS	12/29/22 09:40	12/29/22 09:40

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>22L-2557</u>	<u>12/29/12</u>	<u>0940</u>	DW	Field	Field	Free Chlorine <u>0.84</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) <u>[Signature]</u>	Date/ Time <u>12/29/12 0940</u>
Relinquished By: (Signature) <u>[Signature]</u>	Date/ Time <u>12/29/12 1130</u>
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Correct Preservations <u>Y</u> / N / NA	Correct Containers <u>Y</u> / N / NA
Received By: (Signature) <u>AJC</u>	Date/ Time <u>12/29/12 1133 (1130)</u>
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Receipt Temperature <u> </u>	

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcambell@moniteau.org**

Cell Phone: **5100324**

Email Address: **5100324**

Billing Address: **5100324**

PWSID: **5100324**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.65	120822	704		120822	D	1120	32382	22L0836-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.6	120122	802		120122	D	1240	32382	22L0152-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1240	32382	22L0152-01	BROWNKA_61
5100324	1013	FREE CHLORINE	301	0.56	121522	803		121522	D	1105	32382	22L1500-01	BROWNKA_472
5100324	1013	FREE CHLORINE	301	0.56	122222	804		122222	D	0955	32382	22L2142-01	BROWNKA_878
5100324	1013	FREE CHLORINE	301	0.54	122922	804		122922	D	0940	32382	22L2557-01	BROWNKA_1071



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

30 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L2555
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	22L2555-01	Drinking Water	12/29/2022 09:25	12/29/22 11:33	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

23 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L2139
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	22L2139-01	Drinking Water	12/22/2022 09:37	12/22/22 12:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/23/2022 10:52

Lab Sample ID#: 22L2139-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 12/22/2022 09:37
Receipt Date: 12/22/2022 12:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.480	mg/L		0.200	PS	12/22/22 09:37	12/22/22 09:37

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

22L2139



Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 804	22L2139		0937	DW	Field	Field	Free Chlorine 6.48 mg/L

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) Date/ Time 12/22/02 0937

Relinquished By: (Signature) Date/ Time 12/22/02 1930

Received By: (Signature) Date/ Time 12/22/02 1930

Company/Name: MONTEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: 724-406-4426
Email Address: jcampbell@monteau.org
Billing Address: 51003316
PWSID: 51003316

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.99	120822	801		120822	D	1100	32382	22L0834-01	BROWNKA_59
5100316	1013	FREE CHLORINE	301	0.64	120122	802		120122	D	1123	32382	22L0160-01	BROWNKA_57
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1123	32382	22L0160-01	BROWNKA_58
5100316	1013	FREE CHLORINE	301	0.73	121522	803		121522	D	1028	32382	22L1502-01	BROWNKA_471
5100316	1013	FREE CHLORINE	301	0.48	122222	804		122222	D	0937	32382	22L2139-01	BROWNKA_877



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L1500
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	22L1500-01	Drinking Water	12/15/2022 11:05	12/15/22 13:24	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/19/2022 13:36

Lab Sample ID#: 22L1500-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 12/15/2022 11:05
Receipt Date: 12/15/2022 13:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.560	mg/L		0.200	PS	12/15/22 11:05	12/15/22 11:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTH-
435 Brc
Montiou
(570) 31
FAX: (5



FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		# of Bottles	Matrix	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SWS</u>	<u>22L1500</u>	<u>12/15/02</u>	<u>1105</u>	Field	DW	Field	Free Chlorine <u>0.56</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>		<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>					
<p>Sampled By: (Signature) <u>[Signature]</u> <u>12/15/02</u> <u>1105</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> <u>12/15/02</u> <u>1300</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>	<p>Received By: (Signature) <u>[Signature]</u> <u>12/15/02</u> <u>13:24 (W382)</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>	<p>Correct Preservations <u>Y/N/NA</u> Correct Containers <u>Y/N/NA</u> Receipt Temperature <u>---</u></p>					



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.65	120822	704		120822	D	1120	32382	22L0836-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.6	120122	802		120122	D	1240	32382	22L0152-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1240	32382	22L0152-01	BROWNKA_61
5100324	1013	FREE CHLORINE	301	0.56	121522	803		121522	D	1105	32382	22L1500-01	BROWNKA_472



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L0836
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	22L0836-01	Drinking Water	12/08/2022 11:20	12/8/22 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Asbestos subcontracted to R.J. Lee Group, Inc., PA DEP Lab ID 02-00396; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/20/2022 10:12

Lab Sample ID#: 22L0836-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 12/08/2022 11:20
Receipt Date: 12/08/2022 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.650	mg/L			Client	12/08/22 11:20	12/08/22 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpshville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2220836	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 704	01	DW	Field	Preservative	Free Chlorine 0.65 mg/L
KITCHEN SINK	1100	DW	1	LABEL NONE	ASBESTOS
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>					
<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>					
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>					
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 11:00</p>		<p>Received By: (Signature) <i>[Signature]</i> Date/ Time 12-8-22 1500</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time</p>		<p>Received By: (Signature) Date/ Time</p>			
<p>Relinquished By: (Signature) Date/ Time</p>		<p>Received By: (Signature) Date/ Time</p>			
<p>Relinquished By: (Signature) Date/ Time</p>		<p>Received By: (Signature) Date/ Time</p>			
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature			
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD</p> <p>Contact Person: WEST SUNBURY, PA 16061</p> <p>Phone Number: JEFFREY CAMPBELL</p> <p>Cell Phone: 724-406-4426</p> <p>Email Address: jcampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID:</p>					



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.65	120822	704		120822	D	1120	32382	22L0836-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.6	120122	802		120122	D	1240	32382	22L0152-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1240	32382	22L0152-01	BROWNKA_61

Final Laboratory Report TEM EPA Water Analysis

Report Date: 12/19/2022
Sample Receipt Date: 12/09/2022
R.J Lee Group Job No.: ATP1068588-0
Authorization/P.O. No.: 1
Samples Received: 1
Client Job No.: 22L0836

Attention: Kirsten Conoran
Environmental Service Labs Inc
1803 Philadelphia Street
Indiana, PA 15701
US

Method: EPA Method 100.2 600/R-94-134

Client Sample Number	RJLG Sample Number	Date Prepped	Date Analyzed	Filter Area (mm ²)	Volume (ml)	Area Analyzed (mm ²)	Confidence Interval	Asbestos Structures		Analytical Sensitivity (MFL)	Concentration (MFL)
								Chry	Amph		
22L0836-01	10575317.HTW1	12/09/2022	12/17/2022	1220	100	0.06576	0-4	0	0	>10 μm	< 0.2



Authorized Signature: Jon Swope, Scientist

- NOTES**
- Water samples collected more than 24 hours before receipt may be out of compliance. Drinking water samples are filtered within 24 hours of receipt.
 - <-> indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
 - Sample(s) for this project were analyzed at our Pittsburgh, PA (AIHA LAP, LLC #292885, NVLAP #101208-0, NY ELAP #10884) facility.
 - If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
 - Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, MFL-million fibers per liter.
 - Samples will be held for 30 days and then disposed of per Federal regulations.
 - These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

CLAIMER

ee Group, Inc. is accredited by the New York Department of Health Environmental Laboratory Program (NY ELAP) and the Pennsylvania Department of Environmental Protection (PA DEP) for asbestos in water analysis by TEM. This report may not be used to claim product
assessment by NY ELAP, PA DEP or any other regulatory or laboratory accrediting agency. Any reproduction of this document must be in full in order for the report to be valid. This report is not valid unless it bears the name of a NY ELAP and PA-DEP approved signatory.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limiting provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified
ing to return the samples covered by this report, RJ Lee Group will store the samples for a period of thirty (30) days before discarding. A shipping and handling fee will be assessed for the return of any sample.



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1094	ASBESTOS	009	0.0	0.20000		121722	704		120822	D	1120	02396	10575317	SLOADAML 02396_75



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

12 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L0152
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	22L0152-01	Drinking Water	12/01/2022 11:40	12/1/22 13:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/12/2022 16:00

Lab Sample ID#: 22L0152-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 802 Room 204 Sink

Sample Date: 12/01/2022 11:40
Receipt Date: 12/01/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.600	mg/L			Client	12/01/22 11:40	12/01/22 11:40
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	12/01/22 14:53	12/02/22 15:04
E. Coli	Absent	per 100 mL		1	AMB	12/01/22 14:53	12/02/22 15:04

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



22L0152

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification		ESL# 22L0152		Sample Type		Matrix		# of Bottles		Container Type <small>Preservative</small>		Analysis Requested	
CIRCLE ONE: 704-KITCHEN MAIN SINK 802 ROOM 204 SINK		01		Date 12-27		Time 1140		1		STERILE PLASTIC NA THIO		TC / EC Free Chlorine 0.60	
<p>704: Jan, Mar, May, Jul, Sept, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec</p>													
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>													
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 12-27 1140</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time 12/17/20 1320</p>				<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Monthly</p>					
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 12-27 1330</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p>					
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Address: 1810 WEST SUNBURY ROAD</p>					
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Received By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Contact Person: JEFFREY CAMPBELL</p>					
<p>Correct Preservations: <i>[Signature]</i> Y / N / NA</p>				<p>Correct Containers: <i>[Signature]</i> Y / N / NA</p>				<p>Phone Number: 724-406-4426</p>					
<p>Receipt Temperature: <i>[Signature]</i> 5.1#3</p>				<p>Receipt Temperature: <i>[Signature]</i> 5.1#3</p>				<p>Cell Phone: icampbell@moniteau.org</p>					
<p>Correct Containers: <i>[Signature]</i> Y / N / NA</p>				<p>Correct Containers: <i>[Signature]</i> Y / N / NA</p>				<p>Billing Address: WEST SUNBURY, PA 16061</p>					
<p>Correct Containers: <i>[Signature]</i> Y / N / NA</p>				<p>Correct Containers: <i>[Signature]</i> Y / N / NA</p>				<p>PWSID: 5100324</p>					



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.6	120122	802		120122	D	1240	32382	22L0152-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1240	32382	22L0152-01	BROWNKA_61

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for December 2022

**COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 12/01/2022
 DMR Effective To: 12/31/2022
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

001
 OUTFALL NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	12	01	2022	12	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		6.72	***	***	mg/L	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	***	mg/L	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.11	***	8.63	S.U.	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	S.U.	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	***	mg/L	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		8.11	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***	mg/L	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		.82	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***	mg/L	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		5.7	***	***	µw/cm²	1/week	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***	µw/cm²	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002848	MGD	***	***	***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	***	***	***		1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Faecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		***	2000	10000		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	<2.00	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	25	***		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthehelpdesk@state.pa.us <depgreenporthehelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Fri, Jan 6, 2023 at 1:55 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 12/01/2022-12/31/2022
Report Due Date: 01/28/2023

Submitted By: Jeffrey Campbell
Submission Id: 368036
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau School District
 Moniteau High School Wastewater Plant
 Monthly Worksheet for DEC 2022

FLOW 82,106 gallons TOTAL \div 31 = 2,648 Daily Avg.
 UV Light 122.5 \div 22 = 5.568 TOTAL Avg. 5.7
 PH Low 7.11 BASIN 2 12/28
 High 8.63 BASIN 2 12/1
 D.O. Low 6.72 BASIN 2 12/7
 High 10.63 BASIN 2 12/1

	12/1	12/8		
TOTAL Nitrogen	< 0.729	15.5	16.229	8.11 Avg.
TKN	< 0.625	< 0.625		< 0.625 Avg.
TSS	< 5	< 5		< 5 Avg.
Nitrate / Nitrite	0.616	15.5	16.116	8.05 Avg.
Phos	0.13	1.5	1.63	0.815
CBOD	< 2.00	< 2.00		< 2.00
Fecal	< 1	< 1		< 1

Moniteau High School Sewage Treatment Plant										Daily Operations Worksheet			
Permit # PA0091341										Month	Meter Reading	Time	Operator
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	UV				DEC 2022			
12-1	Thurs	8.59	9.82	8.63	10.63	4.3					9:30 A	Jeff C	
12-2	Fri	8.42	9.19	8.37	9.21	5.1					8:00 A	Jeff C	
12-5	Mon	AERATION	8.24	8.24	9.17	5.3					8:00 A	Jeff C	
12-6	Tues	8.28	9.10	8.12	7.41	5.5					3:00 P	Jeff C	
12-7	Wed	8.21	9.03	8.01	6.72	5.5					2:00 P	Jeff C	
12-8	Thurs	8.11	8.99	7.97	7.21	6.3					10:30 A	Jeff C	
12-9	Fri	AERATION	7.91	7.91	8.28	5.8					1:30 P	Jeff C	
12-12	Mon	7.93	8.52	7.88	9.51	5.9					8:00 A	Jeff C	
12-13	Tues	8.18	9.44	7.49	10.12	5.6					8:00 A	Jeff C	
12-14	Wed	8.21	9.50	7.50	9.73	5.5					5:00 P	Seth C	
12-15	Thurs	8.24	9.37	7.55	9.42	5.7					5:00 P	Seth C	
12-16	Fri	8.03	9.20	7.61	9.37	5.7					5:00 P	Seth C	
12-19	Mon	8.25	9.03	7.69	9.57	5.7					10:30 A	Jeff C	
12-20	Tues	8.08	8.83	7.75	10.20	5.6					8:00 A	Jeff C	
12-21	Wed	8.01	8.80	7.74	10.01	5.7					8:30 A	Jeff C	
12-22	Thurs	7.92	8.70	7.78	9.72	5.8					1:00 P	Jeff C	
12-23	Fri	AERATION	7.75	7.75	9.21	5.8					10:00 A	Jeff C	
12-26	Mon	7.77	8.22	7.47	9.00	5.7					7:00 A	Jeff C	
12-27	Tues	7.75	8.31	7.38	8.93	5.8					7:00 A	Jeff C	
12-28	Wed	AERATION	7.11	7.11	8.49	5.6					1:30 P	Jeff C	
12-29	Thurs	7.91	9.08	7.75	9.17	5.3					2:00 A	Jeff C	
12-30	Fri	7.93	9.63	7.86	9.46	5.3					7:00 A	Jeff C	
						122.5							
						4.28							
						5.568							
Meter		7,363,565											
		7,945,671											

* Test Day

* Test Day



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

21 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L0837
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22L0837-01	Waste Water	12/08/2022 10:30	12/8/22 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/21/2022 09:08

Lab Sample ID#: 22L0837-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 12/08/2022 10:30
Receipt Date: 12/08/2022 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]		
Total Nitrogen	15.5	mg/L		1.66	DAA	12/20/22 12:23	12/20/22 12:23
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	12/14/22 14:50	12/17/22 17:15
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	APC	12/15/22 07:53	12/15/22 11:15
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	15.5	mg/L		1.04	AW	12/20/22 12:23	12/20/22 12:23
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.5	mg/L		0.50	AW	12/15/22 12:20	12/15/22 12:20
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS	2.00	AW	12/09/22 18:35	12/14/22 14:50
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	12/08/22 14:53	12/09/22 11:33

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY



22L0837

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/of	Time on/of	Date	Time		
Effluent Outfall 001	22L0837			12/8/22	10:30 AM	Poly 1000mL	CBOD, TSS
	01					None	
						Poly 1000mL	Total Nitrogen, Total Phosphorus
						H2SO4	
						Sterile Plastic 125mL	Fecal Coliform
						Na2S2O3	
<p>Project Notes: Wastewater</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 12/5/22 10:30 AM</p>				<p>Company Name: MONTEAU SCHOOL DISTRICT</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 12/5/22 11:20</p>				<p>Contact Person: JEFFREY CAMPBELL</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 12-5-22 1:48</p>				<p>Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Phone / Cell: 724-406-4426</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time</p>				<p>Email: jcampbell@moniteau.org</p>			
Correct Preservations		Y / N / NA		Correct Containers		Y / N / NA	
						Receipt Temperature	



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>MONITEAU SD</u>	Work Order: _____
----------------------------	-------------------



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	
Sample Receipt Temperature: _____ °C	Received on Ice? YES <input type="checkbox"/> NO <input type="checkbox"/>
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>MKE (00382)</u>	Samples Received on Ice? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Date/Time Received: <u>12 / 8 / 22 1500</u>	Date Sampled: <u>12 / 8 / 22</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="radio"/> PA <input type="radio"/> NY <input type="radio"/> OH <input type="radio"/> WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

PART C: Receipt Details Completed (if different from above): _____ / / _____

Sample Receipt Criteria		Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Circle Applicable: Damaged Container _____ Leaking Container _____ Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/> YES <input type="radio"/> NO				For non-WW samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/> YES <input type="radio"/> NO				Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES <input type="radio"/> NO <input checked="" type="radio"/>				Sample IDs and Containers Affected:
Other Comments:					Deficiency Log Created: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

Effective Date: _____

Clay Township

David K. Beachem, Chairman
Dale D. Anderson, Vice Chairman
Jeffrey J. Scott, Supervisor
Joann Duke, Secretary/Treasurer


1115 Euclid School Road
Butler, Pennsylvania 16001
724-637-2638
Fax 724-637-3415

E-Mail - jdukeatclay@zoominternet.net

December 21, 2022

TO: MARY JANE DOUBLE AND CINDY BROWN

FROM:


Joann Duke

SUBJECT: Clay Township Appointed Tax Collector

Her information is as follows:

Lori Ann Spreng
325 Shroyer Mill Road
Butler, PA 16001

Cell (For your use only) - 412-614-0601

Land-line (For on the tax cards) - 724-476-1047 - Never heard of that exchange, but that is what Armstrong Gave her.

E-mail - sluss505@gmail.com

OFFICE HOURS (COUNTY & TWP CARDS) Tuesday and Thursday - 10 AM - 6 PM

Additional Hours:

Saturday, April 29, 2023 - 10 AM - 6 PM

Friday, June 30, 2023 - 10 AM - 6 PM

Saturday, December 30, 2023 - 10 AM - 6 PM



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L0043
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22L0043-01	Waste Water	12/01/2022 10:15	12/1/22 13:24	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- LH Laboratory control sample exceeded acceptance criteria, result may be biased high.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/12/2022 15:07

Lab Sample ID#: 22L0043-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 12/01/2022 10:15
 Receipt Date: 12/01/2022 13:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]		
Total Nitrogen	<0.729	mg/L		0.729	DAA	12/05/22 08:40	12/05/22 14:47
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	12/05/22 08:40	12/05/22 14:47
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L	LH	5	APC	12/05/22 08:51	12/05/22 15:29
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.616	mg/L		0.104	AW	12/02/22 12:00	12/02/22 12:00
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.13	mg/L		0.10	AW	12/06/22 09:55	12/06/22 09:55
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB	2.00	TJC	12/01/22 18:44	12/06/22 13:00
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	12/01/22 15:18	12/02/22 11:28



22L0043

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-8003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTO

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Date	Time	Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab						
Date on/of	Time on/of	Date	Time						
Effluent Outfall 001	22-L0043			12/1/22	10:15 AM	WW	1	Poly 1000mL	CBOD, TSS
	01					WW	1	None	Total Nitrogen, Total Phosphorus
						WW	1	H2SO4	Fecal Coliform
								Sterile Plastic 125mL	
								Na2S2O3	

Project Notes:
Wastewater

Company/Name: MONTEAU SCHOOL DISTRICT

Contact Person: JEFFREY CAMPBELL
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
724-406-4426
Email: jcampbell@monteau.org

Received By: (Signature) [Signature] **Date/ Time** 12-1-22 11:45

Relinquished By: (Signature) [Signature] **Date/ Time** 12-1-22 1:24

Received By: (Signature) [Signature] **Date/ Time** 12-1-22 1:24

Relinquished By: (Signature) [Signature] **Date/ Time** 12-1-22 1:24

Correct/Preservations Y/N/NA **Correct/Containers** Y/N/NA **Receipt/Temperature**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (19% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

SAMPLE RECEIPT AND REVIEW FORM

Client: MONITEAU SCHOOL Work Order _____



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____ Date/Time Received: 1 / 1 / _____

Method of Delivery: Client Drop-Off ESL Courier Other: _____ Received on Ice? YES NO

Sample Receipt Temperature: _____ °C IR Gun ID: _____

Containers Removed by Satellite Lab for Analysis of: FE CAL TC/EC TC MPN EC MPN TC/EC MPN N/A

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: MKE (00382) Samples Received on Ice? YES NO

Date/Time Received: 12/1/22 1324 Date Sampled: 12/1/22

Method of Delivery: FedEx UPS Client Drop off Other: _____

Sample Receipt Temperature: 4.5 °C IR Gun ID: 3 Other: _____

Sample State of Collection: PA NY OH WV Other: _____

PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria	Signature	Date	Time
Chain of custody documents included with samples?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Sample containers intact and sealed?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Samples received within holding time?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Adequate sample volume received?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Other Comments:	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		

Comments/Qualifiers (Required for Non-Conforming Items)

Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____

Sample IDs and Containers Affected: _____

Sample IDs and Containers Affected: _____

Sample IDs and Containers Affected: _____

Sample IDs and Containers Affected: _____

Sample IDs and Containers Affected and Observed pH: _____

For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.

Analyses Affected: _____

Sample IDs and Containers Affected: _____

Effective Date: _____ Deficiency Log Created: YES NO

Moniteau School District
Maintenance Department
Dassa McKinney School
Water Treatment Facility
Monthly Report for December 2022

Dassa McKinney Elementary School Water Treatment Facility													
Month	Date	Day	Dec.	2022	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Thurs	8.7	0.01	0.40	0.45	1.17	13765000	JeffR	11:00A	4000			
2	Fri	8.7	0.02	0.44	0.49	1.89	13769500	JeffR	4:30P	4500			
3	Sat												
4	Sun												
5	Mon	8.7	0.02	0.74	0.80	2.54	13773300	JeffR	4:30P	3800			
6	Tues	8.7	0.02	0.84	0.92	2.83	13776600	JeffR	4:00P	3300			
7	Wed	8.7	0.00	0.87	0.97	2.99	13781000	JeffR	4:30P	4400			
8	Thurs	8.7	0.00	0.82	0.94	2.10	13784700	JeffR	4:30P	3700			
9	Fri	8.7	0.01	0.68	0.76	2.25	13787900	JeffR	4:30P	3200			
10	Sat												
11	Sun												
12	Mon	8.7	0.02	0.64	0.70	2.53	13791800	JeffR	4:30P	3900			
13	Tues	8.7	0.02	0.58	0.66	2.89	13795400	JeffR	4:00P	3600			
14	Wed	8.7	0.02	0.58	0.67	2.71	13798600	JeffR	4:30P	3200			
15	Thurs	8.7	0.00	0.66	0.74	2.70	13801700	JeffR	4:30P	3100			
16	Fri	8.7	0.02	0.70	0.77	2.88	13805300	JeffR	4:30P	3600			
17	Sat												
18	Sun												
19	Mon	8.7	0.00	0.57	0.62	2.62	13808700	JeffR	3:30P	3400			
20	Tues	8.7	0.00	0.62	0.70	2.74	13812800	JeffR	4:30P	4100			
21	Wed	8.7	0.02	0.63	0.68	2.85	13816300	JeffR	4:30P	3500			
22	Thurs	8.7	0.02	0.67	0.70	2.91	13819900	JeffR	3:50P	3600			
23	Fri	8.7	0.00	0.97	1.08	2.95	13820300	JeffR	2:00P	400			
24	Sat												
25	Sun												
26	Mon												
27	Tues												
28	Wed												
29	Thurs												
30	Fri												
31	Sat												

Meter Reading 11/30/22 - 13761000



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/30/2022 09:48

Lab Sample ID#: 22L2555-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 12/29/2022 09:25
Receipt Date: 12/29/2022 11:33

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.590	mg/L		0.200	PS	12/29/22 09:25	12/29/22 09:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



22L2555

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 802	22L2555	12/29/22	0925	DW	Field	Field	Free Chlorine 0.59 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time 12/29/22 0925		Received By: (Signature)		Date/ Time 12/29/22 1133 (0.30)	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Correct Preservations <input checked="" type="checkbox"/> N / NA		Correct Containers <input checked="" type="checkbox"/> N / NA		Receipt Temperature 3.8		Ak 12/29/22	
Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly							
Company Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.org Email Address: jcampbell@moniteau.org Billing Address: PWSID: 5100316							



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.99	120822	801		120822	D	1100	32382	22L0834-01	BROWNKA_59
5100316	1013	FREE CHLORINE	301	0.64	120122	802		120122	D	1123	32382	22L0160-01	BROWNKA_57
5100316	1013	FREE CHLORINE	301	0.59	122922	802		122922	D	0925	32382	22L2555-01	BROWNKA_1070
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1123	32382	22L0160-01	BROWNKA_58
5100316	1013	FREE CHLORINE	301	0.73	121522	803		121522	D	1028	32382	22L1502-01	BROWNKA_471
5100316	1013	FREE CHLORINE	301	0.48	122222	804		122222	D	0937	32382	22L2139-01	BROWNKA_877



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

23 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L2142
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	22L2142-01	Drinking Water	12/22/2022 09:55	12/22/22 12:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/23/2022 10:52

Lab Sample ID#: 22L2142-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 12/22/2022 09:55
Receipt Date: 12/22/2022 12:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.560	mg/L		0.200	PS	12/22/22 09:55	12/22/22 09:55

ENVIRONMENTAL SERVICE LABORATORIES, INC

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 804	222142	12/22/22	0955	DW	Field	Field	Free Chlorine 0.56 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) [Signature] Date/ Time 12/22/22 0955
 Relinquished By: (Signature) [Signature] Date/ Time 12/22/22 1050

Received By: (Signature) [Signature] Date/ Time 12/22/22 12:30

Received By: (Signature) _____ Date/ Time _____
 Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: _____
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.org**
 Billing Address: _____
 PWSID: **5100324**



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL
 SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.65	120822	704		120822	D	1120	32382	22L0836-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.6	120122	802		120122	D	1240	32382	22L0152-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1240	32382	22L0152-01	BROWNKA_61
5100324	1013	FREE CHLORINE	301	0.56	121522	803		121522	D	1105	32382	22L1500-01	BROWNKA_472
5100324	1013	FREE CHLORINE	301	0.56	122222	804		122222	D	0955	32382	22L2142-01	BROWNKA_878



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L1502
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	22L1502-01	Drinking Water	12/15/2022 10:28	12/15/22 13:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 12/19/2022 13:37

Lab Sample ID#: 22L1502-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 12/15/2022 10:28
Receipt Date: 12/15/2022 13:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.730	mg/L		0.200	PS	12/15/22 10:28	12/15/22 10:28

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NOF 435
Mon (570)
FAX: (570) 321-1957

VISION 16
22L1502
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	22L1502	Matrix	DW	# of Bottles	Field	Container Type	Preservative	Analysis Requested
	Distribution:	803		Field		Field		Free Chlorine	
Sample Type		Date	Time	Sample Type		Date	Time		
		12/15/22	10:28						

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) *[Signature]* Date/ Time 12/15/22 10:28
 Relinquished By: (Signature) *[Signature]* Date/ Time 12/15/22 13:25 (0388)

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature _____

Company/Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: jcampbell@moniteau.org
 Billing Address: JEFFREY CAMPBELL
 PWSID: 5100316



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.99	120822	801		120822	D	1100	32382	22L0834-01	BROWNKA_59
5100316	1013	FREE CHLORINE	301	0.64	120122	802		120122	D	1123	32382	22L0160-01	BROWNKA_57
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1123	32382	22L0160-01	BROWNKA_58
5100316	1013	FREE CHLORINE	301	0.73	121522	803		121522	D	1028	32382	22L1502-01	BROWNKA_471



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

20 December 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22L0834
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	22L0834-01	Drinking Water	12/08/2022 11:00	12/8/22 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Asbestos subcontracted to R.J. Lee Group, Inc., PA DEP Lab ID 02-00396; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/20/2022 10:11

Lab Sample ID#: 22L0834-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 12/08/2022 11:00
Receipt Date: 12/08/2022 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.990	mg/L		0.200	PS	12/08/22 11:00	12/08/22 11:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY



22L0834

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 22L0834	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>SOL</u>	01	Date <u>12-8-22</u>	DW	Field	Field	Free Chlorine <u>0.29</u> mg/L
<u>KITCHEN SINK</u>	<u>1</u>	Time <u>1100</u>	DW	1	<u>INTL MONI</u>	<u>ASBESTOS</u>
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>						

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Contact Person:	724-406-4426 jcambell@moniteau.org
Phone Number:	5100316
Cell Phone:	
Email Address:	
Billing Address:	
PWSID:	

Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>12-8-22 1500</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	
Correct Preservations	Y / N / NA	Correct Containers	Y / N / NA
Receipt Temperature			



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>MONITEAU SD</u>	Work Order
----------------------------	------------



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>MKE (00382)</u>	Samples Received on Ice? <input checked="" type="radio"/> YES NO
Date/Time Received: <u>12/8/22 1500</u>	Date Sampled: <u>12/8/22</u>
Method of Delivery: FedEx UPS Client Drop off <input checked="" type="radio"/> ESL courier Other: _____	
Sample Receipt Temperature: <u>3.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="radio"/> IA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: <input checked="" type="radio"/> YES NO

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature		Date		Comments/Qualifiers (Required for Non-Conforming Items)
				Time	
Chain of custody documents included with samples?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Circle Applicable: Damaged Container Custody Seal Broken Other: _____ Leaking Container
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="radio"/> YES	<input type="radio"/> NO			Sample IDs and Containers Affected:
Other Comments:					Deficiency Log Created: <input type="radio"/> YES <input checked="" type="radio"/> NO

Effective Date:



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.99	120822	801		120822	D	1100	32382	22L0834-01	BROWNKA_59
5100316	1013	FREE CHLORINE	301	0.64	120122	802		120122	D	1123	32382	22L0160-01	BROWNKA_57
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1123	32382	22L0160-01	BROWNKA_58

Final Laboratory Report TEM EPA Water Analysis

Attention: Kirsten Conoran
Environmental Service Labs Inc
1803 Philadelphia Street
Indiana, PA 15701
US

Report Date: 12/19/2022
Sample Receipt Date: 12/09/2022
RJ Lee Group Job No.: ATP1068586-0
Authorization/P.O. No.:
Samples Received: 1
Client Job No.: 22L0834

Method: EPA Method 100.2 600/R-94-134

Client Sample Number	RJLG Sample Number	Date Prepped	Date Analyzed	Filter Area (mm ²)	Volume (ml)	Area Analyzed (mm ²)	Confidence Interval	Asbestos Structures >10 μm	Analytical Sensitivity (MFL)	Concentration (MFL)
22L0834-01	10575315.HTW1	12/09/2022	12/17/2022	1220	100	0.06576	>10 μm	Chry Amph	>10 μm	>10 μm
							0-4	0	0.2	< 0.2

Authorized Signature: _____



Jon Swope, Scientist

- NOTES**
- Water samples collected more than 24 hours before receipt may be out of compliance. Drinking water samples are filtered within 24 hours of receipt.
 - "<" indicates results less than analytical sensitivity. "-" indicates that sample was not analyzed.
 - Sample(s) for this project were analyzed at our: Pittsburgh, PA (AIHA LAP, LLC #292885, NYLAP #101208-0, NY ELAP # 10884) facility.
 - If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
 - Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, MFL-million fibers per liter.
 - Samples will be held for 30 days and then disposed of per Federal regulations.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

DISCLAIMER

RJ Lee Group, Inc. is accredited by the New York Department of Health, Environmental Laboratory Program (NY ELAP) and the Pennsylvania Department of Environmental Protection (PA DEP) for asbestos in water analysis by TEM. This report may not be used to claim product assessment by NY ELAP, PA DEP or any other regulatory or laboratory accrediting agency. Any reproduction of this document must be in full in order for the report to be valid. This report is not valid unless it bears the name of a NY ELAP and PA-DEP approved signatory.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limiting provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of thirty (30) days before discarding. A shipping and handling fee will be assessed for the return of any sample.



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysi s Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1094	ASBESTOS	009	0.0	0.20000		12/17/22	801		12/08/22	D	1100	02396	10575315	SLOADAML-02396_74



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 December 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22L0160
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	22L0160-01	Drinking Water	12/01/2022 11:23	12/1/22 13:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/12/2022 16:02

Lab Sample ID#: 22L0160-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 802 Room 617 Sink

Sample Date: 12/01/2022 11:23
Receipt Date: 12/01/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.640	mg/L			Client	12/01/22 11:23	12/01/22 11:23
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	12/01/22 14:53	12/02/22 15:04
E. Coli	Absent	per 100 mL		1	AMB	12/01/22 14:53	12/02/22 15:04

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVI:
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-42L

SAMPLE REQUEST & CHAIN OF CUSTODY

BE 1 OF 1



22L0160

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
804-KITCHEN-SINK 802 ROOM 617-SINK	22L0160 01	DATE	TIME	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.64 mg/L

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 12-1-22 11:23
Relinquished By: (Signature) *[Signature]* Date/ Time 12-1-22 13:20

Received By: (Signature) *[Signature]* Date/ Time
Relinquished By: (Signature) *[Signature]* Date/ Time
Relinquished By: (Signature) *[Signature]* Date/ Time

Correct Preservations Y/N/NA Y
Correct Containers Y/N/NA Y
Receipt Temperature 5.1#3

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Contact Person: 724-406-4426
Phone Number: jcampbell@moniteau.org
Cell Phone: 5100316
Billing Address:
PWSID:



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.99	120822	801		120822	D	1100	32382	22L0834-01	BROWNKA_59
5100316	1013	FREE CHLORINE	301	0.64	120122	802		120122	D	1123	32382	22L0160-01	BROWNKA_57
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	120222	802		120122	D	1123	32382	22L0160-01	BROWNKA_58