

**Moniteau School District  
Dassa McKinney Elementary  
School**

**Monthly Operations  
Information**

**Water Treatment Facility  
January 2022**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
JAN	2022						13054700			
1	Sat									
2	Sun									
3	Mon	8.7	0.00	0.44	0.48	2.56	13058400	Jeff R	3:30P	3700
4	Tues	8.7	0.01	0.48	0.55	2.88	13062600	Jeff R	3:00P	4200
5	Wed	8.7	0.02	0.78	0.85	2.96	13066800	Jeff R	3:30P	4200
6	Thurs	8.7	0.00	0.61	0.66	3.25	13071400	Jeff R	3:00P	4600
7	Fri	8.7	0.02	0.78	0.85	2.18	13074900	Jeff R	3:30P	3500
8	Sat									
9	Sun									
10	Mon	8.7	0.00	0.72	0.80	1.94	13079200	Jeff R	3:30P	4300
11	Tues	8.7	0.01	0.69	0.79	2.12	13083100	Jeff R	3:30P	3900
12	Wed	8.7	0.00	0.73	0.81	3.40	13086800	Jeff R	3:30P	3700
13	Thurs	8.7	0.02	0.76	0.83	2.97	13090700	Jeff R	3:30P	3900
14	Fri	8.7	0.00	0.73	0.83	3.25	13094700	Jeff R	3:30P	4000
15	Sat									
16	Sun									
17	Mon	8.7	0.01	0.65	0.70	1.82	13097200	Jeff R	3:30P	2500
18	Tues	8.7	0.00	0.68	0.74	1.96	13097800	Jeff R	3:00P	600
19	Wed	8.7	0.02	0.74	0.81	2.13	13101500	Jeff R	3:00P	3700
20	Thurs	8.7	0.02	0.65	0.68	2.02	13106100	Jeff C	3:30P	4600
21	Fri	8.7	0.02	0.52	0.62	2.02	13106800	Jeff C	9:30 Am	700
22	Sat									
23	Sun									
24	Mon	8.7	0.00	0.55	0.62	2.65	13113400	Jeff R	6:00P	6600
25	Tues	8.7	0.02	0.60	0.67	3.28	13116100	Jeff R	3:30P	2700
26	Wed	8.7	0.00	0.66	0.74	3.29	13119800	Jeff R	3:00P	3700
27	Thurs	8.7	0.01	0.73	0.80	3.19	13123000	Jeff R	3:30P	4200
28	Fri			Sick	Day					
29	Sat									
30	Sun									
31	Mon	8.7	0.00	0.62	0.71	2.84	13126900	Jeff R	3:00P	3900



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2010587**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	2010587-01	Drinking Water	01/06/2022 11:30	1/6/22 16:19	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Sierra Grguric  
Oil & Gas Field Supervisor/Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/12/2022 19:13

**Lab Sample ID#:** 2010587-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 01/06/2022 11:30  
**Receipt Date:** 01/06/2022 16:19

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.620	mg/L		0.200	PS	01/06/22 11:30	01/06/22 11:30
<b>Microbiology</b>	<b>Analytical Method: SM9223 B-04</b>				<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	KD	01/06/22 16:43	01/07/22 16:53
E. Coli	Absent	per 100 mL		1	KD	01/06/22 16:43	01/07/22 16:53

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

THWEST DIVISION  
Main Street  
psville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



2010587

(570) 321-9003  
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

BE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Grab Time				
801 KITCHEN SINK 802 ROOM 617 SINK	2010587	1-6-07	1130	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>0.62</u> mg/L

Rotation:  
801: Jan, Mar, May, Jul, Sep,  
Nov  
802: Feb, Apr, Jun, Aug, Oct,  
Dec

Notes/Special Instructions: *Drinking Water Dassa McKinney - Monthly*

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.8% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**  
Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**  
Contact Person:  
Phone Number:  
Cell Phone: **724-406-4426**  
Email Address: **jcampbell@moniteau.org**  
Billing Address:  
PWSID: **5100316**

Received By: (Signature) *[Signature]* Date/ Time **1-6-07 1130**  
Relinquished By: (Signature) *[Signature]* Date/ Time **1-6-07 1100**  
Relinquished By: (Signature) Date/ Time  
Relinquished By: (Signature) Date/ Time

Correct Preservations  Y / N / NA Correct Containers  Y / N / NA Receipt Temperature dis ice




E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.62	010622	801		010622	D	1130	32382	2010587-01	BROWNKA_86
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	801		010622	D	1130	32382	2010587-01	BROWNKA_87



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8378  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

15 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2011187**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	2011187-01	Drinking Water	01/13/2022 11:23	1/13/22 11:23	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions


RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Carrie Sutton-White  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/15/2022 14:52

Lab Sample ID#: 2011187-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 802 Room 617 Sink

Sample Date: 01/13/2022 11:23  
 Receipt Date: 01/13/2022 11:23

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.740	mg/L		0.200	PS	01/13/22 11:23	01/13/22 11:23



**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vorchies, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



2011187

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE \_\_\_ OF \_\_\_

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2011187	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: <u>802</u>	<u>01</u>	Date <u>11/27</u>	DW	Field	Field	Free Chlorine <u>.74</u> mg/L
		Time <u>11:23</u>				

**ROTATION**

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Sampled By: [Signature]

Date/Time

11/27 11:23

Received By: [Signature]

Date/Time

11/27 13:00

Received By: [Signature]

Date/Time

100552  
11/15/22 14:00

Notes/Special Instructions:

*Drinking Water Dassa McKinney - Weekly*

Company/Name

MONITEAU SCHOOL DISTRICT

Address

391 HOOKER ROAD  
WEST SUNBURY, PA 16061

Contact Person

JEFFREY CAMPBELL

Phone Number

724-406-4426

Cell Phone

jeffcampbell@moniteau.org

Street Address

5100316

Receipt Temperature: 5.0



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.62	010622	801		010622	D	1130	32382	2010587-01	BROWNKA_86
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	801		010622	D	1130	32382	2010587-01	BROWNKA_87
5100316	1013	FREE CHLORINE	301	0.74	011322	802		011322	D	1123	32382	2011187-01	BROWNKA_518



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

21 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2011756**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	2011756-01	Drinking Water	01/20/2022 11:20	1/20/22 14:10	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Carrie Sutton-White  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/21/2022 13:56

**Lab Sample ID#:** 2011756-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 01/20/2022 11:20  
**Receipt Date:** 01/20/2022 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.440	mg/L		0.200	PS	01/20/22 11:20	01/20/22 11:20

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



2011756

THWEST DIVISION  
Main Street  
Parsippany, NJ 07054  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

RE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>2011756</u>	<u>1-20-22</u>	<u>1130</u>	DW	Field	Field	Free Chlorine <u>44</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

*Drinking Water Dassa McKinney - Weekly*

Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>1-20-22 1130</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>1-20-22 1400</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>1-20-22 1410</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>1-20-22 1410</u>
Correct Preservations	Y / N / NA	Correct Containers	Y / N / NA
Receipt Temperature	<u>NA</u>		

Company Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**  
 Contact Person:  
 Phone Number:  
 Cell Phone: **724-406-4426**  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address:  
 PWSID: **5100316**

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.62	010622	801		010622	D	1130	32382	2010587-01	BROWNKA_86
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	801		010622	D	1130	32382	2010587-01	BROWNKA_87
5100316	1013	FREE CHLORINE	301	0.74	011322	802		011322	D	1123	32382	2011187-01	BROWNKA_518
5100316	1013	FREE CHLORINE	301	0.44	012022	803		012022	D	1120	32382	2011756-01	BROWNKA_780



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

28 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2012244**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	2012244-01	Drinking Water	01/27/2022 10:10	1/27/22 13:05	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

The results contained in this Report of Analysis do not exceed the published Pennsylvania Department of Environmental Protection Division of Drinking Water Management's Maximum Contaminant Levels (MCLs) for primary drinking water contaminants.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1800 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/28/2022 12:52

Lab Sample ID#: 2012244-01  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Paul Somogyi  
Client Sample ID: 804 Room 408 Sink

Sample Date: 01/27/2022 10:10  
Receipt Date: 01/27/2022 13:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.610	mg/L		0.200	PS	01/27/22 10:10	01/27/22 10:10



**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVI  
1276 Bentleyville  
Van Voorhis, PA  
(724) 258-TEST  
FAX: (724) 258-4

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 455-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

Page 3 of 4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SASH</u>	<u>2012244</u>	<u>1-27-07</u>	<u>1010</u>	DW	Field	Field	Free Chlorine <u>0.1</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>1-27-07 1010</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>1-27-07 1305</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>			
<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.org</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: _____</p> <p>PWSID: <b>5100316</b></p>				<p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.62	010622	801		010622	D	1130	32382	2010587-01	BROWNKA_86
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	801		010622	D	1130	32382	2010587-01	BROWNKA_87
5100316	1013	FREE CHLORINE	301	0.74	011322	802		011322	D	1123	32382	2011187-01	BROWNKA_518
5100316	1013	FREE CHLORINE	301	0.44	012022	803		012022	D	1120	32382	2011756-01	BROWNKA_780
5100316	1013	FREE CHLORINE	301	0.61	012722	804		012722	D	1010	32382	2012244-01	BROWNKA_1307

**Moniteau School District  
Moniteau High School  
Monthly Operations  
Information  
Water Treatment Facility  
January 2022**

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT												
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME			
1	SAT	46.7	8.64	5,516,621	0.74	0.80	7.1	0.02	0	Jeff C	8:00 AM			
2	SUN	45.9	8.64	5,576,621	0.73	0.81	7.1	0.03	0	Jeff C	8:00 AM			
3	MON	45.5	8.64	5,516,621	0.73	0.81	7.1	0.03	0	Jeff C	8:00 AM			
4	Tues	44.0	7.10	5,516,621	0.72	0.81	7.1	0.02	0	Jeff C	9:00 AM			
5	Wed	51.1	11.40	5,532,891	0.73	0.81	7.2	0.03	0	Jeff C	9:30 AM			
6	Thurs	46.5	7.64	5,532,891	0.74	0.81	7.2	0.03	0	Jeff C	9:00 AM			
7	Fri	45.8	8.25	5,532,891	0.73	0.81	7.2	0.02	0	Jeff C	9:00 AM			
8	SAT	50.1	11.36	5,546,420	0.75	0.82	7.2	0.01	0	Jeff C	9:00 AM			
9	SUN	43.2	10.70	5,546,420	0.73	0.80	7.1	0.03	0	Jeff C	4:00 PM			
10	MON	43.0	10.70	5,546,420	0.72	0.80	7.1	0.03	0	Jeff C	7:00 AM			
11	Tues	42.5	8.32	5,546,420	0.72	0.80	7.1	0.03	0	Jeff C	9:00 AM			
12	Wed	42.5	7.40	5,546,420	0.73	0.80	7.1	0.02	0	Jeff C	9:00 AM			
13	Thurs	49.9	10.90	5,562,455	0.62	0.71	7.1	0.02	0	Jeff C	9:00 AM			
14	Fri	47.2	9.69	5,562,455	0.69	0.77	7.1	0.03	0	Jeff C	12:30 PM			
15	SAT	45.0	9.52	5,562,455	0.67	0.76	7.1	0.03	0	Jeff C	9:30 AM			
16	SUN	44.1	8.90	5,562,455	0.67	0.75	7.1	0.03	0	Jeff C	9:00 AM			
17	MON	42.7	8.42	5,562,455	0.63	0.68	7.1	0.02	0	Jeff C	9:00 AM			
18	Tues	40.2	7.55	5,562,455	0.61	0.67	7.1	0.02	0	Jeff C	5:00 AM			
19	Wed	48.9	11.58	5,578,895	0.65	0.72	7.1	0.03	0	Jeff C	6:00 AM			
20	Thur	45.2	9.66	5,578,895	0.63	0.72	7.1	0.03	0	Jeff C	7:00 AM			
21	Fri	43.2	8.18	5,578,895	0.63	0.73	7.1	0.03	0	Jeff C	10:00 AM			
22	SAT	43.1	7.99	5,578,895	0.64	0.73	7.1	0.03	0	Jeff C	8:30 AM			
23	SUN	42.9	7.10	5,578,895	0.63	0.73	7.1	0.03	0	Jeff C	8:00 AM			
24	MON	42.7	9.37	5,593,426	0.65	0.75	7.1	0.02	0	Jeff C	2:00 PM			
25	Tues	42.0	8.37	5,593,426	0.59	0.69	7.1	0.02	0	Jeff C	9:00 AM			
26	Wed	49.2	10.25	5,605,041	0.62	0.71	7.1	0.02	0	Jeff C	3:00 PM			
27	Thurs	44.6	10.77	5,611,285	0.55	0.61	7.0	0.02	0	Jeff C	3:00 PM			
28	Fri	44.4	9.99	5,611,285	0.55	0.62	7.0	0.02	0	Jeff C	2:00 PM			
29	SAT									Jeff C	10:00 AM			
30	SUN													
31	MON	40.2	7.59	5,611,285	0.55	0.61	7.0	0.02	0	Jeff C	1:28			

Meter Reading on 12/31/21 - 5,516,621

█ = Sewage Testing █ = WATER TESTING.



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2010588**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	2010588-01	Drinking Water	01/06/2022 11:55	1/6/22 16:19	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Sierra Grguric  
Oil & Gas Field Supervisor/Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/12/2022 19:13

**Lab Sample ID#:** 2010588-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 01/06/2022 11:55  
**Receipt Date:** 01/06/2022 16:19


Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-CI G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.780	mg/L		0.200	PS	01/06/22 11:55	01/06/22 11:55
<b>Microbiology</b>	<b>Analytical Method: SM9223 B-04</b>				<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	KD	01/06/22 16:43	01/07/22 16:53
E. Coli	Absent	per 100 mL		1	KD	01/06/22 16:43	01/07/22 16:53

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



FOR INTERNAL LABORATORY USE ONLY



WEST DIVISION  
West  
PA 16150  
EST  
FAX: (724) 465-4209



**SAMPLE REQUEST & CHAIN OF CUSTODY**

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	2010588 CA	1-6-22	1155	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine .78

704: Jan, Mar, May, Jul, Sept, Nov  
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Monthly

Sampled By: (Signature) *[Signature]* Date/ Time 1-6-22 1155  
 Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-22 1615  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) *[Signature]* Date/ Time 1-6-22 1615  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Correct Preservations (Y) / N / NA (Y) / N / NA Correct Containers (Y) / N / NA (Y) / N / NA Receipt Temperature 2.5 (100)

Company/Name: MONITEAU SCHOOL DISTRICT  
 Address: 1810 WEST SUNBURY ROAD  
 WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: jcampbell@moniteau.org  
 Billing Address: 5100324  
 PWSID: 5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.78	010622	704		010622	D	1155	32382	2010588-01	BROWNKA_90
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	704		010622	D	1155	32382	2010588-01	BROWNKA_91





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

21 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2011755**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	2011755-01	Drinking Water	01/20/2022 11:40	1/20/22 14:10	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit


### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

*Carrie Sutton-White*

Carrie Sutton-White  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/21/2022 13:56

**Lab Sample ID#:** 2011755-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 01/20/2022 11:40  
**Receipt Date:** 01/20/2022 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.560	mg/L		0.200	PS	01/20/22 11:40	01/20/22 11:40

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTER**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHERN DIVI'**  
435 Broad Street  
Montoursville, PA  
(570) 321-9003  
FAX: (570) 321-

FOR INTERNAL LABORATORY USE ONLY.



2011755

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E \_\_\_ 1 \_\_\_ OF \_\_\_ 1 \_\_\_

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>SOS</u>	2011755	1-20-22	1140	DW	Field	Field	Free Chlorine <u>5.56</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p><b>ROTATION</b></p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>1-20-22 1140</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>1-20-22 1410</u></p>				<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>1/20/22 1410</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y / N / <u>NA</u></p>				<p>Correct Containers Y / N / <u>NA</u></p> <p>Receipt Temperature <u>N/A</u></p>			
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>							
<p>Company Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD</b> <b>WEST SUNBURY, PA 16061</b> <b>JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.org</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: _____</p> <p>PWSID: <b>5100324</b></p>							

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.78	010622	704		010622	D	1155	32382	2010588-01	BROWNKA_90
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	704		010622	D	1155	32382	2010588-01	BROWNKA_91
5100324	1013	FREE CHLORINE	301	0.7	011322	802		011322	D	1140	32382	2011188-01	BROWNKA_519
5100324	1013	FREE CHLORINE	301	0.56	012022	803		012022	D	1140	32382	2011755-01	BROWNKA_779



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

28 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 2012245  
Project: Drinking Water Moniteau Jr/Sr - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	2012245-01	Drinking Water	01/27/2022 10:35	1/27/22 13:05	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

The results contained in this Report of Analysis do not exceed the published Pennsylvania Department of Environmental Protection Division of Drinking Water Management's Maximum Contaminant Levels (MCLs) for primary drinking water contaminants.

### Definitions


RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/28/2022 12:52

Lab Sample ID#: 2012245-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 804 400 Hall RR Sink

Sample Date: 01/27/2022 10:35  
 Receipt Date: 01/27/2022 13:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-II				Prep Method: No Prep - Field		
Chlorine, Free	0.600	mg/L		0.200	PS	01/27/22 10:35	01/27/22 10:35

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHWEST DIVISION  
850 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>2012245</u>	<u>1977</u>	<u>1655</u>	DW	Field	Field	Free Chlorine <u>0.60</u> mg/L
ROTATION							
Wk 1 - 704 Kitchen Sink							
Wk 2 - 802 Room 204 Sink							
Wk 3 - 803 Admin Sink							
Wk 4 - 804 400 Hall RR Sink							
Wk 5 - 804 400 Hall RR Sink							

Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly

Company Name: MONITEAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: jcampbell@moniteau.org  
 Email Address: 724-406-4426  
 Billing Address: jcampbell@moniteau.org  
 PWSID: 5100324

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OF THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 1-27-27 1655  
 Relinquished By: (Signature) [Signature] Date/ Time 1-27-27 1807  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) [Signature] Date/ Time 127722 1305

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.78	010622	704		010622	D	1155	32382	2010588-01	BROWNKA_90
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010722	704		010622	D	1155	32382	2010588-01	BROWNKA_91
5100324	1013	FREE CHLORINE	301	0.7	011322	802		011322	D	1140	32382	2011188-01	BROWNKA_519
5100324	1013	FREE CHLORINE	301	0.56	012022	803		012022	D	1140	32382	2011755-01	BROWNKA_779
5100324	1013	FREE CHLORINE	301	0.6	012722	804		012722	D	1035	32382	2012245-01	BROWNKA_1308



**Moniteau School District**  
**Moniteau High School**  
**Monthly Operations**  
**Information**  
**Wastewater Treatment Facility**  
**January 2022**

Moniteau High School Sewage Treatment Plant				Daily Operations Worksheet					
Permit # PA0091341				JAN 2022					
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month UV	Meter Reading	Time	Operator
1/11	SAT	6.89	9.85	7.40	8.01	5.9	5,516,621	8:30 AM	JEFF C
1/12	SUN	7.01	9.73	7.60	7.93	6.0		8:30 AM	JEFF C
1/13	MON	7.07	9.66	7.69	7.51	6.2		11:00 AM	JEFF C
1/14	Tues	6.84	10.38	7.18	8.53	6.5		8:00 AM	JEFF C
1/15	wed	6.62	11.65	6.84	9.00	6.9		8:00 AM	JEFF C
1/16	Thurs	6.60	11.70	6.78	9.05	6.5		10:00 AM	JEFF C
1/17	FRI	6.61	11.65	6.65	9.78	6.3		8:00 AM	JEFF C
1/18	SAT	6.65	10.98	6.53	10.01	6.3		8:00 AM	JEFF C
1/19	SUN	6.65	10.75	6.47	10.52	5.9		7:30 AM	JEFF C
1/20	MON	6.68	10.55	6.25	10.79	5.0		10:00 AM	JEFF C
1/21	Tues	6.70	10.50	6.38	10.68	5.0		1:30 PM	JEFF C
1/22	wed	AERATION		6.54	6.75	5.0		1:30 PM	JEFF C
1/23	Thurs	6.56	10.01	6.50	7.38	4.8		11:00 AM	JEFF C
1/24	FRI	6.32	9.17	6.41	8.66	4.8		10:00 AM	JEFF C
1/25	SAT	6.30	9.28	6.42	8.68	4.8		9:00 AM	JEFF C
1/26	SUN	6.25	9.90	6.42	8.70	4.9		9:00 AM	JEFF C
1/27	MON	6.25	9.91	6.48	8.87	4.8		7:00 AM	JEFF C
1/28	Tues	6.20	9.83	6.50	8.81	5.0		9:00 AM	JEFF C
1/29	wed	6.18	10.40	6.49	8.80	4.9		9:15 AM	JEFF C
1/30	Thurs	6.17	10.63	6.50	8.83	4.8		10:30 AM	JEFF C
1/31	FRI	6.15	10.65	6.52	8.85	4.8		10:00 AM	JEFF C
1/23	SAT	N/R							
1/23	SUN	6.17	10.12	6.97	8.32	5.0		6:00 PM	JEFF C
1/24	MON	6.20	9.86	7.01	7.59	5.9		1:30 PM	JEFF C
1/25	Tues	6.28	10.02	7.00	8.56	5.3		10:00 AM	JEFF C
1/26	wed	6.31	10.31	6.99	8.73	5.3		1:00 PM	JEFF C
1/27	Thurs	6.41	10.48	6.97	9.13	4.9	5,611,285	3:30 PM	JEFF C
1/28	FRI								
1/29	SAT					141.5			
1/30	SUN					-26			
1/31	MON					5.44			

\*  
ESL TEST DAY

\*  
TEST DAY

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2022  
 DMR Effective To: 01/31/2022  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	01	01	2022	01	31

FROM

PARAMETER	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	***	***	6.75	***	1/week	Grab
	***	***	4.0 Min	***	1/week	Grab
pH (00400)	***	***	6.15	7.69	1/week	Grab
	***	***	6.0 Min	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	***	***	<5.0	***	2/month	Grab
	***	***	30 Avg Mo	***	2/month	Grab
Total Nitrogen (00600)	***	***	1.365	***	2/month	Grab
	***	***	*** Monitor & Report Avg Mo	***	2/month	Grab
Total Phosphorus (00665)	***	***	.195	***	2/month	Grab
	***	***	*** Monitor & Report Avg Mo	***	2/month	Grab
Ultraviolet light intensity (49607)	***	***	5.44	***	1/week	Grab
	***	***	*** Monitor & Report Avg Mo	***	1/week	Grab
Flow (50050)	.003053	***	***	***	1/week	Measured
	*** Monitor & Report Avg Mo	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	...	...	...	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	...	...	...	2000	10000			
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	...	...	...	Geo Mean	IMAX		2/month	Grab
	PERMIT REQUIREMENT	...	...	...	<2.00	...		2/month	Grab
Facility Comments		...	...	...	25	...	mg/L	2/month	Grab
					Avg Mo				

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

---

## Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

---

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Feb 14, 2022 at 10:16 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 01/01/2022-01/31/2022  
**Report Due Date:** 02/28/2022

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 313500  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Flow			94,664	= 31	3053.61
U.V.	—	—	141.5	÷ 26	5.44
PH	Low		1/21/22	6.15	# 1
	High		1/31/22	7.69	# 2
D.O.	Low		1/12/22	6.75	# 2
	High		1/6/22	11.70	# 1
TOTAL Nitrogen	0.880	1.95	2.73	÷ 2	= 1.365
TSS	< 5	< 5			= < 5
Total K-Nitrogen	< 0.625	< 0.625			= < 0.625
Nitrate / Nitrite	0.880	1.95	2.73	÷ 2	= 1.365
Phosphorus	< 0.10	0.29	0.39	÷ 2	= 0.195
CBOD	< 2.00	< 2.00			< 2.00
Fecal Coliforms	< 1	< 1			< 1



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

02 February 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 2011666  
Project: Wastewater  
Project Description: Wastewater

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2011666-01	Waste Water	01/20/2022 11:00	1/20/22 14:15	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

Carrie Sutton-White  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 02/02/2022 11:07

**Lab Sample ID#:** 2011666-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 01/20/2022 11:00  
**Receipt Date:** 01/20/2022 14:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	1.85	mg/L		0.729	DAA	01/30/22 12:30	02/01/22 12:07
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	TLL	01/27/22 17:55	01/27/22 17:55
General Chemistry	Analytical Method: SM4500 NH3 F-11				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	01/30/22 12:30	02/01/22 12:07
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.85	mg/L		0.104	AW	01/26/22 13:15	01/26/22 13:15
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.29	mg/L		0.10	AW	01/31/22 15:20	01/31/22 15:20
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G	2.00	AS	01/21/22 14:15	01/26/22 09:35
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	VSJ	01/20/22 14:28	01/21/22 11:20



**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTERS  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Benileville Road  
Van Vorthis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

PAGE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESI#	Sample Type		Date	Time	Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab						
		Date enflr	Time enflr						
Effluent Outfall 001	0011000			1/20/22	11:00 AM	WW	1	Poly 1000mL	CBOD, TSS
						WW	1	None	Total Nitrogen, Total Phosphorus
						WW	1	H2SO4	Fecal Coliform
								Sterile Plastic 125mL	
								Na2S2O3	

Project Notes:

Wastewater

Company/Name: MONTEAU SCHOOL DISTRICT  
 Contact Person: JEFFREY CAMPBELL  
 Address: 1810 WEST SUNBURY ROAD  
 WEST SUNBURY, PA 16061  
 Phone / Cell: 724-406-4426  
 Email: jcampbell@monteau.org

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 1/20/22 11:00 AM  
 Relinquished By: (Signature) [Signature] Date/ Time 1/20/22 11:35  
 Relinquished By: (Signature) [Signature] Date/ Time 1/20/22 1400  
 Relinquished By: (Signature) [Signature] Date/ Time 1/20/22 1405  
 Relinquished By: (Signature) [Signature] Date/ Time 1/20/22 1405

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



### SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	W	2011666	here)
------------------------	---	---------	-------

**PART A: GENERAL INFORMATION- SATELLITE LABORATORY**

Received by/Lab ID: _____	Date/Time Received:    /    /    _____
Method of Delivery: Client Drop-Off    ESL Courier    Other: _____	Received on Ice?    YES    NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of:    FECAL    TC/EC    TC MPN    EC MPN    TC/EC MPN <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">N/A</span>	

**PART B: GENERAL INFORMATION- INDIANA LABORATORY**

Received by/Lab ID: <u>JWD/CJSS</u>	Samples Received on Ice? <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span> NO
Date/Time Received: <u>1/20/22 1:15</u>	Date Sampled: <u>1/20/22</u>
Method of Delivery:    FedEx    UPS    Client Drop off <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">ESL courier</span> Other: _____	
Sample Receipt Temperature: <u>3.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">PA</span> NY    OH    WV    Other: _____	PWSID Compliance Drinking Water Samples:    YES <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">NO</span>

**PART C: Receipt Details**    Completed (if different from above): \_\_\_\_\_    Signature \_\_\_\_\_    Date \_\_\_\_\_    Time \_\_\_\_\_

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Comments:
COC form is properly signed in relinquished/received sections?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Comments:
Sample containers intact and sealed?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Circle Applicable:    Damaged Container    Leaking Container Custody Seal Broken    Other: _____
Number of containers received matches number indicated on COC?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Sample IDs and Containers Affected:
Samples received within holding time?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	For non-WW samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">YES</span>	NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	<span style="border: 1px solid black; border-radius: 50%; padding: 2px;">NO</span>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created:  YES <span style="border: 1px solid black; border-radius: 50%; padding: 2px;">NO</span>

Effective Date:



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

20 January 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 2010547  
Project: Wastewater  
Project Description: Wastewater

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2010547-01	Waste Water	01/06/2022 11:00	1/6/22 16:30	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units


### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

Carrie Sutton-White  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/20/2022 09:11

Lab Sample ID#: 2010547-01  
Sample Type: Waste Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Effluent Outfall 001

Sample Date: 01/06/2022 11:00  
Receipt Date: 01/06/2022 16:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	0.880	mg/L		0.729	DAA	01/17/22 13:52	01/18/22 11:27
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	01/11/22 11:29	01/11/22 13:45
<b>General Chemistry</b>	<b>Analytical Method: SM4500 NH3 F-11</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	01/15/22 06:20	01/18/22 11:27
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	0.880	mg/L		0.104	AW	01/17/22 13:52	01/17/22 13:52
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	<0.10	mg/L		0.10	AW	01/17/22 12:35	01/17/22 12:35
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, G, SS	2.00	AS	01/07/22 19:30	01/12/22 14:00
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	VSJ	01/06/22 16:36	01/07/22 10:47

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTERS**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Benileville Road  
Van Vochis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



**NORTHWEST DIVISION**  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Date	Grab	Time	Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Time on/off							
Effluent Outfall 001	2010547			1/6/20		11:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
							WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
							WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

Project Notes:

1. THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
2. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
3. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 1-6-20 11:00 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 1-6-20 11:50


Wastewater

Company/Name: MONTEAU SCHOOL DISTRICT  
Contact Person: JEFFREY CAMPBELL  
Address: 1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061  
Phone / Cell: 724-406-4426  
Email: jcampbell@monteau.org

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



## SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monitro</u>	Work Ord  2010547
------------------------	--

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>(N/A)</u>	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SPM/00382</u>	Samples Received on Ice? <u>(YES)</u> NO
Date/Time Received: <u>11/6/22 10:30</u>	Date Sampled: <u>11/6/22</u>
Method of Delivery: FedEx UPS Client Drop off <u>(ESL courier)</u> Other: _____	
Sample Receipt Temperature: <u>32</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>(PA)</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>(NO)</u>

## PART C: Receipt Details Completed (if different from above): \_\_\_\_\_ / / \_\_\_\_\_

Sample Receipt Criteria	Signature		Date		Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>(YES)</u>	NO				Comments:
COC form is properly signed in relinquished/received sections?	<u>(YES)</u>	NO				Comments:
Sample containers intact and sealed?	<u>(YES)</u>	NO				Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>(YES)</u>	NO				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>(YES)</u>	NO				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>(YES)</u>	NO				Sample IDs and Containers Affected:
Samples received within holding time?	<u>(YES)</u>	NO				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>(YES)</u>	NO				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>(YES)</u>	NO				For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>(YES)</u>	NO				Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>(YES)</u>	<u>(NO)</u>				Sample IDs and Containers Affected:
Other Comments:						Deficiency Log Created: YES <u>(NO)</u>

Effective Date:

GP.25.A-1 Sample Receipt Log