

Moniteau School District
Monthly Operations Report

November 2020

Dassa McKinney Elementary School

Water Treatment facility

Dassa McKinney Elementary School Water Treatment Facility										
Month	NOV	2020								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sun									
2	Mon	7.9	0.00	0.40	0.48	2.13	12188600	Jeff R	4:30P	4600
3	Tues	8.0	0.01	0.54	0.62	2.21	12188600	Jeff R	3:30P	0
4	Wed	8.0	0.03	0.56	0.66	2.18	12189400	Jeff R	3:30P	800
5	Thurs	8.0	0.01	0.50	0.55	2.23	12190100	Jeff R	3:00P	700
6	Fri	7.9	0.02	0.46	0.51	1.98	12190800	Jeff R	4:30P	700
7	Sat									
8	Sun									
9	Mon	8.0	0.02	0.42	0.48	2.25	12192100	Jeff R	3:30P	1300
10	Tues	7.9	0.03	0.44	0.49	1.94	12192700	Jeff R	3:30P	600
11	Wed	8.0	0.03	0.38	0.45	1.99	12193700	Jeff R	4:30P	1000
12	Thurs	8.0	0.03	0.41	0.47	1.77	12193800	Jeff R	3:30P	100
13	Fri	7.9	0.02	0.43	0.50	1.89	12195200	Jeff R	4:30P	1400
14	Sat									
15	Sun									
16	Mon	8.2	0.00	0.42	0.50	1.48	12196100	Jeff R	2:30P	900
17	Tues	8.2	0.00	0.42	0.48	1.50	12201200	Jeff C	4:30P	5100
18	Wed	7.9	0.00	0.50	0.56	0.70	12205100	Jeff C	7:30A	3900
19	Thurs	8.0	0.00	0.65	0.70	0.72	12211100	Jeff C	3:00 Am	
20	Fri	8.0	0.00	0.78	0.81	0.71	12214900	Jeff C	9:30 Am	
21	Sat									
22	Sun									
23	Mon	8.0	0.00	0.95	1.01	2.65	12222600	Jeff C	3:00 pm	
24	Tues	8.0	0.00	0.87	0.94	2.02	12223100	Jeff C	11:00 AM	
25	Wed	8.0	0.02	0.83	0.90	1.88	12224300	Jeff C	10:00 AM	
26	Thurs	No School		Holiday			Closed			
27	Fri	No School		Holiday			Closed			
28	Sat									
29	Sun									
30	Mon	NO School		Holiday			Closed			
31										

Meter Reading 10/30/20 - 12184000



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0110486
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0110486-01	Drinking Water	11/05/2020 12:25	11/5/20 14:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/11/2020 10:15

Lab Sample ID#: 0110486-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 11/05/2020 12:25
Receipt Date: 11/05/2020 14:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.610	mg/L		0.200	PFS	11/05/20 12:25	11/05/20 12:25
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	11/05/20 15:21	11/06/20 15:55
E. Coli	Absent	per 100 mL		1	KEL	11/05/20 15:21	11/06/20 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NOR
435 E
Mont
(570)
FAX:



VISION

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK		11-5-20	12:25	DW	11/5/20 1444 VEL ice	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>0.61</u> mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) [Signature] Date/ Time 11-5-20 12:25
 Relinquished By: (Signature) [Signature] Date/ Time 11-5-20 14:35
 Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) [Signature] Date/ Time 11/5/20 15:10
 Received By: (Signature) _____ Date/ Time _____
 Received By: (Signature) _____ Date/ Time _____

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: _____
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.k12.pa.us**
 Billing Address: _____
 PWSID: **5100316**

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNKA_178



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111080
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0111080-01	Drinking Water	11/12/2020 11:23	11/12/20 19:08	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/13/2020 09:53

Lab Sample ID#: 0111080-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 11/12/2020 11:23
Receipt Date: 11/12/2020 19:08

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.510	mg/L		0.200	PFS	11/12/20 11:23	11/12/20 11:23

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Page 3 of 4

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>802</u>	<u>0111080</u>	<u>11/2/20</u>	<u>1123</u>	DW	Field	Field	Free Chlorine <u>.51</u> mg/L

- ROTATION**
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) [Signature] Date/ Time 11/2/20 1123

Relinquished By: (Signature) [Signature] Date/ Time 11/2/20 1410

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: _____

PWSID: **5100316**

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNSKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNSKA_178
5100316	1013	FREE CHLORINE	301	0.51	111220	802		111220	D	1123	32382	0111080-01	BROWNSKA_375



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111660
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0111660-01	Drinking Water	11/19/2020 11:05	11/20/20 9:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/20/2020 11:22

Lab Sample ID#: 0111660-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 11/19/2020 11:05
Receipt Date: 11/20/2020 09:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.470	mg/L		0.200	PFS	11/19/20 11:05	11/19/20 11:05

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00149	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_644
5100316	2451	DICHLOROACETIC ACID	206	0.00666	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_648
5100316	2452	TRICHLOROACETIC ACID	206	0.0011	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_650
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_653
5100316	2454	DIBROMOACETIC ACID	206	0.00106	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_657
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0103	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_660
5100316	2941	CHLOROFORM (THM)	221	0.0243	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_663
5100316	2942	BROMOFORM (THM)	221	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_665
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0118	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_669
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00459	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_672
5100316	2950	TRIHALOMETHANES	221	0.0408	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_675
5100316	2450	MONOCHLOROACETIC ACID	206	0.00151	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_645
5100316	2451	DICHLOROACETIC ACID	206	0.0057	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_647
5100316	2452	TRICHLOROACETIC ACID	206	0.00114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_651
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_654
5100316	2454	DIBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_656
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00835	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_659
5100316	2941	CHLOROFORM (THM)	221	0.0226	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_662
5100316	2942	BROMOFORM (THM)	221	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_666

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_668
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00381	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_671
5100316	2950	TRihalOMETHANES	221	0.0379	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_674
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	0.51	111220	802		111220	D	1123	32382	0111080-01	BROWNKA_375
5100316	1013	FREE CHLORINE	301	0.47	111920	803		111920	D	1105	32382	0111660-01	BROWNKA_810



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111831
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0111831-01	Drinking Water	11/23/2020 09:30	11/23/20 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/24/2020 10:39

Lab Sample ID#: 0111831-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 11/23/2020 09:30
Receipt Date: 11/23/2020 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.390	mg/L		0.200	PFS	11/23/20 09:30	11/23/20 09:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

0111831

ORTHWEST DIVISION
Main Street
Pittsburgh, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab					
		Date	Time			Preservative	
Distribution: <u>804</u>	<u>0111831</u>	<u>11-23-20</u>	<u>0930</u>	DW	Field	Field	Free Chlorine <u>.39</u> mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) [Signature] Date/ Time 11-23-20 0930

Relinquished By: (Signature) [Signature] Date/ Time 11-23-20 1438

Received By: (Signature) [Signature] Date/ Time 11-23-20 1445

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature —

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: _____

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: _____

PWSID: **5100316**

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00149	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_644
5100316	2451	DICHLOROACETIC ACID	206	0.00666	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_648
5100316	2452	TRICHLOROACETIC ACID	206	0.0011	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_650
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_653
5100316	2454	DIBROMOACETIC ACID	206	0.00106	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_657
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0103	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_660
5100316	2941	CHLOROFORM (THM)	221	0.0243	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_663
5100316	2942	BROMOFORM (THM)	221	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_665
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0118	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_669
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00459	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_672
5100316	2950	TRIHALOMETHANES	221	0.0408	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_675
5100316	2450	MONOCHLOROACETIC ACID	206	0.00151	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_645
5100316	2451	DICHLOROACETIC ACID	206	0.0057	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_647
5100316	2452	TRICHLOROACETIC ACID	206	0.00114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_651
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_654
5100316	2454	DIBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_656
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00835	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_659
5100316	2941	CHLOROFORM (THM)	221	0.0226	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_662
5100316	2942	BROMOFORM (THM)	221	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_666

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_668
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00381	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_671
5100316	2950	TRihalOMETHANES	221	0.0379	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_674
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	0.51	111220	802		111220	D	1123	32382	0111080-01	BROWNKA_375
5100316	1013	FREE CHLORINE	301	0.47	111920	803		111920	D	1105	32382	0111660-01	BROWNKA_810

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



ORTHWEST DIVISION
Main Street
Pittsburgh, PA 15201
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>0111831</u>	<u>11-23-20</u>	<u>0930</u>	DW	Field	Field	Free Chlorine <u>.39</u> mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink



Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) 	Date/ Time <u>11-23-20 0930</u>	Received By: (Signature) <u>CS</u>	Date/ Time <u>11/23/20 1445</u>
Relinquished By: (Signature) 	Date/ Time <u>11-23-20 1438</u>	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number:

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address:

PWSID: **5100316**

Correct Preservations Y / N (NA)

Correct Containers Y / N (NA)

Receipt Temperature —

Department of Environmental Protection

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00149	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_644
5100316	2451	DICHLOROACETIC ACID	206	0.00666	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_648
5100316	2452	TRICHLOROACETIC ACID	206	0.0011	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_650
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_653
5100316	2454	DIBROMOACETIC ACID	206	0.00106	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_657
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0103	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_660
5100316	2941	CHLOROFORM (THM)	221	0.0243	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_663
5100316	2942	BROMOFORM (THM)	221	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_665
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0118	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_669
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00459	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_672
5100316	2950	TRIHALOMETHANES	221	0.0408	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_675
5100316	2450	MONOCHLOROACETIC ACID	206	0.00151	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_645
5100316	2451	DICHLOROACETIC ACID	206	0.0057	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_647
5100316	2452	TRICHLOROACETIC ACID	206	0.00114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_651
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_654
5100316	2454	DIBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_656
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00835	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_659
5100316	2941	CHLOROFORM (THM)	221	0.0226	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_662
5100316	2942	BROMOFORM (THM)	221	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_666

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_668
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00381	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_671
5100316	2950	TRihalOMETHANES	221	0.0379	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_674
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	0.51	111220	802		111220	D	1123	32382	0111080-01	BROWNKA_375
5100316	1013	FREE CHLORINE	301	0.47	111920	803		111920	D	1105	32382	0111660-01	BROWNKA_810
5100316	1013	FREE CHLORINE	301	0.39	112320	804		112320	D	0930	32382	0111831-01	BROWNKA_949



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111831
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0111831-01	Drinking Water	11/23/2020 09:30	11/23/20 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/24/2020 10:39

Lab Sample ID#: 0111831-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 11/23/2020 09:30
Receipt Date: 11/23/2020 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.390	mg/L		0.200	PFS	11/23/20 09:30	11/23/20 09:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

BE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

0111831

ORTHWEST DIVISION
Main Street
Pittsburgh, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>0111831</u>	<u>11-23-20</u>	<u>0930</u>	DW	Field	Field	Free Chlorine <u>.39</u> mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink


THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) 	Date/ Time <u>11-23-20 0930</u>	Received By: (Signature) <u>ca</u>	Date/ Time <u>11/23/20 1445</u>
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature —

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number:

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address:

PWSID: **5100316**

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00149	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_644
5100316	2451	DICHLOROACETIC ACID	206	0.00666	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_648
5100316	2452	TRICHLOROACETIC ACID	206	0.0011	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_650
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_653
5100316	2454	DIBROMOACETIC ACID	206	0.00106	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_657
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.0103	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_660
5100316	2941	CHLOROFORM (THM)	221	0.0243	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_663
5100316	2942	BROMOFORM (THM)	221	0.0	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_665
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0118	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_669
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00459	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_672
5100316	2950	TRIHALOMETHANES	221	0.0408	111720	703		110920	D	0850	32382	0110657-01	BROWNKA_675
5100316	2450	MONOCHLOROACETIC ACID	206	0.00151	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_645
5100316	2451	DICHLOROACETIC ACID	206	0.0057	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_647
5100316	2452	TRICHLOROACETIC ACID	206	0.00114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_651
5100316	2453	MONOBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_654
5100316	2454	DIBROMOACETIC ACID	206	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_656
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00835	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_659
5100316	2941	CHLOROFORM (THM)	221	0.0226	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_662
5100316	2942	BROMOFORM (THM)	221	0.0	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_666

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.0114	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_668
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00381	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_671
5100316	2950	TRIHALOMETHANES	221	0.0379	111720	704		110920	D	0900	32382	0110657-02	BROWNKA_674
5100316	1013	FREE CHLORINE	301	0.61	110520	801		110520	D	1225	32382	0110486-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	801		110520	D	1225	32382	0110486-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	0.51	111220	802		111220	D	1123	32382	0111080-01	BROWNKA_375
5100316	1013	FREE CHLORINE	301	0.47	111920	803		111920	D	1105	32382	0111660-01	BROWNKA_810
5100316	1013	FREE CHLORINE	301	0.39	112320	804		112320	D	0930	32382	0111831-01	BROWNKA_949

Moniteau School District
Monthly Operations Report
November 2020
Moniteau High School
Water Treatment facility

MONITEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	NOV	2020	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	SUN											
2	MON	52.0	9.24	4,038,486	0.87	1.06	7.5	0.00	0			
3	Tues	51.0	8.49	4,038,486	0.90	1.06	7.5	0.00	0	0.91	Jeff C	7:00 AM
4	Wed	53.0	9.55	4,043,313	0.94	1.10	7.4	0.00	0	0.93	Jeff C	8:00 AM
5	Thurs	54.0	8.50	4,043,313	0.94	1.06	7.4	0.00	0	0.97	Jeff C	10:00 AM
6	Fri	57.1	9.70	4,052,664	0.78	0.91	7.3	0.00	0	0.99	Jeff C	10:00 AM
7	SAT											
8	SUN											
9	MON	59.3	8.20	4,052,664	0.85	0.95	7.3	0.03	0			
10	Tues	61.0	9.52	4,057,299	0.88	0.97	7.3	0.01	0	1.22	Jeff R	11:30 AM
11	Wed	62.0	9.04	4,057,299	0.90	0.99	7.3	0.01	0	1.00	Jeff R	11:30 AM
12	Thurs	61.5	8.42	4,057,299	0.89	0.98	7.3	0.01	0	0.99	Jeff C	08:00 AM
13	Fri	60.2	9.34	4,066,369	0.90	0.98	7.3	0.00	0	0.99	Jeff C	08:30 AM
14	SAT											
15	SUN											
16	MON	54.7	8.52	4,066,369	0.71	0.84	7.4	0.01	0			
17	Tues	54.9	9.14	4,071,878	0.73	0.84	7.3	0.00	0	1.19	Jeff C	8:00 AM
18	Wed	51.3	8.03	4,071,878	0.72	0.84	7.3	0.00	0	0.85	Jeff C	10:30 AM
19	Thurs	52.5	9.11	4,081,683	0.62	0.77	7.4	0.00	0	0.87	Jeff C	9:00 AM
20	Fri	56.0	9.51	4,087,187	0.63	0.78	7.4	0.00	0	0.89	Jeff C	8:00 AM
21	SAT											
22	SUN											
23	MON	53.4	8.13	4,087,187	0.64	0.76	7.4	0.01	0			
24	Tues	54.0	9.43	4,097,592	0.65	0.78	7.4	0.01	0	1.53	Jeff C	7:00 AM
25	Wed	53.0	9.20	4,097,592	0.52	0.64	7.4	0.01	0	1.50	Jeff C	1:00 PM
26	Thurs	NO	School	Holiday	Closed					1.32	Jeff C	8:00 AM
27	Fri											
28	SAT											
29	SUN											
30	MON	NO	School	Holiday	Closed							
31												

METER Reading on 10/30/20 4,029,385



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 November 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0110487
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	0110487-01	Drinking Water	11/05/2020 12:50	11/5/20 14:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/11/2020 10:15

Lab Sample ID#: 0110487-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 11/05/2020 12:50
Receipt Date: 11/05/2020 14:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.04	mg/L		0.200	PFS	11/05/20 12:50	11/05/20 12:50
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	11/05/20 15:21	11/06/20 15:55
E. Coli	Absent	per 100 mL		1	KEL	11/05/20 15:21	11/06/20 15:55

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN
435 Broad St
Montoursville
(570) 321-9L
FAX: (570) 321-1957



FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	0110487 <i>en</i>	11-5-20	12:40	DW	3 ③	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>1.04</u>

*11/5/20 3:40
1444 TIL
KCU*


704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Monthly

Sampled By: (Signature) 	Date/ Time 11-5-20 12:40	Received By: (Signature) <i>en</i>	Date/ Time 11/5/20 15:10
Relinquished By: (Signature)	Date/ Time 11-5-20 14:35	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061
Contact Person:	JEFFREY CAMPBELL
Phone Number:	
Cell Phone:	724-406-4426
Email Address:	jcampbell@moniteau.k12.pa.us
Billing Address:	
PWSID:	5100324

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.04	110520	704		110520	D	1250	32382	0110487-01	BROWNKA_181
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	704		110520	D	1250	32382	0110487-01	BROWNKA_182



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111079
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0111079-01	Drinking Water	11/12/2020 11:55	11/12/20 19:07	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/13/2020 09:53

Lab Sample ID#: 0111079-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 11/12/2020 11:55
Receipt Date: 11/12/2020 19:07

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.700	mg/L		0.200	PFS	11/12/20 11:55	11/12/20 11:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435
Mo
(57
FA:

NORTHWEST DIVISION
16
-4209



FOR INTERNAL LABORATORY USE

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Date				
Distribution: <u>802</u>	<u>0111079</u>		<u>11-12-20</u>	<u>1155</u>	DW	Field	Free Chlorine <u>70</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DEUNQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) [Signature] Date/ Time 11-12-20 1155

Relinquished By: (Signature) [Signature] Date/ Time 11-12-20 1410

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) [Signature] Date/ Time 11/12/20 14:07

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: _____

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: _____

PWSID: **5100324**

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.04	110520	704		110520	D	1250	32382	0110487-01	BROWNKA_181
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	704		110520	D	1250	32382	0110487-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.7	111220	802		111220	D	1155	32382	0111079-01	BROWNKA_376



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111661
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0111661-01	Drinking Water	11/19/2020 11:25	11/20/20 9:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/20/2020 11:22

Lab Sample ID#: 0111661-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 11/19/2020 11:25
Receipt Date: 11/20/2020 09:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.630	mg/L		0.200	PFS	11/19/20 11:25	11/19/20 11:25

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.04	110520	704		110520	D	1250	32382	0110487-01	BROWNKA_181
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	704		110520	D	1250	32382	0110487-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.7	111220	802		111220	D	1155	32382	0111079-01	BROWNKA_376
5100324	1013	FREE CHLORINE	301	0.63	111920	803		111920	D	1125	32382	0111661-01	BROWNKA_811



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111833
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0111833-01	Drinking Water	11/23/2020 09:55	11/23/20 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/24/2020 10:39

Lab Sample ID#: 0111833-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 11/23/2020 09:55
Receipt Date: 11/23/2020 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.450	mg/L		0.200	PFS	11/23/20 09:55	11/23/20 09:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVI:
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-1900



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>0111833</u>	<u>11-23-20</u>	<u>09:55</u>	DW	Field	Field	Free Chlorine <u>.45</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)	Date/ Time <u>11-23-20 09:55</u>	Received By: (Signature)	Date/ Time <u>11-23-20 14:45</u>
Relinquished By: (Signature)	Date/ Time <u>11-23-20 14:28</u>	Received By: (Signature) _____	Date/ Time _____
Relinquished By: (Signature) _____	Date/ Time _____	Received By: (Signature) _____	Date/ Time _____
Relinquished By: (Signature) _____	Date/ Time _____	Received By: (Signature) _____	Date/ Time _____

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: _____

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: _____

PWSID: **5100324**

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.04	110520	704		110520	D	1250	32382	0110487-01	BROWNKA_181
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	704		110520	D	1250	32382	0110487-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.7	111220	802		111220	D	1155	32382	0111079-01	BROWNKA_376
5100324	1013	FREE CHLORINE	301	0.63	111920	803		111920	D	1125	32382	0111661-01	BROWNKA_811
5100324	1013	FREE CHLORINE	301	0.45	112320	804		112320	D	0955	32382	0111833-01	BROWNKA_950



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 November 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0111833
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0111833-01	Drinking Water	11/23/2020 09:55	11/23/20 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/24/2020 10:39

Lab Sample ID#: 0111833-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 11/23/2020 09:55
Receipt Date: 11/23/2020 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.450	mg/L		0.200	PFS	11/23/20 09:55	11/23/20 09:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-1900



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>0111833</u>	<u>11-23-20</u>	<u>09:55</u>	DW	Field	Field	Free Chlorine <u>.45</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEYS FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)	Date/ Time <u>11-23-20 09:55</u>	Received By: (Signature)	Date/ Time <u>11-23-20 14:45</u>
Relinquished By: (Signature)	Date/ Time <u>11-23-20 14:28</u>	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Correct Preservations Y/N/NA Y Correct Containers Y/N/NA Y Receipt Temperature —

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number:

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address:

PWSID: **5100324**

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.04	110520	704		110520	D	1250	32382	0110487-01	BROWNKA_181
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110620	704		110520	D	1250	32382	0110487-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.7	111220	802		111220	D	1155	32382	0111079-01	BROWNKA_376
5100324	1013	FREE CHLORINE	301	0.63	111920	803		111920	D	1125	32382	0111661-01	BROWNKA_811
5100324	1013	FREE CHLORINE	301	0.45	112320	804		112320	D	0955	32382	0111833-01	BROWNKA_950

Moniteau School District
Monthly Operations Report
November 2020
Moniteau High School
Waste Water Treatment facility

Moniteau High School Sewage Treatment Plant

Daily Operations Worksheet

Permit # PA0091341

TEST DAY *

TEST DAY *

THANKS GIVING *

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	UV	Month	Meter Reading	Time	Operator
11/2	Mon	8.02	11.11	7.11	8.90	7.7	Nov. 2020	3,895,916	7:30 AM	Jeff C
11/3	Tues	7.50	10.55	7.18	8.93	7.0			2:00 PM	Jeff C
11/4	Wed	7.79	11.01	7.23	8.82	6.9			7:00 AM	Jeff C
11/5	Thurs	7.93	11.21	7.36	8.76	6.8			8:00 AM	Jeff C
11/6	Fri	7.90	11.01	7.45	9.59	7.0			9:50 AM	Jeff C
11/9	Mon	7.79	11.45	7.22	9.21	8.2			10:45 AM	Jeff R
11/10	Tues	7.73	11.15	7.40	8.31	4.7			11:45 AM	Jeff R
11/11	wed	7.70	10.87	7.37	8.38	7.1			10:00 AM	Jeff C
11/12	Thurs	7.84	10.92	7.51	10.24	5.4			8:00 AM	Jeff C
11/13	Fri	7.87	10.95	7.60	10.37	6.1			8:00 AM	Jeff C
11/16	Mon	7.63	10.77	7.65	10.38	6.1			8:00 AM	Jeff C
11/17	Tues	7.80	10.96	7.22	8.79	5.7			10:00 AM	Jeff C
11/18	wed	7.87	10.97	7.24	8.66	6.1			9:30 AM	Jeff C
11/19	Thurs	7.60	10.79	7.10	9.59	5.7			9:00 AM	Jeff C
11/20	Fri	8.08	10.76	7.18	8.81	5.0			8:30 AM	Jeff C
11/23	Mon	8.17	11.12	7.26	9.74	4.7			8:00 AM	Jeff C
11/24	Tues	8.05	11.11	7.27	10.03	4.7			1:00 PM	Jeff C
11/25	wed	7.95	11.09	7.32	10.99	4.5		4,097,592	9:00 AM	Jeff C
11/26	Thurs							Holiday		Jeff C
11/27	Fri							No School		Jeff C
11/30	Mon.							No School		Jeff C
						109.4		201,676		
						÷ 18		÷ 31 =		
						6.07		6,505		

Moniteau School District
Moniteau High School
WASTEWATER TREATMENT PLANT
Monthly Work Sheet for Nov. 2020

Flow - $201,676 \div 31 = 6505$ Avg. Daily

U.V. - 6.07 Avg. Daily

PH High - 8.17 11/23 Basin #1

Low - 7.10 11/19 Basin #2

D.O. High - 11.45 11/9 Basin #1

Low - 8.31 11/10 Basin #2

Total Nitrogen - $2.79 + 0.347 = 3.137 \div 2 = 1.157$

T.S.S. - $< 5 + < 5 = < 5$

Nitrate / Nitrite - $0.354 + 0.347 = 0.701 \div 2 = 0.350$

Phosphorus - $< 0.10 + < 0.10 = < 0.10$

CBOD - $< 3.00 + < 3.00 = < 3.00$

Fecal - $< 1 + < 1 = < 1.0$



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 11/01/2020
 DMR Effective To: 11/30/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
2020	11	01	FROM	2020	11	30	TO

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	***		8.31	***	***	mg/L	1/week	Grab
	PERMIT REQUIREMENT	***	***		4.0 Min	***	***		1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***	***		7.10	***	8.17	S.U.	1/week	Grab
	PERMIT REQUIREMENT	***	***		6.0 Min	***	9.0 Max		1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***		***	<5.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	30 Avg Mo	***		2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***		***	1.16	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***		***	<.10	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***		***	6.07	***	µw/cm²	1/week	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.006505	***		***	***	***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	MGD	***	***	***		1/week	Measured



COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		***	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	2000 Geo Mean	10000 IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	<3.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	25 Avg Mo	***		2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Tuesday, December 8, 2020, 08:46 AM EST

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 11/01/2020-11/30/2020

Report Due Date: 12/28/2020

Submitted By: Jeffrey Campbell

Submission Id: 238342

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 November 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0110434
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0110434-01	Waste Water	11/05/2020 11:00	11/5/20 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/17/2020 09:15

Lab Sample ID#: 0110434-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 11/05/2020 11:00
Receipt Date: 11/05/2020 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	2.79	mg/L		0.104	DAA	11/11/20 14:48	11/11/20 18:19
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	11/10/20 13:38	11/10/20 14:15
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.354	mg/L		0.104	DAA	11/11/20 14:48	11/11/20 18:19
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	<0.10	mg/L		0.10	JPD	11/16/20 12:27	11/16/20 14:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	C, G, SS	3.00	AW	11/06/20 12:32	11/11/20 10:00
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	11/05/20 15:15	11/06/20 11:02

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Page 3 of 6

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	0110434			11/5/20	11:00 AM	WW	1 ✓	Poly 1000mL Preservative None	CBOD, TSS
						WW	1 ✓	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1 ✓	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:
Wastewater

Sampled By: (Signature) *[Signature]* Date/ Time 11/5/20 11:00 AM
 Relinquished By: (Signature) *[Signature]* Date/ Time 11/5/20 12:40
 Relinquished By: (Signature) *[Signature]* Date/ Time 11/5/20 14:35
 Relinquished By: (Signature) _____ Date/ Time _____
 Received By: (Signature) *[Signature]* Date/ Time 11-5-20 1240
 Received By: (Signature) *[Signature]* Date/ Time 11/5/20 14:45
 Received By: (Signature) _____ Date/ Time _____

Company/Name: **MONITEAU SCHOOL DISTRICT**
Contact Person: **JEFFREY CAMPBELL**
Address: **1810 WEST SUNBURY ROAD**
WEST SUNBURY, PA 16061
Phone / Cell: **724-406-4426**
Email: **jcampbell@moniteau.k12.pa.us**

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature _____



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information

0110434

Client: <u>Moniteau</u>		Work Order: _____	
Received by: <u>JTD</u>	Date/Time Received: <u>11/5/2014 15</u>	Date Sampled: <u>11/5/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>5.2</u>		Samples Received on Ice: <u>YES</u> NO	
IR Gun # Used: 1 2 <u>3</u> 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)		Containers removed by Satellite Lab for analysis of:	TCMPN Fecal Coliform TC/EC ECMPN
Sample State of Collection: <u>PA</u> NY OH WV Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>	

PART B: Receipt Details

Completed (if different from above): _____ / ____ / ____
Signature
Date
Time

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	<u>Yes</u>	No	N/A	Comments:	YES <u>NO</u>
2 COC form is properly signed in relinquished/received sections?	<u>Yes</u>	No	N/A	Comments:	YES <u>NO</u>
3 Sample containers intact and sealed?	<u>Yes</u>	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES <u>NO</u>
4 Number of containers received match number indicated on COC?	<u>Yes</u>	No	N/A	Sample ID's affected:	YES <u>NO</u>
5 Sample ID's on COC match ID's on bottles?	<u>Yes</u>	No	N/A	Sample ID's and containers affected:	YES <u>NO</u>
6 Date and time on COC match date and time on bottles?	<u>Yes</u>	No	N/A	Sample ID's affected:	YES <u>NO</u>
7 Samples received within holding time?	<u>Yes</u>	No	N/A	ID's and tests affected:	YES <u>NO</u>
8 Samples received at appropriate pH for analysis requested?	<u>Yes</u>	No	N/A	Sample ID's, containers affected and observed pH:	YES <u>NO</u>
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>Yes</u>	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES <u>NO</u>
11 Adequate sample volume received?	<u>Yes</u>	No	N/A	Analyses Affected:	YES <u>NO</u>
10 VOA vials free of headspace (defined as < 6mm bubble)?	<u>Yes</u>	No	<u>N/A</u>	Sample ID's and containers affected:	YES <u>NO</u>
Other Comments:					Deficiency Log Created: Yes <u>NO</u>



Results Report

Order ID: 0112260

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 0112260-01
Collector: Client

Site: 0110434-01
Collect Date: 11/05/2020 11:00 am

Sample ID: 0110434
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Inorganics									
Total Kjeldahl Nitrogen (TKN)	2.44	mg/L	EPA 351.2	0.50	1	11/10/20	CJ	11/12/20 13:36	ZJH

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 11/13/2020 12:24 pm 0112260
STL_Results Revision #1.9 Effective: 04/16/2020





0112260
Lisa F. Care

CONTRACT ORDER

Service Laboratories, Inc.

0110434

envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0110434-01			
Matrix: Water	Sampled: 11/05/2020 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	11/17/2020 23:00	12/03/2020 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250mlp H_2SO_4
Ph₂ LMT
11/16/20

Suburban Testing Labs

Lab Date/Time: 11/16/20 1037 Lab Temp: 2.9°C
 Number of containers/coblers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: Delivery
 Received in Lab by: LMT (1) 2.9°C

Released By: [Signature] Date: 11/15/20 Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

03 December 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0111601
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0111601-01	Waste Water	11/19/2020 11:00	11/19/20 15:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 12/03/2020 10:43

Lab Sample ID#: 0111601-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 11/19/2020 11:00
Receipt Date: 11/19/2020 15:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	0.347	mg/L		0.104	DAA	11/25/20 16:11	11/27/20 16:20
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	11/24/20 08:41	11/24/20 12:15
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.347	mg/L		0.104	DAA	11/25/20 16:11	11/27/20 16:20
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	<0.10	mg/L		0.10	JPD	11/23/20 14:12	11/23/20 17:30
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	C	3.00	AW	11/20/20 12:25	11/25/20 09:13
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	11/19/20 15:44	11/20/20 13:37

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Page 3 of 6

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	01			11/19/20	11:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
						WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:
Wastewater

Company/Name:
MONITEAU SCHOOL DISTRICT

Contact Person:
JEFFREY CAMPBELL

Address:
1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Phone / Cell:
724-406-4426

Email:
jcampbell@moniteau.k12.pa.us

Moniteau, ORG

[Signature] 11/19/20 11:00 AM
Sampled By: (Signature) Date/ Time

[Signature] 11/19/20 11:20
Relinquished By: (Signature) Date/ Time

[Signature] 11/19/20 1:35
Relinquished By: (Signature) Date/ Time

[Signature] 11-19-20 11:20
Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information

0111601

Client: <u>Monitew</u>	Work Order: _____
Received by: <u>DAA</u>	Date/Time Received: <u>11/19/20 1505</u> Date Sampled: <u>11/19/20</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temp: <u>5.1</u>	Samples Received on Ice: <u>YES</u> NO
IR Gun # Used: 1 2 3 <u>4</u>	
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of: TCMPN Fecal Coliform TC/EC ECMPN
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>

PART B: Receipt Details

Completed (if different from above): _____
Signature: _____ Date: 11/19/20 Time: 1550

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required	
	Yes	No	N/A		YES	NO
1 Chain of custody documents included with samples?	<u>Yes</u>	No	N/A	Comments:	YES	<u>NO</u>
2 COC form is properly signed in relinquished/received sections?	<u>Yes</u>	No	N/A	Comments:	YES	<u>NO</u>
3 Sample containers intact and sealed?	<u>Yes</u>	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES	<u>NO</u>
4 Number of containers received match number indicated on COC?	<u>Yes</u>	No	N/A	Sample ID's affected:	YES	<u>NO</u>
5 Sample ID's on COC match ID's on bottles?	<u>Yes</u>	No	N/A	Sample ID's and containers affected:	YES	<u>NO</u>
6 Date and time on COC match date and time on bottles?	<u>Yes</u>	No	N/A	Sample ID's affected:	YES	<u>NO</u>
7 Samples received within holding time?	<u>Yes</u>	No	N/A	ID's and tests affected:	YES	<u>NO</u>
8 Samples received at appropriate pH for analysis requested?	<u>Yes</u>	No	N/A	Sample ID's, containers affected and observed pH:	YES	<u>NO</u>
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>Yes</u>	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES	<u>NO</u>
11 Adequate sample volume received?	<u>Yes</u>	No	N/A	Analyses Affected:	YES	<u>NO</u>
10 VOA vials free of headspace (defined as < 6mm bubble)?	<u>Yes</u>	No	<u>N/A</u>	Sample ID's and containers affected:	YES	<u>NO</u>
Other Comments:					Deficiency Log Created: Yes <u>No</u>	



Results Report

Order ID: 0114698

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0114698-01	Site: 0111601-01	Sample ID: 0111601
Collector: Client	Collect Date: 11/19/2020 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Inorganics									
Total Kjeldahl Nitrogen (TKN)	< 0.30	mg/L	EPA 351.2	0.30	1	12/02/20	ZJH	12/02/20 14:49	ZJH

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 12/02/2020 4:39 pm 0114698
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT 0
Environmental Service Lab
0111601



0114698
 Lisa F. Care

Please report all results to reports@envlabs.co

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
 1803 Philadelphia Street
 Indiana, PA 15701
 Phone: 724-463-8378
 Fax: 724-465-4209
 Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
 1037F MacArthur Road
 Reading, PA 19605
 Phone : (610) 375-8378
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0111601-01			
Matrix: Water	Sampled: 11/19/2020 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	12/02/2020 23:00	12/17/2020 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D) PH52 AnB			

Suburban Testing Labs

Lab Date/Time: 11/24/20 11:30 Lab Temp: 1.5
 Number of containers/coolers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: _____
 Received in Lab by: Delivery
[Signature]

Released By: _____ Date: 11/19/20 Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____

