

Moniteau School District  
Maintenance Department  
Dassa McKinney School  
Water Treatment Facility  
Monthly Report for September 2022

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Sept.	2022									
1	Thurs	8.7	0.02	0.80	0.88	1.88	13525700	JEFFR	3:30P	6900
2	Fri	8.7	0.00	0.92	0.99	1.85	13530000	JEFFR	4:30P	4300
3	Sat									
4	Sun									
5	Mon									
6	Tues	8.7	0.01	0.85	0.92	1.91	13534700	JEFFR	4:30P	4700
7	Wed	8.7	0.04	0.70	0.78	2.16	13539100	JEFFR	3:00P	4400
8	Thurs	8.7	0.00	0.69	0.75	1.39	13543800	JEFFR	3:30P	4700
9	Fri	8.7	0.01	0.27	0.35	1.42	13547200	JEFFC	1:00 PM	3400
10	Sat									
11	Sun									
12	Mon	8.7	0.02	0.76	0.86	1.58	13552400	JEFFR	2:30P	5200
13	Tues		Vaca	tion						
14	Wed	8.7	0.00	0.81	0.90	1.76	13561700	JEFFR	3:00P	9300
15	Thurs	8.7	0.00	0.66	0.74	1.32	13566800	JEFFR	3:00P	5100
16	Fri	8.7	0.01	0.62	0.69	1.44	13571600	JEFFR	4:30P	9800
17	Sat									
18	Sun									
19	Mon	8.7	0.06	0.80	0.88	1.55	13576000	JEFFR	4:00P	4400
20	Tues	8.7	0.04	0.75	0.86	1.62	13580900	JEFFR	4:00P	4900
21	Wed	8.7	0.02	0.61	0.68	1.81	13584900	JEFFR	4:30P	4006
22	Thurs	8.7	0.04	0.58	0.67	1.87	13588800	JEFFR	3:30P	3900
23	Fri	8.7	0.04	0.70	0.78	2.16	13592500	JEFFR	3:30P	3700
24	Sat									
25	Sun									
26	Mon	8.7	0.02	0.68	0.77	1.87	13596800	JEFFR	4:30P	4300
27	Tues	8.7	0.00	0.70	0.79	1.91	13600700	JEFFR	4:30P	3900
28	Wed	8.7	0.00	0.74	0.84	1.66	13604900	JEFFR	4:30P	4200
29	Thurs	8.7	0.02	0.64	0.72	1.72	13609000	JEFFR	4:30P	4100
30	Fri	8.7	0.02	0.62	0.69	1.75	13612900	JEFFR	4:30P	3900
31										

Meter Reading - 8/31/22 - 13518800





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 September 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22I0171**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	22I0171-01	Drinking Water	09/01/2022 12:20	9/1/22 15:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/12/2022 08:40

**Lab Sample ID#:** 22I0171-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 09/01/2022 12:20  
**Receipt Date:** 09/01/2022 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.900	mg/L		0.200	PS	09/01/22 12:20	09/01/22 12:20
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	AMB	09/01/22 15:55	09/02/22 16:52
E. Coli	Absent	per 100 mL		1	AMB	09/01/22 15:55	09/02/22 16:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Monitorsville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



2210171

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	2210171 C1		1220	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine .90 mg/L

Rotation:  
801: Jan, Mar, May, Jul, Sep,  
Nov  
802: Feb, Apr, Jun, Aug, Oct,  
Dec

Notes/Special Instructions:  
**Drinking Water Dassa McKinney - Monthly**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	9-17-07 1:30		9/18/07 5:00
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	9-1-07 1:30		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Correct Preservations Y/N/NA	Y/N/NA	Correct Containers Y/N/NA	Receipt Temperature 3.4HS

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcambell@moniteau.org**

Cell Phone: **5100316**

Email Address: **5100316**

Billing Address: **5100316**

PWSID: **5100316**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.9	090122	801		090122	D	1220	32382	2210171-01	BROWNKA_34
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	801		090122	D	1220	32382	2210171-01	BROWNKA_35





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

13 September 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22I0932**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	22I0932-01	Drinking Water	09/08/2022 10:43	9/9/22 10:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/13/2022 11:26

**Lab Sample ID#:** 22I0932-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 09/08/2022 10:43  
**Receipt Date:** 09/09/2022 10:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.620	mg/L		0.200	PS	09/08/22 10:43	09/08/22 10:43



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN DIVISION**  
 1276 Benileyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-8376

**NORTHERN DIVISION**  
 435 Broad Street  
 Montoursville, PA 17754  
 (570) 321-9003  
 FAX: (570) 321-1957

**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 16  
 (724) 463-TEST  
 FAX: (724) 465-4209



## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 802	2210932	9/27	1043	DW	Field	Field	Free Chlorine 0.62 mg/L
	01						

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) *[Signature]* Date/Time **9-27 1043**

Relinquished By: (Signature) *[Signature]* Date/Time **9-27 1043**

Received By: (Signature) *[Signature]* Date/Time **9-27 1043**

Relinquished By: (Signature) *[Signature]* Date/Time **9-27 1043**

Received By: (Signature) *[Signature]* Date/Time **9-27 1043**

Relinquished By: (Signature) *[Signature]* Date/Time **9-27 1043**

Correct Preservations  / N / NA Correct Containers  / N / NA Receipt Temperature **4.0**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.9	090122	801		090122	D	1220	32382	2210171-01	BROWNKA_34
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	801		090122	D	1220	32382	2210171-01	BROWNKA_35
5100316	1013	FREE CHLORINE	301	0.62	090822	802		090822	D	1043	32382	2210932-01	BROWNKA_237



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

16 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22I1583**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	22I1583-01	Drinking Water	09/15/2022 11:00	9/15/22 13:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/16/2022 12:33

**Lab Sample ID#:** 22II1583-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 09/15/2022 11:00  
**Receipt Date:** 09/15/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.760	mg/L		0.200	PS	09/15/22 11:00	09/15/22 11:00

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Monitorsville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957



2211583

FOR INTERNAL LABORATORY USE ONLY

**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 803	2211583	9/15/07	1100	DW	Field	Field	Free Chlorine 0.16 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 9/15/07 1100

Relinquished By: (Signature) *[Signature]* Date/ Time 9/15/07 1100

Received By: (Signature) *[Signature]* Date/ Time 9/15/07 1130

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations *[Signature]* Correct Containers *[Signature]* Receipt Temperature \_\_\_\_\_

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
**JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcambell@moniteau.org**

Email Address: **jcambell@moniteau.org**

Billing Address: \_\_\_\_\_

PWSID: **5100316**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.9	090122	801		090122	D	1220	32382	2210171-01	BROWNKA_34
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	801		090122	D	1220	32382	2210171-01	BROWNKA_35
5100316	1013	FREE CHLORINE	301	0.62	090822	802		090822	D	1043	32382	2210932-01	BROWNKA_237
5100316	1013	FREE CHLORINE	301	0.76	091522	803		091522	D	1100	32382	2211583-01	BROWNKA_813





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

30 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2212781  
 Project: Drinking Water Dassa McKinney - Weekly  
 Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	2212781-01	Drinking Water	09/29/2022 10:10	9/29/22 12:15	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Kirsten Conoran  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/30/2022 13:41

Lab Sample ID#: 2212781-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 802 Room 617 Sink

Sample Date: 09/29/2022 10:10  
 Receipt Date: 09/29/2022 12:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.570	mg/L			Client	09/29/22 10:10	09/29/22 10:10

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 455-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1275 Bentleyville Road  
Van Vleet, PA 15355  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
455 Broad Street  
Montoursville, PA 17754  
(570) 321-9503  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 453-TEST  
FAX: (724) 465-4209



2212781

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>802</u>	2212781	Grab	DW	Field	Field	Free Chlorine 0.57 mg/L
	01	Date				
		Time				

### ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/Time 9-29-22 1015  
 Relinquished By: (Signature) [Signature] Date/Time 9-29-22 1015  
 Relinquished By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Received By: (Signature) MCC/00380 Date/Time 9-29-22 1015  
 Received By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Correct Preservations (X) N / NA Correct Containers (X) N / NA Receipt Temperature 3.9

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company Name: MONITEAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: jcampbell@moniteau.org  
 Billing Address: \_\_\_\_\_  
 PWSID: 5100316





E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EEDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.9	090122	801		090122	D	1220	32382	2210171-01	BROWNSKA_34
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	801		090122	D	1220	32382	2210171-01	BROWNSKA_35
5100316	1013	FREE CHLORINE	301	0.62	090822	802		090822	D	1043	32382	2210932-01	BROWNSKA_237
5100316	1013	FREE CHLORINE	301	0.57	092922	802		092922	D	1010	32382	2212781-01	BROWNSKA_2305
5100316	1013	FREE CHLORINE	301	0.76	091522	803		091522	D	1100	32382	2211583-01	BROWNSKA_813
5100316	1013	FREE CHLORINE	301	0.84	091922	804		091922	D	0843	32382	2211794-01	BROWNSKA_1133

Moniteau School District  
Maintenance Department  
Moniteau High School  
Water Treatment Facility  
Monthly Report for September 2022



MONITEAU HIGH SCHOOL WATER TREATMENT PLANT													
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
Sept 2022	1	Thurs	76.5	11.41	7,056, 228	0.64	0.66	7.1	0.02	0	1.71	Jeff C	9:00 AM
	2	Fri	72.0	9.04	7,056, 228	0.63	0.66	7.1	0.02	0	1.70	Jeff C	9:00 AM
	3	SAT											
	4	SUN											
	5	Mon	66.4	10.85	7,068, 129	0.63	0.67	7.1	0.00	0	0.99	Jeff C	9:30 AM
	6	Tues	65.0	9.45	7,068, 129	0.63	0.66	7.1	0.00	0	0.98	Jeff C	9:00 AM
	7	Wed	64.0	8.10	7,068, 129	0.63	0.66	7.1	0.00	0	0.98	Jeff C	9:00 AM
	8	Thurs	54.0	9.00	7,070, 615	0.59	0.63	7.1	0.00	0	1.10	Jeff C	9:00 AM
	9	Fri	66.0	8.01	7,070, 615	0.60	0.63	7.1	0.00	0	1.09	Jeff C	9:00 AM
	10	SAT											
	11	SUN											
	12	Mon	70.0	8.91	7,081, 127	0.60	0.64	7.2	0.00	0	1.10	Jeff C	10:00 AM
	13	Tues	70.0	10.73	7,093, 269	0.59	0.63	7.2	0.03	0	1.11	Jeff C	3:00 PM
	14	Wed	70.0	9.25	7,093, 269	0.60	0.63	7.2	0.02	0	1.10	Jeff C	2:00 PM
	15	Thurs	65.6	10.81	7,102, 095	0.59	0.63	7.2	0.02	0	1.10	Jeff C	3:00 PM
	16	Fri	70.1	9.01	7,102, 095	0.59	0.62	7.2	0.02	0	1.11	Jeff C	2:00 PM
	17	SAT											
	18	SUN											
	19	Mon	76.0	9.20	7,104, 765	0.58	0.61	7.2	0.00	0	0.98	Jeff C	9:00 AM
	20	Tues	75.6	7.11	7,104, 765	0.60	0.62	7.2	0.00	0	0.99	Jeff C	5:30 PM
	21	Wed	75.7	8.95	7,116, 863	0.62	0.65	7.2	0.00	0	1.12	Jeff C	4:00 PM
	22	Thurs	68.0	10.96	7,124, 333	0.58	0.62	7.2	0.00	0	1.12	Jeff C	3:30 PM
	23	Fri	65.9	10.58	7,129, 828	0.59	0.62	7.2	0.00	0	1.10	Jeff C	1:30 PM
	24	SAT											
	25	SUN											
	26	Mon	65.5	10.56	7,137, 940	0.54	0.63	7.1	0.01	0	1.30	Jeff C	11:00 AM
	27	Tues	63.0	10.39	7,143, 396	0.57	0.68	7.2	0.02	0	1.28	Jeff R	12:00 PM
	28	Wed	62.1	8.40	7,143, 396	0.60	0.63	7.3	0.04	0	0.78	Jeff R	11:45 AM
	29	Thurs	61.7	10.92	7,156, 076	0.54	0.61	7.2	0.04	0	1.07	Jeff R	11:30 AM
	30	Fri	61.0	8.20	7,156, 639	0.56	0.58	7.2	0.04	0	1.48	Jeff R	11:30 AM
	31												

WATER TESTING

SEWAGE TESTING





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 September 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22I0178**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	22I0178-01	Drinking Water	09/01/2022 12:55	9/1/22 15:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/12/2022 08:40

**Lab Sample ID#:** 22I0178-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 09/01/2022 12:55  
**Receipt Date:** 09/01/2022 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.470	mg/L		0.200	PS	09/01/22 12:55	09/01/22 12:55
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	AMB	09/01/22 15:55	09/02/22 16:52
E. Coli	Absent	per 100 mL		1	AMB	09/01/22 15:55	09/02/22 16:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



2210178

**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

<b>HEADQUARTER</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<b>SOUTHERN DIVISION</b> 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	<b>NORTHERN DIVISION</b> 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16150 (724) 463-TEST FAX: (724) 465-4209
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

<b>Sample Identification</b> CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	ESL# 2210178 01	<table border="1"> <tr> <th colspan="2">Sample Type</th> </tr> <tr> <td>Grab</td> <td>Time</td> </tr> <tr> <td>9-1-27</td> <td>12:55</td> </tr> </table>	Sample Type		Grab	Time	9-1-27	12:55	Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC/EC Free Chlorine e 47
Sample Type												
Grab	Time											
9-1-27	12:55											

704: Jan, Mar, May, Jul, Sept, Nov  
 802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Monthly

Company/Name: Address: Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:	MONITEAU SCHOOL DISTRICT 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcampbell@moniteau.org 5100324
Sampled By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time Relinquished By: (Signature) Date/ Time	Received By: (Signature) Date/ Time Received By: (Signature) Date/ Time Received By: (Signature) Date/ Time
Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature 3.2-#3	Drinking Water Moniteau Jr/Sr - Monthly



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.47	090122	704		090122	D	1255	32382	2210178-01	BROWNKA_36
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	704		090122	D	1255	32382	2210178-01	BROWNKA_37



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

13 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22I0928**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802	22I0928-01	Drinking Water	09/08/2022 11:10	9/9/22 10:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/13/2022 14:27

**Lab Sample ID#:** 22I0928-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802

**Sample Date:** 09/08/2022 11:10  
**Receipt Date:** 09/09/2022 10:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.470	mg/L		0.200	CLSW	09/08/22 11:10	09/08/22 11:10

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



2210928

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY 3E \_\_\_ 1 \_\_\_ OF \_\_\_ 1 \_\_\_

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>807</u>	<u>2210928</u>	<u>9/8/27</u>	<u>1100</u>	DW	Field	Field	Free Chlorine <u>0.47</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEYS FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: *Drinking Water Moniteau Jr/Sr - Weekly*

Sampled By: (Signature) <u>[Signature]</u>	Date/ Time <u>9-9-27 1100</u>
Relinquished By: (Signature) <u>[Signature]</u>	Date/ Time <u>9-9-27 140</u>
Received By: (Signature) <u>[Signature]</u>	Date/ Time <u>9-9-22 1000</u>
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Correct Preservations <u>(X)</u> / N / NA	Correct Containers <u>(Y)</u> / N / NA
Receipt Temperature <u>4.7</u>	

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**

Contact Person: **724-406-4426  
jcambell@moniteau.org**

Phone Number: **5100324**

Cell Phone:

Email Address:

Billing Address:

PWSID:



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.47	090122	704		090122	D	1255	32382	2210178-01	BROWNKA_36
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	704		090122	D	1255	32382	2210178-01	BROWNKA_37
5100324	1013	FREE CHLORINE	301	0.47	090822	802		090822	D	1110	32382	2210928-01	BROWNKA_235



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

16 September 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22I1597**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	22I1597-01	Drinking Water	09/15/2022 11:17	9/15/22 13:20	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/16/2022 12:34

**Lab Sample ID#:** 22I1597-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 09/15/2022 11:17  
**Receipt Date:** 09/15/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.540	mg/L		0.200	PS	09/15/22 11:17	09/15/22 11:17

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



N DIVISION  
Street  
le, PA 17754  
003

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY  
FAX: (570) 321-1957

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>2211597</u>	<u>9/15/24</u>	<u>1117</u>	DW	Field	Field	Free Chlorine <u>0.54</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:  
**Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**  
Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**  
Contact Person: **JEFFREY CAMPBELL**  
Phone Number: **724-406-4426**  
Cell Phone: **jcampbell@moniteau.org**  
Email Address: **jcampbell@moniteau.org**  
Billing Address:  
PWSID: **5100324**

Received By: (Signature) [Signature] Date/ Time 9/15/24 1:30  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA \_\_\_\_\_ Correct Containers Y / N / NA \_\_\_\_\_ Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program


SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.47	090122	704		090122	D	1255	32382	2210178-01	BROWNKA_36
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	704		090122	D	1255	32382	2210178-01	BROWNKA_37
5100324	1013	FREE CHLORINE	301	0.47	090822	802		090822	D	1110	32382	2210928-01	BROWNKA_235
5100324	1013	FREE CHLORINE	301	0.54	091522	803		091522	D	1117	32382	2211597-01	BROWNKA_825





1801 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00782

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

30 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2212780  
 Project: Drinking Water Moniteau Jr/Sr - Weekly  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	2212780-01	Drinking Water	09/29/2022 10:28	9/29/22 12:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 463-4209  
 PADEP: 33-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 463-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/30/2022 13:42

Lab Sample ID#: 2212780-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 804 400 Hall RR Sink

Sample Date: 09/29/2022 10:28  
 Receipt Date: 09/29/2022 12:15

Analyte	Sample Result	Units	Data Qualifier	RI	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
Chlorine, Free	0.560	mg/L			Client	09/29/22 10:28	09/29/22 10:28

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15306  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Mumfoursville, PA 17754  
(570) 321-6003  
FAX (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE \_\_\_\_\_ OF \_\_\_\_\_



2212780

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2212780	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>SU</u>	<u>Q1</u>	Grab Date: <u>9-29-22</u> Time: <u>1028</u>	DW	Field	Field	Free Chlorine <u>0.56</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						

Notes/Special Instructions:  
*Drinking Water Moniteau Jr/Sr - Weekly*

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD  
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.org

Billing Address: 5100324

PWSID: 5100324

---

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (16% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Sampled By (Signature): [Signature] Date/ Time: 9-29-22 1028

Relinquished By (Signature): [Signature] Date/ Time: 9-29-22 1015

Relinquished By (Signature): \_\_\_\_\_ Date/ Time: \_\_\_\_\_

Relinquished By (Signature): \_\_\_\_\_ Date/ Time: \_\_\_\_\_

Relinquished By (Signature): \_\_\_\_\_ Date/ Time: \_\_\_\_\_

Correct Preservations Y / N / N A \_\_\_\_\_ Correct Containers Y / N / N A \_\_\_\_\_ Receipt Temperature \_\_\_\_\_





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.47	090122	704		090122	D	1255	32382	2210178-01	BROWNKA_36
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090222	704		090122	D	1255	32382	2210178-01	BROWNKA_37
5100324	1013	FREE CHLORINE	301	0.47	090822	802		090822	D	1110	32382	2210928-01	BROWNKA_235
5100324	1013	FREE CHLORINE	301	0.54	091522	803		091522	D	1117	32382	2211597-01	BROWNKA_825
5100324	1013	FREE CHLORINE	301	0.71	091922	804		091922	D	0900	32382	2211796-01	BROWNKA_1134
5100324	1013	FREE CHLORINE	301	0.56	092922	804		092922	D	1028	32382	2212760-01	BROWNKA_2306

Moniteau School District  
Maintenance Department  
Moniteau High School  
Wastewater Treatment Facility  
Monthly Report for September 2022







JEFFREY CAMPBELL <jcampbell@moniteau.org>

## Your eDMR Report Has Been Received For Permit No. PA0091341

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Tue, Oct 11, 2022 at 8:13 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL  
Permit Number: PA0091341  
Report Frequency: Monthly  
Report Type: DMR  
Reporting Period: 09/01/2022-09/30/2022  
Report Due Date: 10/28/2022

Submitted By: Jeffrey Campbell  
Submission Id: 352869  
Submission Status: Received  
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau High School  
 WASTE WATER PLANT Monthly Worksheet

Flow  $100,411 \div 30 = 3347$  Daily Avg.

U.V. Light  $145.9 \div 22 = 6.63$  Daily Avg.

D.O. Low 5.16

High 7.20

pH low 6.13

High 7.47

TOTAL Nitrogen	2.25	0.761	3.011	1.505
TKN	< 0.625	< 0.625		< 0.625
TSS	< 5	< 5		< 5
Nitrate / Nitrite	2.25	0.761	3.011	1.505
Phos	0.24	0.12	0.36	0.18
CBOD	< 2.00	< 2.00		< 2.00
Fecal	< 5	< 1		< 3



DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341  
 PERMIT NUMBER

001  
 OUTFALL NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	09	01	2022	09	30

FROM

PARAMETER	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION		
			VALUE	UNITS	VALUE	VALUE	VALUE	
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		5.16	***		
			***		4.0 Min	***		
pH (00400)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		6.13	***		
			***		6.0 Min	***		
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		***	<5.0		
			***		***	30 Avg Mo		
Total Nitrogen (00600)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		***	1.50		
			***		***	Monitor & Report Avg Mo		
Total Phosphorus (00665)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		***	.18		
			***		***	Monitor & Report Avg Mo		
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	***		***	6.63		
			***		***	Monitor & Report Avg Mo		
Flow (50050)	SAMPLE MEASUREMENT	PERMIT REQUIREMENT	.003347	MGD	***	***		
			Monitor & Report		***	***		






DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTR		
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		***	<3.0	<3.0
	PERMIT REQUIREMENT	***	***		***	200 Geo Mean	1000 IMAX
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	<2.00	***
	PERMIT REQUIREMENT	***	***		***	25 Avg Mo	***
Facility Comments							

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER
----------	---------------	-------------------------------



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

27 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2211477  
 Project: Wastewater  
 Project Description: Wastewater

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab Outfall 001	2211477-01	Waste Water	09/15/2022 10:30	9/15/22 14:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Shane Molyneux  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/27/2022 17:11

Lab Sample ID#: 2211477-01  
 Sample Type: Waste Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Effluent Grab Outfall 001

Sample Date: 09/15/2022 10:30  
 Receipt Date: 09/15/2022 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]		
Total Nitrogen	0.761	mg/L		0.729	DAA	09/23/22 06:40	09/23/22 16:54
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	09/23/22 06:40	09/23/22 16:54
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	TLL	09/22/22 17:10	09/22/22 17:10
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.761	mg/L		0.104	AW	09/20/22 12:34	09/20/22 12:34
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.12	mg/L		0.10	AW	09/23/22 12:35	09/23/22 12:35
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB	2.00	MJS	09/16/22 13:53	09/21/22 08:05
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	09/15/22 14:30	09/16/22 11:12




**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTERS  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957



NORTHERN DIVISION  
950 M  
Sharp  
(724)  
FAX: 2211477



2211477

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Sample Identification	ESLA#	Sample Type				Matrix	# of Containers	Container Type	Analysis Requested
		Composic	Date en/of	Time en/of	Grab				
		Date en/of	Date	Time					
Effluent Outfall 001	01	<del>9/15/22</del>	<del>9/15/22</del>	<del>10:30</del>	WW	1	Poly 1000mL	CBOD, TSS	
		<del>9/15/22</del>	<del>9/15/22</del>	<del>10:30</del>					
		<del>9/15/22</del>	<del>9/15/22</del>	<del>10:30</del>					
					WW	1	Poly 1000mL	Total Nitrogen, Total Phosphorus	
					WW	1	Sterile Plastic 125mL	Fecal Coliform	
							Na2S2O3		

**Project Notes:**  
Wastewater

Company Name: **MONTEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**  
Address: **1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061  
724-406-4426**  
Email: **jcampbell@monteau.org**

Received By: (Signature) *[Signature]* Date/Time **9-15-22 1115**  
Received By: (Signature) *[Signature]* Date/Time **9/15/22 1400 (60302)**  
Received By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
Received By: (Signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Correct/Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_



## SAMPLE RECEIPT AND REVIEW FORM



2211477

Client:

Monkton School District

Work Order

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>AK/00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>9/15/22 1400</u>	Date Sampled: <u>9/15/22</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>6.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

## PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria			Signature	Date	Time
	YES	NO			
Chain of custody documents included with samples?	<u>YES</u>	NO			
COC form is properly signed in relinquished/received sections?	<u>YES</u>	NO			
Sample containers intact and sealed?	<u>YES</u>	NO			
Number of containers received matches number indicated on COC?	<u>YES</u>	NO			
Sample IDs on COC match IDs on bottles?	<u>YES</u>	NO			
Date and time on COC match date and time on bottles?	<u>YES</u>	NO			
Samples received within holding time?	<u>YES</u>	NO			
Samples received at appropriate pH for analysis requested?	<u>YES</u>	NO			
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u>	NO			
Adequate sample volume received?	<u>YES</u>	NO			
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>YES</u>	<u>NO</u>			
Other Comments:				Deficiency Log Created:	
				YES <u>NO</u>	

Effective Date:

GP.25.A-1 Sample Receipt Log





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

15 September 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22I0114**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22I0114-01	Waste Water	09/01/2022 10:30	9/1/22 16:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/15/2022 09:58

**Lab Sample ID#:** 22I0114-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 09/01/2022 10:30  
**Receipt Date:** 09/01/2022 16:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: *** DEFAULT SPECIFIC METHOD</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	2.25	mg/L		0.729	DAA	09/14/22 06:40	09/14/22 14:11
<b>General Chemistry</b>	<b>Analytical Method: EPA 351.2</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	09/14/22 06:40	09/14/22 14:11
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	TLL	09/08/22 17:40	09/08/22 17:40
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-16 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	2.25	mg/L		0.104	AW	09/02/22 12:32	09/02/22 12:32
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.24	mg/L		0.10	AW	09/12/22 11:15	09/12/22 11:15
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	MJS	09/02/22 14:58	09/07/22 09:20
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<5	MPN/100 mL		5	AMB	09/01/22 16:19	09/02/22 11:20

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTERS**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHERN DIVISION**  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

**NORTHWEST DIVIS**  
950 Main Street  
Sharpsville, PA 1615  
(724) 463-TEST  
FAX: (724) 465-4201



2210114

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Containers	Matrix	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/off	Time on/off	Date	Time		
Effluent Outfall 001	2210114			9/1/22	10:30 AM	Poly 1000mL	CBOD, TSS
	01					None	
						Poly 1000mL	Total Nitrogen, Total Phosphorus
						H2SO4	
						Sterile Plastic 125mL	Fecal Coliform
						Na2S2O3	

**Project Notes:**  
Wastewater

**Company/Name:**  
MONITEAU SCHOOL DISTRICT

**Contact Person:**  
JEFFREY CAMPBELL

**Address:**  
1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061  
724-406-4426  
jcampbell@moniteau.org

**Received By: (Signature)** [Signature] **Date/ Time** 9-1-22 12:58

**Relinquished By: (Signature)** [Signature] **Date/ Time** 9-1-22 1:30 AM

**Received By: (Signature)** [Signature] **Date/ Time** 9-1-22 1:30

**Relinquished By: (Signature)** [Signature] **Date/ Time** 9-1-22 1:30

**Received By: (Signature)** [Signature] **Date/ Time** 9-1-22 1:30

**Relinquished By: (Signature)** [Signature] **Date/ Time** 9-1-22 1:30

**Correct Preservations** Y / N / NA      **Correct Containers** Y / N / NA      **Receipt Temperature**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.





# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monitau</u>	Work Order: _____
------------------------	-------------------



2210114

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>BB/00382</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES NO
Date/Time Received: <u>9/11/22 1630</u>	Date Sampled: <u>9/11/22</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>4.7</u> °C	IR Gun ID: <u>9</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA <input type="checkbox"/> NY <input type="checkbox"/> OH <input type="checkbox"/> WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="checkbox"/> NO

### PART C: Receipt Details Completed (if different from above): \_\_\_\_\_ / / \_\_\_\_\_

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/> YES	<input type="checkbox"/> NO	Comments:
COC form is properly signed in relinquished/received sections?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Comments:
Sample containers intact and sealed?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input type="checkbox"/> YES	<input type="checkbox"/> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input type="checkbox"/> YES	<input checked="" type="checkbox"/> NO	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <input checked="" type="checkbox"/> NO

Effective Date: \_\_\_\_\_

GP.25.A-1 Sample Receipt Log