

**Moniteau School District
Maintenance Department
Monthly Report**

**Dassa McKinney Elementary School
Water Treatment Facility**

June 2021

Dassa McKinney Elementary School Water Treatment Facility

Month	June	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Date	Day									
1	Tues.	8.7	0.04	0.53	0.59	3.53	12659100	JEFFR	3:30P	4500
2	Wed	8.7	0.03	0.55	0.61	3.41	12663800	JEFFR	3:00P	4700
3	Thurs.	8.7	0.02	0.75	0.80	2.16	12668000	JEFFR	3:30P	4200
4	Fri	8.7	0.02	0.72	0.80	2.24	12672300	JEFFR	3:00P	4300
5	Sat									
6	Sun									
7	Mon	8.7	0.04	0.70	0.77	2.37	12680100	JEFFR	2:30P	7800
8	Tues	8.7	0.02	0.65	0.70	2.26	12684700	JEFFR	3:00P	4600
9	Wed	8.7	0.03	0.77	0.84	1.61	12685300	JEFFR	3:00P	600
10	Thurs	8.7	0.02	0.75	0.85	1.59	12690300	JEFFC	4:00P	
11	Fri	8.7	0.02	0.75	0.83	1.71	12690300	JEFFC	6:00A	
12	Sat									
13	Sun									
14	Mon	7.9	0.00	0.58	0.62	1.90	129690600	JEFFC	3:00PM	
15	Tues	7.9	0.00	0.57	0.60	1.93	129690600	JEFFC	9:00AM	
16	Wed	7.9	0.00	0.50	0.56	1.90	12690700	JEFFC	5:00PM	
17	Thurs	7.9	0.00	0.45	0.58	1.89	12691100	JEFFC	10:00AM	
18	Fri	7.9	0.00	0.45	0.55	1.87	12691100	JEFFC	2:00PM	
19	Sat									
20	Sun									
21	Mon	7.9	0.00	0.32	0.45	1.80	1269130	JEFFC	5:00PM	
22	Tues	7.9	0.00	0.25	0.30	1.80	1269130	JEFFC	1:00PM	
23	Wed	7.9	0.00	1.11	1.15	1.67	1269130	JEFFC	2:00AM	
24	Thurs	7.9	0.00	1.05	1.10	1.63	1269270	JEFFC	3:00AM	140
25	Fri	7.9	0.01	1.00	1.05	1.65	1269270	JEFFC	2:00PM	
26	Sat									
27	Sun									
28	Mon	7.9	0.01	0.90	0.97	1.64	1269270	JEFFC	9:00AM	0
29	Tues	7.9	0.00	0.74	0.77	1.31	1269350	JEFFC	2:00AM	80
30	Wed	7.9	0.00	0.63	0.74	1.30	1269350	JEFFC	1:00PM	
31										

Meter Reading 5/28/21 12654600



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1060574
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1060574-01	Drinking Water	06/04/2021 10:50	6/4/21 16:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager



ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



WEST DIVISION
1060574
EST

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE: 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 1060574	Sample Type		Matrix	# of Bottles	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC/EC Free Chlorine .80 mg/L
		Grab	Time				
801 KITCHEN-SINK 802 ROOM 617 SINK	or	6-4-21	10:50	DW	1		

<p>Rotation: 801: Jan, Mar, May, Jul, Sep, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec</p>	<p>Notes/Special Instructions: Drinking Water Dassa McKinney - Monthly</p>
---	--

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) <i>[Signature]</i>	Date/ Time 6-4-21 10:50
Relinquished By: (Signature) <i>[Signature]</i>	Date/ Time 6-4-21 10:55
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time

Received By: (Signature) <i>[Signature]</i>	Date/ Time 6-4-21 10:55 (0330)
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time

Correct Preservations	Y / N / NA	Correct Containers	Y / N / NA	Receipt Temperature	28.0c #3
					FCC

Company Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Contact Person:	
Phone Number:	724-406-4426
Cell Phone:	
Email Address:	jcampbell@moniteau.org
Billing Address:	
PWSID:	5100316



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1061277
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1061277-01	Drinking Water	06/10/2021 12:25	6/11/21 10:26	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/11/2021 15:08

Lab Sample ID#: 1061277-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 06/10/2021 12:25
Receipt Date: 06/11/2021 10:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.910	mg/L		0.200	PS	06/10/21 12:25	06/10/21 12:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
	1061277	Grab				
Distribution: 801	01	Date: 6/10/21	Time: 1225	Field	Field	Free Chlorine <u>.91</u> mg/L

ROTATION						
Wk 1 - 801 Kitchen Sink						
Wk 2 - 802 Room 617 Sink						
Wk 3 - 803 Room 606 Sink						
Wk 4 - 804 Room 408 Sink						
Wk 5 - 802 Room 617 Sink						

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	6-10-21 1225		6/10/21 10:25 AM
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Correct Preservations Y / N (NA)	Correct Containers Y / N (NA)	Receipt Temperature	

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.91	061021	801		061021	D	1225	32382	1061277-01	BROWNKA_387
5100316	1013	FREE CHLORINE	301	0.8	060421	802		060421	D	1050	32382	1060574-01	BROWNKA_90
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1050	32382	1060574-01	BROWNKA_91



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1061916
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	1061916-01	Drinking Water	06/17/2021 13:25	6/17/21 16:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.91	061021	801		061021	D	1225	32382	1061277-01	BROWNKA_387
5100316	1013	FREE CHLORINE	301	0.8	060421	802		060421	D	1050	32382	1060574-01	BROWNKA_90
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1050	32382	1060574-01	BROWNKA_91
5100316	1013	FREE CHLORINE	301	0.41	061721	803		061721	D	1325	32382	1061916-01	BROWNKA_811



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1062504
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1062504-01	Drinking Water	06/24/2021 11:25	6/24/21 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/24/2021 19:34

Lab Sample ID#: 1062504-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 06/24/2021 11:25
Receipt Date: 06/24/2021 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-C1 G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.970	mg/L		0.200	PS	06/24/21 11:25	06/24/21 11:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

1062504

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 1062504	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 804	01	Date 6/24/11	DW	Field	Field	Free Chlorine, 97 mg/L
		Time 1125				

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)  Date/ Time 6/24/11 1125
Relinquished By: (Signature)  Date/ Time 6/24/11 1328

Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA
Correct Containers Y / N / NA
Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.org
Billing Address: 5100316
PWSID: 5100316



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.91	061021	801		061021	D	1225	32382	1061277-01	BROWNKA_387
5100316	1013	FREE CHLORINE	301	0.8	060421	802		060421	D	1050	32382	1060574-01	BROWNKA_90
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1050	32382	1060574-01	BROWNKA_91
5100316	1013	FREE CHLORINE	301	0.41	061721	803		061721	D	1325	32382	1061916-01	BROWNKA_811
5100316	1013	FREE CHLORINE	301	0.97	062421	804		062421	D	1125	32382	1062504-01	BROWNKA_1069

**Moniteau School District
Maintenance Department
Monthly Report
Moniteau High School
Water Treatment Facility
June 2021**

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	Tues	64.0	7.40	4,662, 680	1.06	1.13	7.3	0.02	0	0.87	Jeff C	10:00 AM
2	wed	65.0	8.52	4,669, 798	1.02	1.16	7.3	0.01	0	0.89	Jeff C	9:00 AM
3	Thurs	65.2	7.10	4,669, 798	1.03	1.12	7.3	0.01	0	0.90	Jeff C	7:00 AM
4	Fri	65.6	7.58	4,676, 936	0.97	1.08	7.1	0.00	0	1.44	Jeff C	10:00 AM
5	SAT											
6	SUN											
7	Mon	69.0	7.16	4,682, 923	0.95	1.05	7.2	0.00	0	1.21	Jeff C	2:00 PM
8	Tues	70.1	8.05	4,689, 707	0.92	1.02	7.2	0.00	0	1.18	Jeff C	2:30 PM
9	Wed	71.1	8.80	4,695, 598	0.72	0.86	7.2	0.00	0	1.01	Jeff C	3:00 PM
10	Thurs	72.0	8.51	4,696, 606	0.71	0.87	7.2	0.00	0	1.00	Jeff C	8:00 AM
11	Fri	72.1	7.16	4,696, 606	0.71	0.86	7.2	0.00	0	1.00	Jeff C	10:00 AM
12	SAT											
13	SUN											
14	Mon	70.0	8.02	4,709, 356	0.63	0.71	7.3	0.00	0	0.98	Jeff C	4:30 PM
15	Tues	70.0	7.88	4,709, 356	0.63	0.70	7.3	0.00	0	0.99	Jeff C	7:15 AM
16	Wed	66.4	9.00	4,721, 384	0.64	0.71	7.3	0.00	0	1.50	Jeff C	5:30 PM
17	Thurs	65.2	8.42	4,721, 384	0.64	0.71	7.3	0.00	0	1.54	Jeff C	7:15 AM
18	Fri	67.1	8.08	4,721, 384	0.64	0.72	7.3	0.00	0	1.54	Jeff C	9:30 AM
19	SAT											
20	SUN											
21	Mon	66.7	9.00	4,728, 395	0.62	0.65	7.3	0.00	0	1.55	Jeff C	7:00 AM
22	Tues	67.1	7.06	4,728, 395	0.60	0.63	7.3	0.00	0	1.54	Jeff C	2:00 PM
23	Wed	66.7	8.70	4,732, 068	0.52	0.59	7.5	0.03	0	1.53	Jeff C	9:00 AM
24	Thurs	67.1	8.60	4,732, 068	0.50	0.57	7.3	0.01	0	1.50	Jeff C	2:00 AM
25	Fri	69.0	8.58	4,732, 068	0.51	0.55	7.3	0.00	0	1.51	Jeff C	2:00 AM
26	SAT											
27	SUN											
28	Mon	72.0	8.80	4,737, 831	0.49	0.56	7.3	0.00	0	1.22	Jeff C	2:00 AM
29	Tues	71.9	8.61	4,737, 831	0.49	0.56	7.3	0.00	0	1.21	Jeff C	4:00 AM
30	Wed	71.0	8.14	4,737, 831	0.47	0.55	7.3	0.00	0	1.21	Jeff C	9:00 AM
31												

 Sewage
 
 Water



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1060573
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1060573-01	Drinking Water	06/04/2021 10:25	6/4/21 16:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager



ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE ONLY



1060573

(570) 321-9003
FAX: (570) 321-1957

THWEST DIVISION
Main Street
Pottsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL# 1060573	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	01	6-4-21	1025	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.42

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Monthly

Notes/Special Instructions:

Sampled By: (Signature) <i>[Signature]</i>	Date/ Time 6-4-21 1025
Relinquished By: (Signature) <i>[Signature]</i>	Date/ Time 6-4-21 1025
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Correct Preservations (Y/N/NA)	Correct Containers (Y/N/NA)
Receipt Temperature 4.8°C	Receipt Temperature ICE

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.org

Email Address: jcampbell@moniteau.org

Billing Address: 5100324

PWSID: 5100324



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1061278
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1061278-01	Drinking Water	06/10/2021 12:55	6/11/21 10:29	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/11/2021 15:08

Lab Sample ID#: 1061278-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 06/10/2021 12:55
Receipt Date: 06/11/2021 10:29

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.750	mg/L		0.200	PS	06/10/21 12:55	06/10/21 12:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 704	1061278	6/10/21	1255	DW	Field	Field	Free Chlorine .78 mg/L

ROTATION
 Wk 1 - 704 Kitchen Sink
 Wk 2 - 802 Room 204 Sink
 Wk 3 - 803 Admin Sink
 Wk 4 - 804 400 Hall RR Sink
 Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:
 Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)	6/10/21 1055	Date/ Time
Relinquished By: (Signature)	6/10/21 1438	Date/ Time
Relinquished By: (Signature)		Date/ Time
Relinquished By: (Signature)		Date/ Time

Received By: (Signature)	6/11/21 1020 1050	Date/ Time
Received By: (Signature)		Date/ Time
Received By: (Signature)		Date/ Time

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature

Company Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: jcampbell@moniteau.org
 Billing Address:
 PWSID: 5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.75	061021	704		061021	D	1255	32382	1061278-01	BROWNKA_388
5100324	1013	FREE CHLORINE	301	1.42	060421	802		060421	D	1025	32382	1060573-01	BROWNKA_94
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1025	32382	1060573-01	BROWNKA_95



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 June 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1061915
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1061915-01	Drinking Water	06/17/2021 13:40	6/17/21 15:58	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/17/2021 19:06

Lab Sample ID#: 1061915-01
 Sample Type: Drinking Water
 Sample Source: Grab
 Sampler: Paul Somogyi
 Client Sample ID: 803 Admin Sink

Sample Date: 06/17/2021 13:40
 Receipt Date: 06/17/2021 15:58

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.560	mg/L		0.200	PS	06/17/21 13:40	06/17/21 13:40



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.75	061021	704		061021	D	1255	32382	1061278-01	BROWNKA_388
5100324	1013	FREE CHLORINE	301	1.42	060421	802		060421	D	1025	32382	1060573-01	BROWNKA_94
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1025	32382	1060573-01	BROWNKA_95
5100324	1013	FREE CHLORINE	301	0.56	061721	803		061721	D	1340	32382	1061915-01	BROWNKA_810



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

24 June 2021

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 1062505
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1062505-01	Drinking Water	06/24/2021 11:40	6/24/21 13:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/24/2021 19:33

Lab Sample ID#: 1062505-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 06/24/2021 11:40
Receipt Date: 06/24/2021 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	06/24/21 11:40	06/24/21 11:40

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



1062505



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>1062505</u>	<u>6/24/21</u>	<u>1140</u>	DW	Field	Field	Free Chlorine <u>64</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcambell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>							
Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>6-24-21 1140</u>	Received By: (Signature)	<u>X5</u>	Date/ Time	<u>6-24-21 13:45</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>6-24-21 13:48</u>	Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature			

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.75	061021	704		061021	D	1255	32382	1061278-01	BROWNKA_388
5100324	1013	FREE CHLORINE	301	1.42	060421	802		060421	D	1025	32382	1060573-01	BROWNKA_94
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060521	802		060421	D	1025	32382	1060573-01	BROWNKA_95
5100324	1013	FREE CHLORINE	301	0.56	061721	803		061721	D	1340	32382	1061915-01	BROWNKA_810
5100324	1013	FREE CHLORINE	301	0.64	062421	804		062421	D	1140	32382	1062505-01	BROWNKA_1070

**Moniteau School District
Maintenance Department
Monthly Report
Moniteau High School
Wastewater Treatment Facility
June 2021**

Moniteau School District
Moniteau High School Wastewater Plant
Monthly Report for June 2021

Flow $54,151 \div 30 = 1,805.03$ Daily Avg.

U.V. $110.5 \div 22 = 5.02$ Avg.

PH Low 6.07

High 8.77

D.O. Low 7.24

High 10.23

TOTAL Nitrogen - $<0.520 + 0.147 = 0.667 \div 2 = 0.3335$

TSS - $<5 + <5 = <10 \div 2 = <5$

Nitrate / Nitrite - $<0.520 + 0.147 = 0.667 \div 2 = 0.3335$

Phosphorus - $0.20 + 0.12 = 0.32 \div 2 = 0.16$

CBOD - $14.1 + <12.0 = 26.1 \div 2 = 13.05$

Fecal Coliforms - $<5 + <1 = <6 \div 2 = <3$



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
FACILITY: MONITEAU JR SR HIGH SCHOOL
LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly
DMR Effective From: 06/01/2021
DMR Effective To: 06/30/2021
Permit Expires: 05/31/2022
Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2021	06	01	2021	06	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.24	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	mg/L	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.07	***	8.77	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	***	<5.0	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	30 Avg Mo	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***	***	.33	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		***	***	.16	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	***	5.02	1/week	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.001805	MGD	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<3.0	<3.0		No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		***	200	1000	IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	13.05	***			2/month	Grab
	PERMIT REQUIREMENT	***		***	25	***		mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jul 7, 2021 at 10:13 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 06/01/2021-06/30/2021
Report Due Date: 07/28/2021

Submitted By: Jeffrey Campbell
Submission Id: 272807
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 June 2021

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 1060552
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1060552-01	Waste Water	06/04/2021 09:30	6/4/21 16:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- MH Matrix Spike recovery exceeded the laboratory acceptance criteria; result may be biased high.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/17/2021 08:24

Lab Sample ID#: 1060552-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/04/2021 09:30
Receipt Date: 06/04/2021 16:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	<0.520	mg/L		0.520	AW	06/15/21 15:29	06/15/21 15:29
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	06/09/21 10:39	06/09/21 13:15
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	<0.520	mg/L	MH	0.520	AW	06/15/21 15:29	06/15/21 15:29
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.20	mg/L		0.10	JPD/AW	06/09/21 11:00	06/09/21 14:10
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	14.1	mg/L	BB, SS	12.0	JAW	06/05/21 15:00	06/10/21 09:30
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<5	MPN/100 mL		5	RAE	06/04/21 16:50	06/05/21 13:33



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	Work Ord 1060552
------------------------	-------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SW/INSLV</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>6/4/12 1032</u>	Date Sampled: <u>6/4/12</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>2.4</u> °C	IR Gun ID: <u>43</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____ / / _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)	Signature	Date	Time
Chain of custody documents included with samples?	<u>YES</u> NO	Comments:			
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments:			
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____			
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected:			
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:			
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:			
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected:			
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH:			
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.			
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected:			
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>YES</u> <u>NO</u>	Sample IDs and Containers Affected:			
Other Comments:			Deficiency Log Created: YES <u>NO</u>		

Effective Date:

GP.25.A-1 Sample Receipt Log



Results Report

Order ID: 1F02795

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 1F02795-01	Site: 1060552-01	Sample ID: 1060552
Collector: Client	Collect Date: 06/04/2021 9:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Inorganics									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	06/14/21	EJJ	06/15/21 13:55	EJJ

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 06/16/2021 3:45 pm 1F02795
STL_Results Revision #1.9 Effective: 04/16/2020





1F02795
Lisa F. Care

CONTRACT ORDER
Environmental Service Laboratories, Inc.
1060552

@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1060552-01			
Matrix: Water	Sampled: 06/04/2021 09:30	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	06/16/2021 23:00	07/02/2021 09:30	
Containers Supplied: Poly 250mL, H2SO4 (D)	PHC2		

PHV
DWC
6/8/21

Suburban Testing Labs

Lab Date/Time: 6/8/21 1210 Lab Temp: 1.4°C SOE

- Number of containers/coolers match number on COC? Y / N
- Sample labels and COC are free of discrepancies? Y / N
- All containers in tact? Y / N
- Received in lab within acceptable temperature limits? Y / N
- 40mL VOA vials free of headspace? Y / N

Relinquished by: delivery
Received in Lab by: dw ①

Released By: g Date: 6/8/21 Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

25 June 2021

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 1061898
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1061898-01	Waste Water	06/17/2021 11:45	6/17/21 15:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/25/2021 15:05

Lab Sample ID#: 1061898-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Grab

Sample Date: 06/17/2021 11:45
Receipt Date: 06/17/2021 15:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	0.147	mg/L		0.104	AW	06/23/21 15:56	06/23/21 15:56
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	06/22/21 11:29	06/22/21 12:45
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.147	mg/L		0.104	AW	06/23/21 15:56	06/23/21 15:56
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.12	mg/L		0.10	AW	06/25/21 10:00	06/25/21 10:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<12.0	mg/L	G	12.0	AS	06/18/21 13:40	06/23/21 09:35
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	06/17/21 16:24	06/18/21 11:14

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



1061898



NORTHWEST DIVISION
950 Main Street
Sharnsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/off	Date	Time			
Effluent Outfall 001	1061898		6/17/21	11:45 AM	1	Poly 1000mL	CBOD, TSS
					1	None	Total Nitrogen, Total Phosphorus
					1	Poly 1000mL H2SO4	Fecal Coliform
						Sterile Plastic 125mL	
						Na2S2O3	
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 6/17/21 11:45</p>				<p>Project Notes: Wastewater</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 6/17/21 1:35</p>				<p>Company Name: MONTEAU SCHOOL DISTRICT</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 6/17/21 1:58</p>				<p>Contact Person: JEFFREY CAMPBELL</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 6/17/21 1:58</p>				<p>Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 6/17/21 1:58</p>				<p>Phone / Cell: 724-406-4426</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Email: icampbell@monteau.org</p>			
<p>Correct Containers Y / N / NA</p>				<p>Receipt Temperature</p>			



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	Work Order: 1061898
------------------------	----------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JM/WJB</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>6/17/17 1530</u>	Date Sampled: <u>6/17/17</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>36</u> °C	IR Gun ID: <u>45</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____ / _____ / _____ Signature Date Time

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO	Comments:
Sample containers intact and sealed?	<u>YES</u> NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>YES</u> <u>NO</u>	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES <u>NO</u>

Effective Date:

GP.25.A-1 Sample Receipt Log



Results Report

Order ID: 1F04571

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 1F04571-01	Site: 1061898-01	Sample ID: 1061898
Collector: Client	Collect Date: 06/17/2021 11:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Inorganics									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	06/23/21	EJJ	06/24/21 12:46	ZJH

Sample Receipt Conditions: All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 06/24/2021 4:40 pm 1F04571
STL_Results Revision #1.9 Effective: 04/16/2020





UBCONTRACT ORDER

Environmental Service Laboratories, Inc.

1061898

1F04571
Lisa F. Care

... report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1061898-01			
Matrix: Water	Sampled: 06/17/2021 11:45	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen		06/29/2021 23:00	07/15/2021 11:45
Containers Supplied: Poly 250mL, H2SO4 (D)	pH < 2 TUB 6/18/21		

Suburban Testing Labs

Lab Date/Time: 6/18/21 1026 Lab Temp: 5.9°C
ICE

- Number of containers/coolers match number on COC? Y/N
- Sample labels and COC are free of discrepancies? Y/N
- All containers in tact? Y/N
- Received in lab within acceptable temperature limits? Y/N
- 40mL VOA vials free of headspace? Y/N

Relinquished by: Delivery
Received in Lab by: TUB 6/18/21 1026 5.9°C

Released By: _____ Date: 6/17/21 Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____

