

**Moniteau School District**  
**Maintenance Department**  
**Dassa McKinney Elementary School**  
**Monthly Water Treatment Plant**  
**Operations Report**  
**May 2021**

Dassa McKinney Elementary School Water Treatment Facility											
Month	Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
	1	Sat									
	2	Sun									
	3	Mon	8.7	0.04	0.65	0.69	3.27	12568300	Jeff R	3:00P	5100
	4	Tues	8.7	0.02	0.60	0.68	3.13	12573700	Jeff R	3:00P	5400
	5	Wed	8.7	0.01	0.51	0.57	2.68	12577700	Jeff R	3:00P	4000
	6	Thurs	8.7	0.04	0.46	0.53	2.26	12582900	Jeff R	3:00P	5200
	7	Fri	8.7	0.02	0.47	0.55	2.13	12587400	Jeff R	3:00P	4500
	8	Sat									
	9	Sun									
	10	Mon	8.7	0.00	0.35	0.42	2.88	12592000	Jeff R	3:00P	4600
	11	Tues	8.7	0.02	0.46	0.53	2.91	12594400	Jeff R	3:00P	4100
	12	Wed	8.7	0.05	0.63	0.70	1.87	12601100	Jeff R	3:00P	4700
	13	Thurs	8.7	0.03	0.70	0.80	1.92	12609800	Jeff R	3:00P	8700
	14	Fri	8.7	0.02	0.73	0.79	3.10	12610500	Jeff R	3:00P	700
	15	Sat									
	16	Sun									
	17	Mon	8.7	0.03	0.64	0.71	3.12	12614500	Jeff R	3:30P	4000
	18	Tues	8.7	0.04	0.62	0.64	2.66	12618800	Jeff R	3:00P	4300
	19	Wed	8.7	0.02	0.68	0.75	2.48	12623200	Jeff R	3:30P	4100
	20	Thurs	8.7	0.03	0.74	0.83	2.27	12627500	Jeff R	3:30P	4300
	21	Fri	8.7	0.02	0.76	0.85	2.92	12632200	Jeff R	3:30P	4700
	22	Sat									
	23	Sun									
	24	Mon	8.7	0.02	0.65	0.69	2.70	12636300	Jeff R	3:30P	4100
	25	Tues	8.7	0.03	0.59	0.66	2.28	12640600	Jeff R	3:00P	4300
	26	Wed	8.7	0.02	0.58	0.64	2.32	12644900	Jeff R	7:30P	4300
	27	Thurs	8.7	0.02	0.54	0.60	2.19	12649600	Jeff C	10:30A	4700
	28	Fri	8.7	0.02	0.52	0.60	2.21	12654600	Jeff C	1:00PM	5000
	29	Sat									
	30	Sun									
	31	Mon									

\*ATHM/HAA 5

Meter Reading - 4/30/21 - 12563100



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1050507**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1050507-01	Drinking Water	05/06/2021 10:50	5/6/21 13:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/11/2021 13:14

**Lab Sample ID#:** 1050507-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** John Cavallo, Jr.  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 05/06/2021 10:50  
**Receipt Date:** 05/06/2021 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.400	mg/L		0.200	JC	05/06/21 10:50	05/06/21 10:50



**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

LABORATORY USE ONLY  
FAX: (724) 321-1957  
FAX: (724) 465-4209



1050507

**SAMPLE RECEIPT & RECORD OF CUSTODY**

RE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 801	1050507	5-6	1050	DW	Field	Field	Free Chlorine 0.40 mg/L
<p><b>ROTATION</b></p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.org**

Cell Phone: **5100316**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) *[Signature]* Date/ Time **5-6-21 1050**

Relinquished By: (Signature) *[Signature]* Date/ Time **5-6-21 1300**

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations **Y / N / (NA)** Correct Containers **Y / N / (NA)** Receipt Temperature \_\_\_\_\_

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
**VIEW/EDIT RECORDS**

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.4	050621	801		050621	D	1050	32382	1050507-01	BROWNKA_42



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

14 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1051225**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1051225-01	Drinking Water	05/13/2021 13:00	5/13/21 15:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/14/2021 14:38

**Lab Sample ID#:** 1051225-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 05/13/2021 13:00  
**Receipt Date:** 05/13/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.700	mg/L		0.200	PS	05/13/21 13:00	05/13/21 13:00





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.4	050621	801		050621	D	1050	32382	1050507-01	BROWNKA_42
5100316	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1300	32382	1051225-01	BROWNKA_520



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISI  
1276 Bentleyville R  
Van Voorhis, PA 15  
(724) 258-TEST  
FAX: (724) 258-8

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

Page 4 of 4

<p>Sample Identification</p> <p>ESL# <u>1051225</u></p>		<p>Sample Type</p> <p>Grab</p>		<p>Matrix</p> <p>DW</p>		<p># of Bottles</p> <p>Field</p>		<p>Container Type</p> <p>Preservative</p> <p>Field</p>		<p>Analysis Requested</p> <p>Free Chlorine <u>170</u> mg/L</p>					
<p>Distribution: <u>500</u></p>		<p>Date</p> <p>5-13-11</p>		<p>Time</p> <p>1300</p>		<p>Field</p>		<p>Field</p>		<p>mg/L</p>					
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>															
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>															
<p>Sampled By: (Signature)</p> <p><i>[Signature]</i></p>				<p>Date/ Time</p> <p>5/13/11 1300</p>				<p>Received By: (Signature)</p> <p><i>[Signature]</i></p>				<p>Date/ Time</p> <p>5/13/11 1500</p>			
<p>Relinquished By: (Signature)</p>				<p>Date/ Time</p>				<p>Received By: (Signature)</p>				<p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p>				<p>Date/ Time</p>				<p>Received By: (Signature)</p>				<p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p>				<p>Date/ Time</p>				<p>Received By: (Signature)</p>				<p>Date/ Time</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>				<p>Receipt Temperature</p>							
<p>Notes/Special Instructions::</p> <p><b>Drinking Water Dassa McKinney - Weekly</b></p>															
<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD</b></p> <p><b>WEST SUNBURY, PA 16061</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.org</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: <b>5100316</b></p> <p>PWSID: <b>5100316</b></p>															



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

21 May 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1051870**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	1051870-01	Drinking Water	05/20/2021 12:10	5/20/21 15:38	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/21/2021 10:14

**Lab Sample ID#:** 1051870-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 05/20/2021 12:10  
**Receipt Date:** 05/20/2021 15:38

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.630	mg/L		0.200	PS	05/20/21 12:10	05/20/21 12:10



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

TEST DIVISION  
Street PA 16 EST  
465-4209



## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABOR.

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 803	1051870	5/29/1	12:00	DW	Field	Field	Free Chlorine .63 mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1-1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
<i>[Signature]</i>	5/29/1 12:00	<i>[Signature]</i>	5/29/1 12:00
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
<i>[Signature]</i>	5/29/1 12:00	<i>[Signature]</i>	5/29/1 12:00
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
<i>[Signature]</i>	5/29/1 12:00	<i>[Signature]</i>	5/29/1 12:00
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
<i>[Signature]</i>	5/29/1 12:00	<i>[Signature]</i>	5/29/1 12:00
Correct Preservations Y / N (NA)	Correct Containers Y / N (NA)	Receipt Temperature	
Y	Y	5	

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
**JEFFREY CAMPBELL**  
 Contact Person:  
 Phone Number: **724-406-4426**  
 Cell Phone:  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address:  
 PWSID: **5100316**

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.4	050621	801		050621	D	1050	32382	1050507-01	BROWNKA_42
5100316	1013	FREE CHLORINE	301	0.7	051321	801		051321	D	1300	32382	1051230-01	BROWNKA_740
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	051421	801		051321	D	1300	32382	1051230-01	BROWNKA_741
5100316	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1300	32382	1051225-01	BROWNKA_520
5100316	1013	FREE CHLORINE	301	0.63	052021	803		052021	D	1210	32382	1051870-01	BROWNKA_1083





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

27 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1052383**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1052383-01	Drinking Water	05/27/2021 11:00	5/27/21 13:28	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/27/2021 21:14

**Lab Sample ID#:** 1052383-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 05/27/2021 11:00  
**Receipt Date:** 05/27/2021 13:28

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.520	mg/L		0.200	PS	05/27/21 11:00	05/27/21 11:00



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.4	050621	801		050621	D	1050	32382	1050507-01	BROWNKA_42
5100316	1013	FREE CHLORINE	301	0.7	051321	801		051321	D	1300	32382	1051230-01	BROWNKA_740
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	051421	801		051321	D	1300	32382	1051230-01	BROWNKA_741
5100316	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1300	32382	1051225-01	BROWNKA_520
5100316	1013	FREE CHLORINE	301	0.63	052021	803		052021	D	1210	32382	1051870-01	BROWNKA_1083
5100316	1013	FREE CHLORINE	301	0.52	052721	804		052721	D	1100	32382	1052383-01	BROWNKA_1644



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



ST DIVISION  
Street PA 16  
WEST

FOR INTERNAL LABORATORY USE ONLY

FAX: (724) 465-4209

FAX: (570) 321-1957

SE 1 OF 1

## SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SWH</u>	<u>1052383</u>	<u>5/27/12</u>	<u>1100</u>	DW	Field	Field	Free Chlorine <u>1.52</u> mg/L
	<u>ca</u>						

ROTATION  
 Wk 1 - 801 Kitchen Sink  
 Wk 2 - 802 Room 617 Sink  
 Wk 3 - 803 Room 606 Sink  
Wk 4 - 804 Room 408 Sink  
 Wk 5 - 802 Room 617 Sink

Notes/Special Instructions:  
**Drinking Water Dassa McKinney - Weekly**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Sampled By: (Signature) [Signature] Date/ Time 5/27/12 1100

Relinquished By: (Signature) [Signature] Date/ Time 5/27/12 1300

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA Y / N / NA Correct Containers Y / N / NA Y / N / NA Receipt Temperature \_\_\_\_\_

**Moniteau School District  
Maintenance Department  
Moniteau High School  
Monthly Water Treatment Plant  
Operations Report  
May 2021**







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1050505**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1050505-01	Drinking Water	05/06/2021 11:10	5/6/21 13:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 05/11/2021 10:46

**Lab Sample ID#:** 1050505-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** John Cavallo, Jr  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 05/06/2021 11:10  
**Receipt Date:** 05/06/2021 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.350	mg/L		0.200	JWD	05/06/21 11:10	05/06/21 11:10

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN DIVISION**  
 1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-8376

**NORTHE**  
 435 Broac  
 Montoursv  
 (570) 321-  
 FAX: (570) 463-TEST



1050505

(724) 463-TEST  
 FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

STUDY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>704</u>	<u>1050505</u>	<u>5-6</u>	<u>1110</u>	DW	Field	Field	Free Chlorine <u>0.35</u> mg/L
<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: 0 auto;">           ROTATION  <u>Wk 1 - 704 Kitchen Sink</u>            Wk 2 - 802 Room 204 Sink            Wk 3 - 803 Admin Sink            Wk 4 - 804 400 Hall RR Sink            Wk 5 - 804 400 Hall RR Sink         </div>							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>5-6-21 1130</u>		Received By: (Signature) <u>[Signature]</u> Date/ Time <u>5-6-21 1300</u>		Notes/Special Instructions: <b>Drinking Water Moniteau Jr/Sr - Weekly</b>			
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____		Company/Name: <b>MONITEAU SCHOOL DISTRICT</b>			
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____		Address: <b>391 HOOKER ROAD</b> <b>WEST SUNBURY, PA 16061</b>			
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____		Contact Person: <b>JEFFREY CAMPBELL</b>			
Correct Preservations Y / N / (NA)		Correct Containers Y / N / (NA)		Billing Address: <b>724-406-4426</b> <b>jcampbell@moniteau.org</b>			
Receipt Temperature _____		Receipt Temperature _____		PWSID: <b>5100324</b>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.35	050621	704		050621	D	1110	32382	1050505-01	BROWNKA_43





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

16 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1051226**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1051226-01	Drinking Water	05/13/2021 13:15	5/13/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/16/2021 21:27

**Lab Sample ID#:** 1051226-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 05/13/2021 13:15  
**Receipt Date:** 05/13/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.700	mg/L		0.200	PS	05/13/21 13:15	05/13/21 13:15

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



1051226

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>SQ</u>	<u>1051226</u>	<u>5/30/15</u>	<u>1315</u>	DW	Field	Field	Free Chlorine <u>70</u> mg/L

**ROTATION**

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) 	Date/ Time <u>5/27/15 1315</u>	
Relinquished By: (Signature) 	Date/ Time <u>5/27/15 1420</u>	
Relinquished By: (Signature) 	Date/ Time <u>5/27/15 1500</u>	
Relinquished By: (Signature)	Date/ Time	
Relinquished By: (Signature)	Date/ Time	
Relinquished By: (Signature)	Date/ Time	
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature

Notes/Special Instructions::

**Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
 Contact Person: **JEFFREY CAMPBELL**  
 Phone Number: **724-406-4426**  
 Cell Phone: **jcampbell@moniteau.org**  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address:  
 PWSID: **5100324**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.35	050621	704		050621	D	1110	32382	1050505-01	BROWNKA_43
5100324	1013	FREE CHLORINE	301	0.7	051321	704		051321	D	1315	32382	1051228-01	BROWNKA_742
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	051421	704		051321	D	1315	32382	1051228-01	BROWNKA_744
5100324	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1315	32382	1051226-01	BROWNKA_743





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

21 May 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1051871**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1051871-01	Drinking Water	05/20/2021 12:30	5/20/21 15:38	

**Report Narrative**

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

**Definitions**

RL Reporting Limit

**Certifications**

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

**Approved By**

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/21/2021 10:14

**Lab Sample ID#:** 1051871-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 05/20/2021 12:30  
**Receipt Date:** 05/20/2021 15:38

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.690	mg/L		0.200	PS	05/20/21 12:30	05/20/21 12:30

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



FOR INTERNAL LABORATORY USE ONLY  
FAX: (570) 321-1957

NORTHWEST DIVISION  
10 Main Street  
Parsippany, NJ 07054  
(724) 463-TEST  
FAX: (724) 465-4209

## CHAIN OF CUSTODY

DATE: 11/11/08 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 803	1051871	Grab	DW	Field	Field	Free Chlorine 0.69 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>						
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
Sampled By: (Signature)		Date/ Time: 5/20/08 1430		Received By: (Signature)		
Relinquished By: (Signature)		Date/ Time: 5/20/08 1447		Received By: (Signature)		
Relinquished By: (Signature)		Date/ Time:		Received By: (Signature)		
Relinquished By: (Signature)		Date/ Time:		Received By: (Signature)		
Correct Preservations Y/N <u>NA</u>		Correct Containers Y/N <u>NA</u>		Receipt Temperature <u>—</u>		
Company/Name: MONITEAU-SCHOOL-DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: Phone Number: 724-406-4426 Cell Phone: icampbell@moniteau.org Email Address: Billing Address: PWSID: 5100324						



**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.35	050621	704		050621	D	1110	32382	1050505-01	BROWNKA_43
5100324	1013	FREE CHLORINE	301	0.7	051321	704		051321	D	1315	32382	1051228-01	BROWNKA_742
5100324	2450	MONOCHLOROACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_531
5100324	2451	DICHLOROACETIC ACID	206	0.00408	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_544
5100324	2452	TRICHLOROACETIC ACID	206	0.00116	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_557
5100324	2453	MONOBROMOACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_570
5100324	2454	DIBROMOACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_583
5100324	2456	HALOACETIC ACIDS (FIVE)	206	0.00524	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_596
5100324	2941	CHLOROFORM (THM)	221	0.0178	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_609
5100324	2942	BROMOFORM (THM)	221	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_622
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.00773	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_635
5100324	2944	CHLORODIBROMOMETHANE (THM)	221	0.00268	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_648
5100324	2950	TRIHALOMETHANES	221	0.0283	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_661
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	051421	704		051321	D	1315	32382	1051228-01	BROWNKA_744
5100324	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1315	32382	1051226-01	BROWNKA_743
5100324	1013	FREE CHLORINE	301	0.69	052021	803		052021	D	1230	32382	1051871-01	BROWNKA_1084



2/26 ✓m  
2:30pm

**PAUL K. POULOS**

2364 Eastbrook Road, New Castle, PA 16105  
724-859-8947

**Objective:** To obtain a position that will utilize and develop my existing skills, knowledge base, and adaptability.

**EMPLOYMENT**

- April 2010  
to present      **Youngblood Paving Inc**, Wampum, PA
- Operate and maintained the following equipment on a daily basis; Roller, Maintainer, Skid Loader, Paver, Tractor Trailer, and Tri-axle Dump Truck.
  - Commercial parking lots, roadways, and residential driveways.
- December 2011  
to March 2014      **Cranberry Township Municipal, Department of Public Works, Facilities**, Cranberry Twp., PA
- Provide maintenance and perform various duties on facilities as directed
- June 1986  
to present      **Meinert Well Drilling**, Zelienople, PA
- Drill wells and Install water systems.
- May 2008 to  
April 2010      **Craig Wicks Trucking and Excavating**, Economy Borough, PA
- Drove and maintained a Tandem Truck for Walsh Construction
- March 2001  
to May 2008      **White Oak Paving** New Castle, PA
- Owner Operator / CDL Class A Licensed
  - Operate and maintained the following equipment on a daily basis; Roller, Maintainer, Skid Loader, Paver, Tractor Trailer and Tri-axle Dump Truck.
  - Supervise seven to ten company employees.
  - Commercial parking lots, roadways, and residential driveways.
  - Bidding and pricing of all types of paving applications.
  - Experience with catch basins and risers.
- May 2000 to  
March 2001      **Lawrence County Corrections**, Prison, New Castle, PA
- *Correction Officer*
- Nov 1996 to  
May 1997      **State Pipe Services**, Cranberry Township, PA
- Installed Commercial sewage lines.
- April 1989 to  
October 1999      **C J Long Paving**, New Castle, PA
- Operate the following equipment on a daily basis; Roller, Maintainer, Skid Loader, Paver, Tractor Trailer, and Tri-axle Dump Truck.
  - Foreman and Supervised seven to ten company employees.
  - Commercial parking lots, roadways, and residential driveway.
- May 1988 to  
April 1989      **American Motors Corporation**, Automotive Parts Distribution Center, Warrendale, PA
- Packaging, Shipping and Receiving Automotive parts, and forklift operator.
- July 1984 to  
December 1985      **Beaver Valley Builder Supply**, Concrete and Construction Company, Ambridge, PA
- *Lubrication and Mechanic*
  - *Rebuild Alternators, Generators, and maintenance on trucks and heavy equipment.*
  - Tested and received a CDL Class A operators license.
- March 1984 to  
July 1984      **Wiegand Brothers Transmissions** North Hills, PA
- *Transmission Technician, rebuilt and installed transmissions*

**EDUCATION:**

- SLIPPERY ROCK UNIVERSITY** – Environmental Studies January 1986 to May 1988  
**ROSEDALE TECHNICAL INSTITUTE** – Automotive and Diesel Technologies  
September 1982 to March 1984  
**AMBRIDGE AREA HIGH SCHOOL** – Graduate June 1982

**References available upon request**



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

27 May 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1052384**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1052384-01	Drinking Water	05/27/2021 11:20	5/27/21 13:29	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/27/2021 21:14

**Lab Sample ID#:** 1052384-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 05/27/2021 11:20  
**Receipt Date:** 05/27/2021 13:29

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.980	mg/L		0.200	PS	05/27/21 11:20	05/27/21 11:20



**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.35	050621	704		050621	D	1110	32382	1050505-01	BROWNKA_43
5100324	1013	FREE CHLORINE	301	0.7	051321	704		051321	D	1315	32382	1051228-01	BROWNKA_742
5100324	2450	MONOCHLOROACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_531
5100324	2451	DICHLOROACETIC ACID	206	0.00408	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_544
5100324	2452	TRICHLOROACETIC ACID	206	0.00116	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_557
5100324	2453	MONOBROMOACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_570
5100324	2454	DIBROMOACETIC ACID	206	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_583
5100324	2456	HALOACETIC ACIDS (FIVE)	206	0.00524	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_596
5100324	2941	CHLOROFORM (THM)	221	0.0178	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_609
5100324	2942	BROMOFORM (THM)	221	0.0	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_622
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.00773	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_635
5100324	2944	CHLORODIBROMOMETHANE (THM)	221	0.00268	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_648
5100324	2950	TRIHALOMETHANES	221	0.0283	051321	704		051021	D	0855	32382	1050739-01	BROWNKA_661
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	051421	704		051321	D	1315	32382	1051228-01	BROWNKA_744
5100324	1013	FREE CHLORINE	301	0.7	051321	802		051321	D	1315	32382	1051226-01	BROWNKA_743
5100324	1013	FREE CHLORINE	301	0.69	052021	803		052021	D	1230	32382	1051871-01	BROWNKA_1084
5100324	1013	FREE CHLORINE	301	0.98	052721	804		052721	D	1120	32382	1052384-01	BROWNKA_1645



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHWEST DIVISION  
Main Street  
Pittsburgh, PA 15201  
(412) 463-TEST  
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

## SAMPLE REQUEST & CHAIN OF CUSTODY

DATE: \_\_\_/\_\_\_/\_\_\_ OF \_\_\_ 1\_\_\_

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SOU</u>	<u>1052384</u>	<u>SOT</u>	<u>120</u>	DW	Field	Field	Free Chlorine <u>0.98</u> mg/L
<p><b>ROTATION</b></p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions: <b>Drinking Water Moniteau Jr/Sr - Weekly</b></p>							
<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.org</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: <b>5100324</b></p> <p>PWSID: <b>5100324</b></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u></p> <p>Date/Time: <u>SOT 1120</u></p>		<p>Received By: (Signature) <u>[Signature]</u></p> <p>Date/Time: <u>5/20/13 13:21 (W/S)</u></p>					
<p>Relinquished By: (Signature)</p> <p>Date/Time:</p>		<p>Received By: (Signature)</p> <p>Date/Time:</p>					
<p>Relinquished By: (Signature)</p> <p>Date/Time:</p>		<p>Received By: (Signature)</p> <p>Date/Time:</p>					
<p>Relinquished By: (Signature)</p> <p>Date/Time:</p>		<p>Received By: (Signature)</p> <p>Date/Time:</p>					
<p>Correct Preservations Y/N <u>(NA)</u></p>		<p>Correct Containers Y/N <u>(NA)</u></p>		<p>Receipt Temperature <u>    </u></p>			

**Moniteau School District  
Maintenance Department  
Moniteau High School  
Monthly Waste Water Treatment Plant  
Operations Report  
May 2021**



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 05/01/2021  
 DMR Effective To: 05/31/2021  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2021	05	01	2021	05	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		4.26	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.18	***	7.97	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	***	<5.0	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	30 Avg Mo	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***	***	13.11	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		***	***	1.25	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	***	5.13	1/week	Grab
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.003147	MGD	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo		***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		6.0	6.0	6.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		200	1000	IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		4.66	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		25	***	Avg Mo		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------





JEFFREY CAMPBELL &lt;jcampbell@moniteau.org&gt;

---

**Your eDMR Report Has Been Received For Permit No. PA0091341**

1 message

---

**depgreenporthelpdesk@state.pa.us** <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, Jun 9, 2021 at 1:34 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 05/01/2021-05/31/2021  
**Report Due Date:** 06/28/2021

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 268845  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau School District  
 MAINTENANCE DEPT.  
 Moniteau High School  
 WASTE WATER TREATMENT PLANT  
 Monthly Work sheet for May 2021

Flow  $97,579 \div 31 = 3,147$  Daily Avg.

UV  $102.7 \div 20 = 5.135$  Daily Avg.

PH Low 6.18

High 7.97

DO Low 4.26

High 8.77

TOTAL Nitrogen  $0.630 + 25.6 = 26.23 \div 2 = 13.115$

TSS  $< 5 + < 5 = < 5$

Nitrate / Nitrite  $0.630 + 24.3 = 24.93 \div 2 = 12.465$

Phosphorous  $< 0.10 + 2.4 = 2.5 \div 2 = 1.25$

CBOD  $7.32 + 72.0 = 9.32 \div 2 = 4.66$

FECAL  $< 1 + 12 = 12 \div 2 = 6$

Moniteau High School Sewage Treatment Plant Permit # PA0091341				Daily Operations Worksheet			
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
5/3	Mon	7.26	4.26			MAY 2021	JEFF R
5/4	Tues	7.18	6.72	DOWN FOR	4.538, 4.11		JEFF R
5/5	Wed	7.11	5.43	SUMMER			JEFF R
5/6	Thurs	7.18	6.37	MAINTENANCE			JEFF R
5/7	Fri	7.19	6.77				JEFF R
5/10	Mon	7.76	8.49				JEFF R
5/11	Tues	7.83	8.21				JEFF C
5/12	Wed	7.97	8.20				JEFF C
5/13	Thurs	7.43	8.18				JEFF C
5/14	Fri	7.47	8.23				JEFF C
5/17	Mon	7.04	6.86				JEFF C
5/18	Tues	7.10	7.01				JEFF C
5/19	Wed	6.84	8.47				JEFF C
5/20	Thurs	6.89	8.51				JEFF C
5/21	Fri	6.94	8.58				JEFF C
5/24	Mon	6.48	8.75				JEFF C
5/25	Tues	6.59	8.77				JEFF C
5/26	Wed	6.36	8.44				JEFF C
5/27	Thurs	6.38	8.50				JEFF C
5/28	Fri	6.18	5.99				JEFF C
5/31	Mon.	Holiday	—				JEFF C
						4,655,990	

\* TEST DAY

\* TEST DAY





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

19 May 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1050508**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1050508-01	Waste Water	05/06/2021 11:00	5/6/21 13:00	

**Report Narrative**

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Incorrect bottle used for CBOD/TSS. Client resampling. 5/19/21 RAE

**Definitions**

RL Reporting Limit

**Certifications**

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

**Approved By**

Rebecca Erwin  
 Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/19/2021 09:10

**Lab Sample ID#:** 1050508-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 05/06/2021 11:00  
**Receipt Date:** 05/06/2021 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	25.6	mg/L		1.04	DAA	05/17/21 16:45	05/18/21 12:38
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	24.3	mg/L		1.04	DAA	05/17/21 16:45	05/18/21 12:38
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	2.4	mg/L		0.50	JPD	05/17/21 15:14	05/17/21 16:20
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	12	MPN/100 mL		1	KEL	05/06/21 15:38	05/07/21 12:19

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTERS**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209



**SOUTHERN DIVISION**  
 1276 Benlleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-8376



**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 16150  
 (724) 463-TEST  
 FAX: (724) 465-4209

FOR INTERNAL

# SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Grab				
		Date on/off	Date				
Effluent Outfall 001	1050508	<del>5/6/21</del>	<del>5/6/21</del>	WW	1	Poly 1000mL	CBOD, TSS  Total Nitrogen, Total Phosphorus  Fecal Coliform
		<del>5/6/21</del>	<del>5/6/21</del>	WW	1	None	
		<del>5/6/21</del>	5/6/21 11:00 AM	WW	1	Poly 1000mL H2SO4	
				WW	1	Sterile Plastic 125mL Na2S2O3	

**Project Notes:**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

**Wastewater**

Company/Name: **MONITEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061**

Phone / Cell: **724-406-4426**

Email: **jcampbell@moniteau.org**

Received By: (Signature) *Jeffrey Campbell* Date/ Time **5/6/21 11:00 AM**

Relinquished By: (Signature) *Jeffrey Campbell* Date/ Time **5/6/21 11:00 AM**

Received By: (Signature) *[Signature]* Date/ Time **5/6/21 11:05 AM**

Relinquished By: (Signature) *[Signature]* Date/ Time **5/6/21 11:05 AM**

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

*Jeffrey Campbell*





## SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montreal</u>	Work Order:  1050508
-------------------------	----------------------

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received:    /    /    _____
Method of Delivery: Client Drop-Off    ESL Courier    Other: _____	Received on Ice?    YES    NO
Sample Receipt Temperature:    _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of:    FECAL    TC/EC    TC MPN    EC MPN    TC/EC MPN <u>N/A</u>	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>J.D. WISN</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>5/6/17 13:00</u>	Date Sampled: <u>5/6/17</u>
Method of Delivery:    FedEx    UPS    Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>5.3</u> °C	IR Gun ID: <u>43</u>
Sample State of Collection: <u>PA</u> NY    OH    WV    Other: _____	PWSID Compliance Drinking Water Samples:    YES <u>NO</u>

### PART C: Receipt Details    Completed (if different from above): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Sample Receipt Criteria		Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u> NO				Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u> NO				Comments:
Sample containers intact and sealed?	<u>YES</u> NO				Circle Applicable:    Damaged Container    Leaking Container Custody Seal Broken    Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u> NO				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u> NO				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u> NO				Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u> NO				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u> NO				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u> NO				For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u> NO				Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>YES</u> <u>NO</u>				Sample IDs and Containers Affected:
Other Comments:					Deficiency Log Created:  YES <u>NO</u>

Effective Date:

GP.25.A-1 Sample Receipt Log



### Results Report

Order ID: 1E02402

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 1E02402-01  
Collector: Client

Site: 1050508-01  
Collect Date: 05/06/2021 11:00 am

Sample ID: 1050508  
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

<u>Inorganics</u>									
Total Kjeldahl Nitrogen (TKN)	1.33	mg/L	EPA 351.2	0.50	1	05/12/21	ZJH	05/13/21 8:07	ZJH

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test pH, Lab is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\*pH, Final for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 05/13/2021 3:05 pm 1E02402  
STL\_Results Revision #1.9 Effective: 04/16/2020







1E02402  
Lisa F. Care

CONTRACT ORDER

Environmental Service Laboratories, Inc.

1050508

esl@envlabs.com. Contact ESL with any questions.

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701  
Phone: 724-463-8378  
Fax: 724-465-4209  
Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
1037F MacArthur Road  
Reading, PA 19605  
Phone : (610) 375-8378  
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1050508-01			
Matrix: Water	Sampled: 05/06/2021 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	05/18/2021 23:00	06/03/2021 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250-10  
-1 H2SO4  
PH 1.2  
FIP

**Suburban Testing Labs**

Lab Date/Time: 5-7-21 1345 Lab Temp: 2-50C FIP

- Number of containers/coolers match number on COC?  Y/N
- Sample labels and COC are free of discrepancies?  Y/N
- All containers in tact?  Y/N
- Received in lab within acceptable temperature limits?  Y/N
- 40mL VOA vials free of headspace?  Y/N

Relinquished by: [Signature]

Received in Lab by: [Signature]

Released By: [Signature] Date: 5/7/21 Received By: [Signature] Date: 5/7/21 0815

Released By: [Signature] Date: 5/7/21 945 Received By: [Signature] Date: 5-7-21





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

24 May 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1051172**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1051172-01	Waste Water	05/13/2021 11:00	5/13/21 16:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/24/2021 16:00

**Lab Sample ID#:** 1051172-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 05/13/2021 11:00  
**Receipt Date:** 05/13/2021 16:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	0.630	mg/L		0.520	DAA	05/19/21 13:13	05/21/21 08:37
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	05/19/21 12:03	05/19/21 12:45
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	0.630	mg/L		0.520	DAA	05/19/21 13:13	05/21/21 08:37
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	<0.10	mg/L		0.10	JPD	05/20/21 11:45	05/20/21 12:30
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	7.32	mg/L	BB, SS	2.00	JAW	05/14/21 17:25	05/19/21 11:30
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	05/13/21 15:32	05/14/21 12:17



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTERS**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHE**  
1276 Ber  
Van Voo  
(724) 251  
FAX: (724)

  
1051172

**NORTHWEST DIVISION**  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

17754  
1957

FOR INTERNAL LABORATORY USE ONLY

# SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Grab				
		Date on/off	Date	Time			
Effluent Outfall 001	01	<del>1051172</del>	5/13/21	11:00 AM	1	Poly 1000mL	CBOD, TSS
					1	None	
					1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
					1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

**Project Notes:**  
Wastewater


Company/Name: **MONTEAU SCHOOL DISTRICT**


Contact Person: **JEFFREY CAMPBELL**


Address: **1810 WEST SUNBURY ROAD**  
**WEST SUNBURY, PA 16061**  
**724-406-4426**


Email: [jcampbell@monteau.org](mailto:jcampbell@monteau.org)


THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.


Sampled By: (Signature)  Date/ Time 5/13/21 11:00 AM

Relinquished By: (Signature)  Date/ Time 5/13/21 1315

Relinquished By: (Signature)  Date/ Time 5/13/21 1600 (00382)

Received By: (Signature)  Date/ Time

Received By: (Signature)  Date/ Time

Received By: (Signature)  Date/ Time

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_





## SAMPLE RECEIPT AND REVIEW FORM



1051172

Client: Moniteau School District

Work Order

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received:    /    /    _____
Method of Delivery: Client Drop-Off    ESL Courier    Other: _____	Received on Ice?    YES    NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of:    FECAL    TC/EC    TC MPN    EC MPN    TC/EC MPN    N/A	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SJM (00382)</u>	Samples Received on Ice? <input checked="" type="radio"/> YES    NO
Date/Time Received: <u>5/13/21 1600</u>	Date Sampled: <u>5/13/21</u>
Method of Delivery:    FedEx    UPS    Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>2.9</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="radio"/> PA    NY    OH    WV    Other: _____	PWSID Compliance Drinking Water Samples:    YES <input checked="" type="radio"/> NO

### PART C: Receipt Details    Completed (if different from above): \_\_\_\_\_

Signature

Date

Time

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Circle Applicable:    Damaged Container    Leaking Container Custody Seal Broken    Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="radio"/> YES	<input type="radio"/> NO	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created:  YES <input checked="" type="radio"/> NO

Effective Date:

GP.25.A-1 Sample Receipt Log



### Results Report

Order ID: 1E03413

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 1E03413-01  
Collector: Client

Site: 1051172-01  
Collect Date: 05/13/2021 11:00 am

Sample ID: 1051172  
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<b>Inorganics</b>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	05/18/21	ZJH	05/20/21 10:24	ZJH

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 05/20/2021 3:45 pm 1E03413  
STL\_Results Revision #1.9 Effective: 04/16/2020





1E03413  
Lisa F. Care

CONTRACT ORDER

Environmental Service Laboratories, Inc.

1051172

envlabs.com. Contact ESL with any questions.

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701  
Phone: 724-463-8378  
Fax: 724-465-4209  
Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
1037F MacArthur Road  
Reading, PA 19605  
Phone : (610) 375-8378  
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1051172-01			
Matrix: Water	Sampled: 05/13/2021 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	05/25/2021 23:00	06/10/2021 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250 mL P H<sub>2</sub>SO<sub>4</sub>  
PH<sub>2</sub> CMV 5/14/21

**Suburban Testing Labs**

Lab Date/Time: 5-14-21 1345 Lab Temp: 2.5°C

Number of containers/coolers match number on COC?  Y  N  
 Sample labels and COC are free of discrepancies?  Y  N  
 All containers in tact?  Y  N  
 Received in lab within acceptable temperature limits?  Y  N  
 40mL VOA vials free of headspace?  Y  N

Relinquished by: [Signature]

Received in Lab by: CMV (1)

Released By: [Signature] Date: 5/13/21 Received By: [Signature] Date: 5/14/21

Released By: [Signature] Date: 5-14-21 Received By: [Signature] Date: 5-14-21







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

27 May 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1051859**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1051859-01	Waste Water	05/20/2021 11:00	5/20/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

CBOD/TSS resample only needed. Notified the client on cancelled analyses on 5/21/21. RAE

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/27/2021 13:29

**Lab Sample ID#:** 1051859-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 05/20/2021 11:00  
**Receipt Date:** 05/20/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>		<b>Analytical Method: SM2540 D-11</b>			<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	05/25/21 13:41	05/25/21 14:00
<b>General Chemistry</b>		<b>Analytical Method: SM5210 B-11</b>			<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	>2.0	mg/L	BB, G, SS	2.00	AW	05/21/21 15:00	05/26/21 09:20

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTERS**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



1051859



(570) 321-9003  
FAX: (570) 321-1957

**NORTHWEST DIVISION**  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

# CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type			Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Date on/off	Grab				
		Date on/off	Date	Time				
Effluent Outfall 001	1051859	<del> </del>	5/20/21	11:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
		<del> </del>			WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
		<del> </del>			WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

**Project Notes:**  
**Wastewater**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 5/20/21 11:00 AM  
 Relinquished By: (Signature) *[Signature]* Date/ Time 5/20/21 11:00 AM  
 Relinquished By: (Signature) *[Signature]* Date/ Time 5/20/21 11:00 AM  
 Relinquished By: (Signature) *[Signature]* Date/ Time 5/20/21 11:00 AM

Received By: (Signature) *[Signature]* Date/ Time 5/20/21 12:25  
 Received By: (Signature) *[Signature]* Date/ Time 5/20/21 12:25  
 Received By: (Signature) *[Signature]* Date/ Time 5/20/21 12:25  
 Received By: (Signature) *[Signature]* Date/ Time 5/20/21 12:25


Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Contact Person: **JEFFREY CAMPBELL**  
 Address: **1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061**  
 Phone / Cell: **724-406-4426**  
 Email: [jcampbell@moniteau.org](mailto:jcampbell@moniteau.org)

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_





## SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montevideo</u>	Work O	 1051859
---------------------------	--------	--

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received:    /    /    _____
Method of Delivery: Client Drop-Off    ESL Courier    Other: _____	Received on Ice?    YES    NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of:    FECAL    TC/EC    TC MPN    EC MPN    TC/EC MPN <input checked="" type="checkbox"/> N/A	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JND</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES    NO
Date/Time Received: <u>5/20/17 15:00</u>	Date Sampled: <u>5/20/17</u>
Method of Delivery:    FedEx    UPS    Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>25</u> °C	IR Gun ID: <u>43</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA    NY    OH    WV    Other: _____	PWSID Compliance Drinking Water Samples:    YES <input checked="" type="checkbox"/> NO

### PART C: Receipt Details    Completed (if different from above): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Sample Receipt Criteria		Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/> YES    NO				Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/> YES    NO				Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/> YES    NO				Circle Applicable:    Damaged Container    Leaking Container Custody Seal Broken    Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/> YES    NO				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/> YES    NO				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/> YES    NO				Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/> YES    NO				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/> YES    NO				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/> YES    NO				For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/> YES    NO				Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="checkbox"/> YES <input checked="" type="checkbox"/> NO				Sample IDs and Containers Affected:
Other Comments:					Deficiency Log Created:  YES <input checked="" type="checkbox"/> NO

Effective Date:

GP.25.A-1 Sample Receipt Log