

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for April 2023

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER
 DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST

ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

FACILITY: MONTEAU JR SR HIGH SCHOOL

LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220

STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	04	01	2023	04	30

Reporting Frequency: Monthly
 DMR Effective From: 04/01/2023
 DMR Effective To: 04/30/2023
 Permit Expires: 01/31/2028
 Permit Application Due: 08/04/2027
 No Discharge:

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	PERMIT REQUIREMENT	VALUE	UNITS	PERMIT REQUIREMENT		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	6.17	mg/L	***	4.0	mg/L	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***			4.0	mg/L	***	Daily when Discharging	Grab
	SAMPLE MEASUREMENT	7.09	mg/L	***	6.0	mg/L	***	Daily when Discharging	Grab
pH (00400)	PERMIT REQUIREMENT	***			Daily Min	S.U.	9.0	Daily when Discharging	Grab
	SAMPLE MEASUREMENT	***			***		Daily Max		
	SAMPLE MEASUREMENT	***			<5.0	mg/L	<5.0	2/month	Grab
Total Suspended Solids (00530)	PERMIT REQUIREMENT	***			30.0	mg/L	60.0	2/month	Grab
	SAMPLE MEASUREMENT	***			Avg Mo		MAX		
	SAMPLE MEASUREMENT	***			<.165	mg/L	***	2/month	Grab
Ammonia-Nitrogen (00610)	PERMIT REQUIREMENT	***			Monitor & Report		***	2/month	Grab
	SAMPLE MEASUREMENT	***			Avg Mo		***		
	SAMPLE MEASUREMENT	***			6.87	mg/L	***	Daily when Discharging	Grab
Ultraviolet light intensity (49607)	PERMIT REQUIREMENT	***			Monitor & Report		***	Daily when Discharging	Grab
	SAMPLE MEASUREMENT	***			Avg Mo		***		
	SAMPLE MEASUREMENT	.003623	uv/cm ²	***	***		***	1/week	Measured
Flow (50050)	PERMIT REQUIREMENT	***			Monitor & Report		***	1/week	Measured
	SAMPLE MEASUREMENT	***			Avg Mo		***	2/month	Grab
	SAMPLE MEASUREMENT	***			<1.0	MGD	<1.0	2/month	Grab
Fecal Coliform (74055)	PERMIT REQUIREMENT	***			2000	No./100 ml	10000	2/month	Grab
	SAMPLE MEASUREMENT	***			Geo Mean		MAX		
	SAMPLE MEASUREMENT	***			***		***	2/month	Grab

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER
 DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	PERMIT REQUIREMENT	VALUE	UNITS	PERMIT REQUIREMENT		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	<2.0	<2.0	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	25.0 Avg Mo	50.0 IMAX	2/month	Grab
Facility Comments									

COMMENT DETAILS		OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
COMMENTS				



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>

Fri, May 12, 2023 at 11:08 AM

To: jcampbell@moniteau.org, mcafoose92@hotmail.com

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 04/01/2023-04/30/2023

Report Due Date: 05/28/2023

Submitted By: Jeffrey Campbell

Submission Id: 393172

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: April 2023

Flow	$97,884 \div 30 = 3,262.8 : 3,263$ Daily Avg		
UV Light	$130.6 \div 19 = 6.87 : 6.87$ Daily Avg		
		Basin #	Date
PH Low	7.09	1	4/20
PH High	8.59	2	4/4
D. O. Low	6.17	1	4/25
D. O. High	10.86	2	4/10

Date:	4/6	4/20	Sub	$\div 2$	TOTAL
Total Nitrogen	33.2	3.39	36.59	18.295	18.30
TSS	<5	<5	—	—	<5
TKN	4.74	<0.625	5.365	2.6825	2.6
Nitrate/Nitrate	28.4	3.39	31.79	15.895	15.90
Phos	3.6	0.52	4.12	2.06	2.06
CBOD	<2.00	<2.00	—	—	<2.00
Fecal	<1	<1	—	—	<1
Ammonia	<0.165	<0.165	—	—	<0.165



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D0625
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23D0625-01	Waste Water	04/06/2023 09:30	4/6/23 13:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- ML Matrix Spike recovery fell below the laboratory acceptance criteria; result may be biased low.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/24/2023 16:57

Lab Sample ID#: 23D0625-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 04/06/2023 09:30
 Receipt Date: 04/06/2023 13:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	33.2	mg/L			1.66	DAA	04/17/23 12:40	04/17/23 17:50	
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.165	mg/L		0.165	0.400	TLL	04/18/23 08:13	04/18/23 08:13	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	4.74	mg/L	ML		0.625	DAA	04/17/23 09:00	04/17/23 17:50	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	<5	mg/L			5	APC	04/13/23 07:45	04/13/23 17:20	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	28.4	mg/L			1.04	AW	04/17/23 12:40	04/17/23 12:40	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem			
Phosphorus	3.6	mg/L			0.50	AW	04/14/23 13:10	04/14/23 13:10	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS		2.00	ATJ	04/07/23 13:51	04/12/23 09:23	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	DAA	04/06/23 13:45	04/07/23 11:32	



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work	 23D0625	
-------------------------	------	-------------	--

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD 100388</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>4/6/13 1540</u>	Date Sampled: <u>4/6/13</u>
Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____	
Sample Receipt Temperature: <u>4.0</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details

Completed (if different from above): _____

Signature _____

Date / /

Time _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO	Comments:
COC form is properly signed in relinquished/received sections?	YES NO	Comments:
Sample containers intact and sealed?	YES NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES NO	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES NO

Effective Date:

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

04 May 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23D2127
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23D2127-01	Waste Water	04/20/2023 11:00	4/20/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 05/04/2023 15:14

Lab Sample ID#: 23D2127-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 04/20/2023 11:00
 Receipt Date: 04/20/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	3.39	mg/L			1.14	DAA	05/01/23 06:40	05/01/23 13:55	
General Chemistry	Analytical Method: ASTM6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.165	mg/L		0.165	0.400	TLL	05/03/23 21:54	05/03/23 21:54	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	DAA	05/01/23 06:40	05/01/23 13:55	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	<5	mg/L			5	AH	04/27/23 13:52	04/27/23 13:52	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	3.39	mg/L			0.520	AW	04/26/23 11:06	04/26/23 11:06	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem			
Phosphorus	0.52	mg/L			0.10	AW	04/27/23 12:10	04/27/23 12:10	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS		2.00	MGF	04/20/23 18:51	04/25/23 15:33	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	AMB	04/20/23 14:59	04/21/23 11:08	

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street



23D2127

FOR INTERNAL LAI

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite Date on/off	Grab Date				
Effluent Outfall 001	73027		4/20/23	WW	1	Poly 1000mL None	CBOD, TSS
			1100	WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
				WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
				WW	1	Poly 1000mL None	Ames

Project Notes:

- THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Wastewater

Company Name: **MONTEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061**

Phone / Cell: **724-406-4426**

Email: **jcampbell@montiteau.org**

Received By: (Signature) *[Signature]* Date/ Time **4/20/23 11:00**

Relinquished By: (Signature) *[Signature]* Date/ Time **4/20/23 11:00**

Received By: (Signature) *[Signature]* Date/ Time **4/20/23 11:50 AM**

Relinquished By: (Signature) *[Signature]* Date/ Time **4/20/23 11:50**

Received By: (Signature) *[Signature]* Date/ Time **4/20/23 11:50**

Relinquished By: (Signature) *[Signature]* Date/ Time **4/20/23 11:50**

Correct Preservations **Y / N / NA** Correct Containers: **Y / N / NA** Receipt Temperature _____



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Mon'teau</u>	Work 23D2127
-------------------------	--

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	
Sample Receipt Temperature: _____ °C	Received on Ice? YES NO
IR Gun ID: _____	
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JDS 100380</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>4/20/13 1430</u>	Date Sampled: <u>4/20/13</u>
Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES	NO		Comments:
COC form is properly signed in relinquished/received sections?	YES	NO		Comments:
Sample containers intact and sealed?	YES	NO		Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES	NO		Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES	NO		Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES	NO		Sample IDs and Containers Affected:
Samples received within holding time?	YES	NO		Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES	NO		Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO		For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO		Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	NO		Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES NO

Effective Date: _____

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for April 2023

MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
MONTTEAU HIGH SCHOOL WATER TREATMENT PLANT												
April	2023											
1	SAT											
2	Sun											
3	Mon	60.0	11.42	7,755,210	0.69	0.77	7.1	0.00	0.0	1.15	Jeff C	2:30 PM
4	Tues	57.3	10.67	7,757,057	0.54	0.64	7.0	0.01	0.0	0.80	Jeff C	11:00 AM
5	wed	63.7	9.28	7,760,403	0.59	0.68	7.0	0.01	0.0	0.91	Jeff C	5:00 PM
6	Thurs	62.5	11.00	7,767,903	0.46	0.52	7.2	0.01	0.0	1.00	Jeff C	5:00 PM
7	Fri	61.3	10.69	7,767,903	0.46	0.52	7.2	0.01	0.0	1.02	Jeff C	11:00 AM
8	SAT											
9	Sun											
10	Mon	59.5	8.46	7,767,903	0.46	0.52	7.1	0.00	0.0	1.01	Jeff C	5:30 PM
11	Tues	61.7	11.56	7,781,136	0.55	0.62	7.1	0.02	0.0	1.13	Jeff C	4:30 PM
12	wed	61.5	10.75	7,781,136	0.55	0.62	7.1	0.02	0.0	1.15	Jeff C	9:00 AM
13	Thurs	65.0	8.52	7,781,136	0.53	0.56	7.1	0.01	0.0	1.13	Jeff C	11:00 AM
14	Fri	67.8	9.23	7,791,280	0.55	0.63	7.1	0.01	0.0	1.26	Jeff C	7:30 AM
15	SAT											
16	Sun											
17	Mon	65.0	10.92	7,804,094	0.68	0.72	7.1	0.03	0.0	1.77	Jeff C	11:30 AM
18	Tues	63.7	8.91	7,804,094	0.69	0.73	7.1	0.01	0.0	1.75	Jeff C	1:00 PM
19	wed	59.1	10.62	7,814,687	0.75	0.81	7.0	0.00	0.0	1.15	Jeff C	1:00 PM
20	Thurs	59.2	9.71	7,814,687	0.75	0.81	7.0	0.00	0.0	1.12	Jeff C	9:00 AM
21	Fri	61.4	8.14	7,815,087	0.72	0.77	7.0	0.00	0.0	1.10	Jeff C	9:00 AM
22	SAT											
23	Sun											
24	Mon	59.5	8.39	7,828,669	0.69	0.73	7.2	0.01	0.0	1.60	Jeff C	9:00 AM
25	Tues	58.0	11.43	7,840,513	0.69	0.74	7.2	0.02	0.0	0.78	Jeff C	8:30 AM
26	wed	58.3	8.45	7,840,513	0.69	0.74	7.2	0.01	0.0	0.79	Jeff C	9:00 AM
27	Thurs	59.2	8.81	7,842,580	0.69	0.74	7.2	0.01	0.0	0.79	Jeff C	9:00 AM
28	Fri	61.4	11.81	7,853,094	0.72	0.75	7.1	0.00	0.0	1.01	Jeff C	8:00 AM
29	SAT											
30	Sun											
31												

Water Samples

Sewage Samples

Meter Reading on 3/31/23
7,731,987

*

*



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

13 April 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23D0717
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23D0717-01	Drinking Water	04/06/2023 11:40	4/6/23 13:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/13/2023 12:32

Lab Sample ID#: 23D0717-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 04/06/2023 11:40
Receipt Date: 04/06/2023 13:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.520	mg/L			Client	04/06/23 11:40	04/06/23 11:40
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	04/06/23 14:19	04/07/23 16:50
E. Coli	Absent	per 100 mL		1	DAA	04/06/23 14:19	04/07/23 16:50

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23D0717	Sample Type	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
CIRCLE ONE: 704: KITCHEN MAIN SINK (802 ROOM 204-SINK)	01	Date 4-6-23	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.52
Sample Grab	Time					
	1:40					



704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)	Date/ Time 4-6-23 1140	Company/Name:	MONITEAU SCHOOL DISTRICT
Relinquished By: (Signature)	Date/ Time 4-6-23 1355	Address:	1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061
Relinquished By: (Signature)	Date/ Time	Contact Person:	JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Phone Number:	724-406-4426
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Cell Phone:	724-406-4426
		Email Address:	jcampbell@moniteau.org
		Billing Address:	
		PWSID:	5100324
Received By: (Signature)	Date/ Time	Receipt Temperature	
Received By: (Signature)	Date/ Time		
Received By: (Signature)	Date/ Time		



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONTEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.52	040623	802		040623	D	1140	32382	23D0717-01	BROWNKA_79
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1140	32382	23D0717-01	BROWNKA_80



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 April 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23D1402
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23D1402-01	Drinking Water	04/13/2023 11:30	4/13/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/17/2023 13:14

Lab Sample ID#: 23D1402-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 04/13/2023 11:30
Receipt Date: 04/13/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.600	mg/L		0.200	PS	04/13/23 11:30	04/13/23 11:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

THWEST DIVISION
Main Street
Xsville, PA 16
463-TEST
(724) 465-4209

FOR INTERNAL USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 704	232102	4/13/03	1130	DW	Field	Field	Free Chlorine 0.60 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

Notes/Special Instructions: **Drinking Water Moniteau Jr/Sr - Weekly**

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**



Billing Address: **5100324**

PWSID: **5100324**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) 	Date/ Time	Received By: (Signature) 	Date/ Time
4-13-03 1130	4-15-03 1530	03	0330
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature _____



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.6	041323	704		041323	D	1130	32382	23D1402-01	BROWNK_A_632
5100324	1013	FREE CHLORINE	301	0.52	040623	802		040623	D	1140	32382	23D0717-01	BROWNK_A_79
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1140	32382	23D0717-01	BROWNK_A_80



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D2151
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23D2151-01	Drinking Water	04/20/2023 11:30	4/20/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/21/2023 14:04

Lab Sample ID#: 23D2151-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 04/20/2023 11:30
Receipt Date: 04/20/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.700	mg/L		0.200	PS	04/20/23 11:30	04/20/23 11:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVI
950 Main Street
Sharpshville, PA 16
(724) 463-TEST
FAX: (724) 465-4211

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>23D2151</u>	<u>4/20/23</u>	<u>11:30</u>	DW	Field	Field	Free Chlorine <u>0.70</u> mg/L
<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: 0 auto;"> <p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							
<p>Notes/Special Instructions: <u>Drinking Water Moniteau Jr/Sr - Weekly</u></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) <u>[Signature]</u>		Date/ Time <u>4/20/23 11:30</u>		Company Name: MONITEAU SCHOOL DISTRICT		Address: 391 HOOKER ROAD	
Relinquished By: (Signature) <u>[Signature]</u>		Date/ Time <u>4/20/23 11:30</u>		Contact Person: JEFFREY CAMPBELL		Phone Number: 724-406-4426	
Relinquished By: (Signature) _____		Date/ Time _____		Cell Phone: 724-406-4426		Email Address: jcampbell@moniteau.org	
Relinquished By: (Signature) _____		Date/ Time _____		Billing Address: _____		PWSID: 5100324	
Correct Preservations Y / N (NA)		Correct Containers Y / N (NA)		Receipt Temperature <u> </u>		_____	



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.6	041323	704		041323	D	1130	32382	23D1402-01	BROWNKKA_632
5100324	1013	FREE CHLORINE	301	0.52	040623	802		040623	D	1140	32382	23D0717-01	BROWNKKA_79
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1140	32382	23D0717-01	BROWNKKA_80
5100324	1013	FREE CHLORINE	301	0.7	042023	803		042023	D	1130	32382	23D2151-01	BROWNKKA_1218



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 May 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D2827
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23D2827-01	Drinking Water	04/27/2023 10:55	4/27/23 12:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 05/02/2023 13:01

Lab Sample ID#: 23D2827-0I
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 04/27/2023 10:55
Receipt Date: 04/27/2023 12:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.660	mg/L		0.200	PS	04/27/23 10:55	04/27/23 10:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-3376

FOR INTERN



SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

NORTHERN DIVISION

 23D2827

NORTHWEST DIVISION
 950 Main Street
 Sharpsville, PA 16
 (724) 463-TEST
 FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 804	2552827	4/27/03	10:55	DW	Field	Field	Free Chlorine 0.66 mg/L
<div style="border: 1px solid black; padding: 5px;"> <p style="text-align: center;">ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall-RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p style="text-align: center;"><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>							
<p>Sampled By: (Signature)  Date/ Time 4-27-03 05:00</p>				<p>Received By: (Signature)  Date/ Time 4/27/03 12:55</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>			
<p>Company Name: MONITEAU SCHOOL DISTRICT</p>				<p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p>			
<p>Phone Number: 724-406-4426</p>				<p>Cell Phone: icampbell@moniteau.org</p>			
<p>Billing Address: 5100324</p>				<p>PWSID: 5100324</p>			

Department of Environmental Protection

E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.6	041323	704		041323	D	1130	32382	23D1402-01	BROWNKA_632
5100324	1013	FREE CHLORINE	301	0.52	040623	802		040623	D	1140	32382	23D0717-01	BROWNKA_79
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1140	32382	23D0717-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	0.7	042023	803		042023	D	1130	32382	23D2151-01	BROWNKA_1218
5100324	1013	FREE CHLORINE	301	0.66	042723	804		042723	D	1055	32382	23D2827-01	BROWNKA_2072

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for April 2023

Dassa McKinney Elementary School Water Treatment Facility

Month	April	2023	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sat										
2	Sun										
3	Mon	8.7	0.02	0.67	0.75	3.25	14088100	JEFF R	4:30P	1800	
4	Tues	8.7	0.02	0.64	0.72	3.28	14091300	JEFF R	4:30P	3200	
5	Wed	8.7	0.04	0.45	0.52	2.17	14095000	JEFF R	4:30P	3700	
6	Thurs	8.7	0.04	0.55	0.63	2.35	14095300	JEFF R	4:30P	300	
7	Fri										
8	Sat										
9	Sun										
10	Mon	8.7	0.01	0.49	0.53	2.40	14095600	JEFF R	5:00P	300	
11	Tues	8.7	0.02	0.67	0.76	2.58	14099700	JEFF R	4:30P	4100	
12	Wed	8.7	0.02	0.53	0.62	2.67	14104600	JEFF R	4:30P	4900	
13	Thurs	8.7	0.02	0.63	0.73	3.15	14108600	JEFF R	4:30P	4000	
14	Fri	8.7	0.00	0.77	0.84	3.36	14112700	JEFF R	4:30P	4100	
15	Sat										
16	Sun										
17	Mon	8.7	0.02	0.76	0.86	2.37	14116900	JEFF R	4:30P	4200	
18	Tues	8.7	0.00	0.78	0.85	2.45	14121200	JEFF R	4:30P	4300	
19	Wed										
20	Thurs										
21	Fri										
22	Sat										
23	Sun										
24	Mon	8.7	0.00	0.91	1.05	2.05	14138300	JEFF R	4:30P	17100	
25	Tues	8.7	0.00	0.85	0.95	2.28	14142800	JEFF R	4:30P	4500	
26	Wed	8.7	0.01	0.70	0.78	2.86	14146800	JEFF R	4:30P	4000	
27	Thurs	8.7	0.02	0.62	0.71	3.34	14151500	JEFF R	4:30P	4700	
28	Fri										
29	Sat										
30	Sun										
31											

Meter Reading 3131/23 - 141086300



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D0716
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23D0716-01	Drinking Water	04/06/2023 11:20	4/6/23 13:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/13/2023 12:31

Lab Sample ID#: 23D0716-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 04/06/2023 11:20
Receipt Date: 04/06/2023 13:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.540	mg/L			Client	04/06/23 11:20	04/06/23 11:20
Microbiology							
	Analytical Method: SM 9223 B-16				Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	04/06/23 14:19	04/07/23 16:50
E. Coli	Absent	per 100 mL		1	DAA	04/06/23 14:19	04/07/23 16:50

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification 801 KITCHEN SINK 802 ROOM 617 SINK	ESL# 23D0716	Sample Type Date Grab Time 4:03 1:30	Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC / EC Free Chlorine 0.54 mg/L



Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE-ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) 	Date/ Time 4-6-23 11:00
Relinquished By: (Signature) 	Date/ Time 4-6-23 1:30
Received By: (Signature) 	Date/ Time 4/10/23 1:35
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Correct Preservations Y/N / NA	Correct Containers Y/N / NA
	Receipt Temperature 20.7°C

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.org**

Cell Phone: **5100316**

Email Address: **5100316**

Billing Address: **5100316**

PWSID: **5100316**



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.54	040623	802		040623	D	1120	32382	23D0716-01	BROWNIKA_77
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1120	32382	23D0716-01	BROWNIKA_78



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

05 May 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D1321
Project: Drinking Water Dassa McKinney - SOC
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101 - SOCs	23D1321-01	Drinking Water	04/13/2023 10:55	4/13/23 13:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

SOCs subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



Results Report

Order ID: 3D04058

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: Moniteau School District

Attn: Accounts Payable

Sample Number: 3D04058-01 Site: EP 101 Sample ID: 23D1321-01
Collector: CLIENT Collect Date: 04/13/2023 10:55 am Sample Type: E
Sample Regulatory ID: 5100316 SDWA Reporting IDs: (101 / R / E)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Dioxins and Furans by Isotope Dilution HRGC/HRMS

EPA1613B

2,3,7,8-TCDD < 10 pg/L EPA1613B 10 1 04/21/23 04/29/23 15:36 SUB*

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 1,2,3,4-TCDD-13C	11000	pg/L	EPA1613B	527%	1	0.0-0.0	04/29/23 15:36
Surrogate: 2,3,7,8-TCDD-13C	750	pg/L	EPA1613B	37%	1	31.0-137.0	04/29/23 15:36
Surrogate: 2,3,7,8-TCDD-37Cl4	120	pg/L	EPA1613B	58%	1	42.0-164.0	04/29/23 15:36

Semivolatiles

SOC 504.1, Analysis

1,2-Dibromoethane (EDB) < 0.0197 µg/L EPA 504.1 0.0197 1 04/17/23 MAG 04/18/23 4:40 MAG
1,2-Dibromo-3-chloropropane (DBCP) < 0.0197 µg/L EPA 504.1 0.0197 1 04/17/23 MAG 04/18/23 4:40 MAG

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 1,1,1,2-Tetrachloroethane	0.2366	µg/L	EPA 504.1	96%	1	70-130	04/18/23 4:40

SOC 505

PCBs (as Aroclors) < 0.1977 µg/L EPA 505 0.1977 1 04/19/23 MAG 04/20/23 12:01 MAG
Toxaphene < 1.977 µg/L EPA 505 1.977 1 04/19/23 MAG 04/20/23 12:01 MAG

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Tetrachloro-m-xylene	1.038	µg/L	EPA 505	105%	1	70-130	04/20/23 12:01

SOC 515.3

Dalapon < 1.25 µg/L EPA 515.3 1.25 1 04/20/23 AMAA 04/21/23 20:00 MWS
2,4-D < 1.25 µg/L EPA 515.3 1.25 1 04/20/23 AMAA 04/21/23 20:00 MWS
Pentachlorophenol < 0.12 µg/L EPA 515.3 0.12 1 04/20/23 AMAA 04/21/23 20:00 MWS
2,4,5-TP (Silvex) < 0.31 µg/L EPA 515.3 0.31 1 04/20/23 AMAA 04/21/23 20:00 MWS
Picloram < 1.25 µg/L EPA 515.3 1.25 1 04/20/23 AMAA 04/21/23 20:00 MWS
Dinoseb < 1.25 µg/L EPA 515.3 1.25 1 04/20/23 AMAA 04/21/23 20:00 MWS

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 2,4-Dichlorophenylacetic Acid (DCAA)	22.9	µg/L	EPA 515.3	92%	1	70-130	04/21/23 20:00

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



PA DEP # 06-00208
NJDEP# PA081

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



PA DEP # 06-00208
NJDEP# PA081

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



SUBURBAN TESTING LABS

The test *pH_i Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH_i Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



PA DEP # 06-00208
NJDEP# PA081

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



SUBURBAN TESTING LABS

The test *pH_i Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH_i Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



PA DEP # 06-00208
NJDEP# PA081

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com

PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04058-01	Site: EP 101	Sample ID: 23D1321-01
Collector: CLIENT	Collect Date: 04/13/2023 10:55 am	Sample Type: E
Sample Regulatory ID: 5100316	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 525.2									
Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/21/23	NDK	04/21/23 15:56	DWL
Atrazine	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) adipate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
di(2-Ethylhexyl) phthalate	< 1.46	µg/L	EPA 525.2	1.46	1	04/21/23	NDK	04/21/23 15:56	DWL
Endrin	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/21/23	NDK	04/21/23 15:56	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorobenzene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Hexachlorocyclopentadiene	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Methoxychlor	< 0.24	µg/L	EPA 525.2	0.24	1	04/21/23	NDK	04/21/23 15:56	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/21/23	NDK	04/21/23 15:56	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.66	µg/L	EPA 525.2	96%	1	50-150	04/21/23 15:56
Surrogate: Triphenylphosphate	5.08	µg/L	EPA 525.2	105%	1	50-150	04/21/23 15:56
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	4.44	µg/L	EPA 525.2	91%	1	50-150	04/21/23 15:56
Surrogate: Perylene-d12	4.33	µg/L	EPA 525.2	89%	1	50-150	04/21/23 15:56

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
SOC 531.2									
Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 0:36	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	55.0	µg/L	EPA 531.2	110%	1	70-130	04/28/23 0:36

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 15:42	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 0:47	ENB

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID 68-00563

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS



PA DEP # 06-00208
NJDEP# PA081

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/04/2023 2:57 pm 3D04058
STL_Results Revision #2.1 Effective: 09/01/2022





3D04058
Lauren Ulle

UBCONTRACT ORDER

Environmental Service Laboratories, Inc.

23D1321

ports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Kirsten Conoran

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Client: Moniteau School District

PWSID: 5100316

Analysis	Due	Expires	Comments
----------	-----	---------	----------

Sample ID: 23D1321-01 Sample Name: Entry Point 101 - SOCs

Matrix: Drinking Water Sampled: 04/13/2023 10:55 Sample Type: Grab Sampled By: Paul Somogyi

SOC 1613 2,3,7,8 TCDD Dioxin	04/25/2023 23:00	04/12/2024 10:55	
SOC 504	04/25/2023 23:00	04/27/2023 10:55	
SOC 505	04/25/2023 23:00	04/27/2023 10:55	
SOC 515	04/25/2023 23:00	04/27/2023 10:55	
SOC 525 Pesticides	04/25/2023 23:00	04/27/2023 10:55	
SOC 531.1	04/25/2023 23:00	05/11/2023 10:55	
SOC 547 Glyphosate	04/25/2023 23:00	04/27/2023 10:55	
SOC 548.1 Endothall	04/25/2023 23:00	04/20/2023 10:55	
SOC 549 Diquat	04/25/2023 23:00	04/20/2023 10:55	

Containers Supplied:

Amber Glass, 1000mL, Na2S2O3 (A)	Amber Glass, 1000mL, Na2S2O3 (B)	VOA Vial, 40mL, Na2S2O3 (C)	VOA Vial, 40mL, Na2S2O3 (D)	VOA Vial, 40mL, Na2S2O3 (E)
VOA Vial, 40mL, Na2S2O3 (F)	VOA Vial, 40mL, Na2S2O3 (G)	VOA Vial, 40mL, Na2S2O3 (H)	Amber Glass, 500mL, Na2S2O3 (I)	Amber Glass, 1000mL, Na2SO3 and HCL (J)
Amber Glass, 1000mL, Na2SO3 and HCL (K)	Amber Glass, 250mL, Na2S2O3 & C6H7KO7 (L)	Amber Glass, 250mL, Na2S2O3 (M)	Amber HDPE, 1000mL, Na2S2O3 & H2SO4 (N)	

Suburban Testing Labs

Lab Date/Time: 4-14-23 1825 Lab Temp: 18.5°C

Number of containers/coolers match number on COC?
Sample labels and COC are free of discrepancies.
All containers intact?
Received in lab within acceptable temperature limits?
40 mL VOA vials free of headspace?

Relinquished by: [Signature]

Received in lab by: CTB 4-14-23 1825
[Signature]

Released By: [Signature] Date: 4/13/23

Received By: [Signature] Date: 04/14/23

Released By: [Signature] Date: 04/14/23

Received By: [Signature] Date: 4-14-23





3D04058
Lauren Ullie

UBCONTRACT ORDER

Environmental Service Laboratories, Inc.

23D1321

orders@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Kirsten Conoran

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Client: Moniteau School District

PWSID: 5100316

Analysis	Due	Expires	Comments
----------	-----	---------	----------

Sample ID: 23D1321-01 Sample Name: Entry Point 101 - SOC's

Matrix: Drinking Water Sampled: 04/13/2023 10:55 Sample Type: Grab Sampled By: Paul Somogyi

SOC 1613 2,3,7,8 TCDD Dioxin	04/25/2023 23:00	04/12/2024 10:55	
SOC 504	04/25/2023 23:00	04/27/2023 10:55	
SOC 505	04/25/2023 23:00	04/27/2023 10:55	
SOC 515	04/25/2023 23:00	04/27/2023 10:55	
SOC 525 Pesticides	04/25/2023 23:00	04/27/2023 10:55	
SOC 531.1	04/25/2023 23:00	04/27/2023 10:55	
SOC 547 Glyphosate	04/25/2023 23:00	05/11/2023 10:55	
SOC 548.1 Endothal	04/25/2023 23:00	04/27/2023 10:55	
SOC 549 Diquat	04/25/2023 23:00	04/20/2023 10:55	
	04/25/2023 23:00	04/20/2023 10:55	

Containers Supplied:

Amber Glass, 1000mL, Na2S2O3 (A)	Amber Glass, 1000mL, Na2S2O3 (B)	VOA Vial, 40mL, Na2S2O3 (C)	VOA Vial, 40mL, Na2S2O3 (D)	VOA Vial, 40mL, Na2S2O3 (E)
VOA Vial, 40mL, Na2S2O3 (F)	VOA Vial, 40mL, Na2S2O3 (G)	VOA Vial, 40mL, Na2S2O3 (H)	Amber Glass, 500mL, Na2S2O3 (I)	Amber Glass, 1000mL, Na2SO3 and HCL (J)
Amber Glass, 1000mL, Na2SO3 and HCL (K)	Amber Glass, 250mL, Na2S2O3 & C6H7KO7 (L)	Amber Glass, 250mL, Na2S2O3 (M)	Amber HDPE, 1000mL, Na2S2O3 & H2SO4 (N)	

Suburban Testing Labs

Lab Date/Time: 4-14-23 1822 Lab Temp: 18.5°C

Number of containers/coolers match number on COC?
Sample labels and COC are free of discrepancies.
All containers intact?
Received in lab within acceptable temperature limits?
40 mL VOA vials free of headspace?

Relinquished by: *[Signature]*
Received in lab by: CTB 4-14-23 1825
[Signature]

Released By: *[Signature]* Date: 4/13/23

Received By: *[Signature]* Date: 04/14/23 0630

Released By: *[Signature]* Date: 04/14/23 0845

Received By: *[Signature]* Date: 4-14-23 0855





SUBURBAN
TESTING LABS

Login Container Record



Work Order ID: 3D04058

Client: Environmental Service Laboratories, Inc.
Project: SDWA SOCs

Project Manager: Lauren Ullie
SDG ID:

Preservation Confirmation

3D04058-01 EP 101	<input checked="" type="checkbox"/>	A - 1L GA & Na2S2O3
	<input checked="" type="checkbox"/>	B - 1L GA & Na2S2O3
	<input type="checkbox"/>	C - 40ml VOA & Na2S2O3
	<input type="checkbox"/>	D - 40ml VOA & Na2S2O3
	<input type="checkbox"/>	E - 40ml VOA & Na2S2O3
	<input type="checkbox"/>	F - Trip Blank
	<input type="checkbox"/>	G - 40ml VOA & Na2S2O3
	<input type="checkbox"/>	H - 40ml VOA & Na2S2O3
	<input type="checkbox"/>	I - 40ml VOA & Na2S2O3
	<input checked="" type="checkbox"/>	J - 500mL GA & Na2S2O3
	<input type="checkbox"/>	K - 1L GA & Sodium Sulfite & HCl at sampling
<input type="checkbox"/>	L - 1L GA & Sodium Sulfite & HCl at sampling	
<input checked="" type="checkbox"/>	M - 250mL GA & Na2S2O3 & C6H7K	
<input checked="" type="checkbox"/>	N - 250mL GA & Na2S2O3	
<input type="checkbox"/>	O - 1L PVC Amber & Na2S2O3 & H2SO4 at	

*PH 5-9 total 21MS
O PH < 2 total 21MS
Δ PH 3-10 total 21MS

Sample Conditions

Number of Containers/Cooler
Sealed matches number on COC? Y/N

All Containers Intact? Y/N

Sample labels and COC free of
discrepancies? Y/N

Y/N

VOC vials for VOA analysis free
of headspace, if applicable? Y/N

Y/N


File Not Found: Work\23D\23D1321_COC_02.pdf

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTH
435 Bro
Monroeville
(570) 32
FAX: (5



T DIVISION
Tel: A 16150
3T
35-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Sample Identification	ESL#	Composite		Date	Grab	Matrix	# of Containers	Container Type	Analysis Requested				
		Date on/off	Time on/off										
Entry Point 101	23D1321	[X]		4/13/03	1055	DW	3	40 ml CLEAR VIAL Na2S2O3	SOC 504				
		DW	3			40 ml CLEAR VIAL Na2S2O3	SOC 505						
		DW	2			AMBER GLASS Na2S2O3	SOC 515 / SOC 548						
		DW	2			AMBER GLASS Sodium Sulfite/HCL	SOC 525						
		DW	1			250 ML AMBER GLASS Na2S2O3, C6H7KO7	SOC 531.1						
		DW	1			250 ML AMBER GLASS Na2S2O3	SOC 547						
		DW	1			1 L HDPE AMBER Na2S2O3 & H2SO4	SOC 549						
		DW	2			AMBER GLASS Na2S2O3	SOC 1613						
		<p>Project Notes: <i>Drinking Water Dassa McKinney - SOC</i></p>											
		<p>Company/Name: MONTEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: [blank] Email Address: jcampbell@monteau.org Billing Address: [blank] PWSID: 5100316</p>											

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 4/13/03 1055
 Relinquished By: (Signature) *[Signature]* Date/ Time 4/13/03 1334

Received By: (Signature) *[Signature]* Date/ Time 4/13/03 1340
 Relinquished By: (Signature) *[Signature]* Date/ Time 4/13/03 0230

Received By: (Signature) *[Signature]* Date/ Time [blank]
 Relinquished By: (Signature) *[Signature]* Date/ Time [blank]



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D1403
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23D1403-01	Drinking Water	04/13/2023 10:45	4/13/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/17/2023 13:15

Lab Sample ID#: 23D1403-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 04/13/2023 10:45
Receipt Date: 04/13/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.410	mg/L		0.200	PS	04/13/23 10:45	04/13/23 10:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE ONLY

ST DIVISION
eel
PA 16
ST
665-4209



23D1403

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL# 23D1403	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: <u>S&S</u>	<u>CA</u>	Date <u>4-15-03</u>	DW	Field	Field	Free Chlorine <u>0.4</u> mg/L
<p style="text-align: center;">ROTATION</p> <p>Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink</p>						
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
<p>Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly</p>						
<p>Company/Name: MONTEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD</p> <p>WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address: 5100316</p> <p>PWSID: 5100316</p>						
Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>4-15-03</u>	<u>1048</u>	Received By: (Signature)	<u>[Signature]</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>4-15-03</u>	<u>1330</u>	Received By: (Signature)	<u>[Signature]</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>4-15-03</u>	<u>1330</u>	Received By: (Signature)	<u>[Signature]</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>4-15-03</u>	<u>1330</u>	Received By: (Signature)	<u>[Signature]</u>
Correct Preservations Y/N/NA	Y/N/NA	Correct Containers Y/N/NA	Y/N/NA	Receipt Temperature		



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.41	041323	801		041323	D	1045	32382	23D1403-01	BROWNKA_631
5100316	1013	FREE CHLORINE	301	0.54	040623	802		040623	D	1120	32382	23D0716-01	BROWNKA_77
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1120	32382	23D0716-01	BROWNKA_78



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

21 April 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23D2152
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23D2152-01	Drinking Water	04/20/2023 11:15	4/20/23 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/21/2023 14:04

Lah Sample ID#: 23D2152-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 04/20/2023 11:15
Receipt Date: 04/20/2023 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.790	mg/L		0.200	PS	04/20/23 11:15	04/20/23 11:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DI
950 Main Street
Sharpsville, PA 1
(724) 463-TEST
FAX: (724) 465-



23D2152

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 803	7302152	4/20/23	11:5	DW	Field	Field	Free Chlorine 0.79 mg/L

ROTATION
 Wk 1 - 801 Kitchen Sink
 Wk 2 - 802 Room 617 Sink
 Wk 3 - 803 Room 606 Sink
 Wk 4 - 804 Room 408 Sink
 Wk 5 - 802 Room 617 Sink

Notes/Special Instructions:
 Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426
jcampbell@moniteau.org**

Phone Number: **5100316**

Cell Phone: **5100316**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) *[Signature]* Date/Time **4/20/23 11:5**

Relinquished By: (Signature) *[Signature]* Date/Time **4/20/23 11:5**

Relinquished By: (Signature) *[Signature]* Date/Time **4/20/23 11:5**

Relinquished By: (Signature) *[Signature]* Date/Time **4/20/23 11:5**

Correct Preservations Y/N/TNA **Y/N/TNA** Correct Containers Y/N/NA **Y/N/NA** Receipt Temperature



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.41	041323	801		041323	D	1045	32382	23D1403-01	BROWNKA_631
5100316	1013	FREE CHLORINE	301	0.54	040623	802		040623	D	1120	32382	23D0716-01	BROWNKA_77
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1120	32382	23D0716-01	BROWNKA_78
5100316	1013	FREE CHLORINE	301	0.79	042023	803		042023	D	1115	32382	23D2152-01	BROWNKA_1217



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 May 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D2828
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23D2828-01	Drinking Water	04/27/2023 10:25	4/27/23 12:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 05/02/2023 13:01

Lab Sample ID#: 23D2828-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler:
Client Sample ID: 804 Room 408 Sink

Sample Date: 04/27/2023 10:25
Receipt Date: 04/27/2023 12:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.680	mg/L		0.200	PS	04/27/23 10:25	04/27/23 10:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

WEST DIVISION
Street
e, PA 16
-TEST
(A) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 804	2352828	Grab	DW	Field	Field	Free Chlorine 0.68 mg/L
		Date				
		Time				
		10:25				
		4/23				

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802-Room 617 Sink

Notes/Special Instructions:
Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	4-23-05 05:00		4-23-05 12:05
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Correct Preservations	Y/N / NA	Correct Containers	Y/N / NA
Company/Name:		MONITEAU SCHOOL DISTRICT	
Address:		391 HOOKER ROAD WEST SUNBURY, PA 16061	
Contact Person:		JEFFREY CAMPBELL	
Phone Number:		724-406-4426	
Cell Phone:		jcambell@moniteau.org	
Billing Address:		5100316	
PWSID:			

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Department of Environmental Protection

E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.41	041323	801		041323	D	1045	32382	23D1403-01	BROWNIKA_631
5100316	1013	FREE CHLORINE	301	0.54	040623	802		040623	D	1120	32382	23D0716-01	BROWNIKA_77
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040723	802		040623	D	1120	32382	23D0716-01	BROWNIKA_78
5100316	1013	FREE CHLORINE	301	0.79	042023	803		042023	D	1115	32382	23D2152-01	BROWNIKA_1217
5100316	1013	FREE CHLORINE	301	0.68	042723	804		042723	D	1025	32382	23D2828-01	BROWNIKA_2073