

Moniteau School District
Dassa McKinney
Elementary School
Water Treatment Facility
Monthly Operations and
Testing Report for February
2020



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

28 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0022155
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0022155-01	Drinking Water	02/27/2020 12:30	2/27/20 14:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/28/2020 09:39

Lab Sample ID#: 0022155-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 02/27/2020 12:30
Receipt Date: 02/27/2020 14:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.07	mg/L		0.200	PFS	02/27/20 12:30	02/27/20 12:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
Main Street
Pottsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>504</u>	<u>0022155</u>	<u>20720</u>	<u>1230</u>	DW	Field	Field	Free Chlorine <u>1.07</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>20720 1230</u>		Received By: (Signature) <u>[Signature]</u> Date/ Time <u>20720 14:55</u>		Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly			
Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>20720 1445</u>		Received By: (Signature) _____ Date/ Time _____		Company/Name: MONITEAU SCHOOL DISTRICT			
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____		Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061			
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____		Contact Person: JEFFREY CAMPBELL Phone Number: 724 406-4426			
Correct Preservations Y / N (NA)		Correct Containers Y / N (NA)		Email Address: jcampbell@moniteau.k12.pa.us Billing Address: _____ PWSID: 5100316			

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00103	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_853
5100316	2451	DICHLOROACETIC ACID	206	0.00327	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_856
5100316	2452	TRICHLOROACETIC ACID	206	0.00156	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_857
5100316	2453	MONOBROMOACETIC ACID	206	0.0	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_859
5100316	2454	DIBROMOACETIC ACID	206	0.0	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_861
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00586	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_864
5100316	2941	CHLOROFORM (THM)	221	0.0097	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_865
5100316	2942	BROMOFORM (THM)	221	0.0	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_867
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00464	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_869
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00158	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_871
5100316	2950	TRIALOMETHANES	221	0.0159	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_873
5100316	2450	MONOCHLOROACETIC ACID	206	0.00103	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_854
5100316	2451	DICHLOROACETIC ACID	206	0.00317	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_855
5100316	2452	TRICHLOROACETIC ACID	206	0.00162	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_858
5100316	2453	MONOBROMOACETIC ACID	206	0.0	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_860
5100316	2454	DIBROMOACETIC ACID	206	0.0	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_862
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00582	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_863
5100316	2941	CHLOROFORM (THM)	221	0.0102	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_866
5100316	2942	BROMOFORM (THM)	221	0.0	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_868

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00484	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_870
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00164	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_872
5100316	2950	TRihalOMETHANES	221	0.0166	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_874
5100316	1013	FREE CHLORINE	301	0.7	020620	801		020620	D	1245	32382	0020557-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	801		020620	D	1245	32382	0020557-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.68	021320	802		021320	D	1250	32382	0021202-01	BROWNKA_417
5100316	1013	FREE CHLORINE	301	1.07	022020	803		022020	D	1315	32382	0021653-01	BROWNKA_910
5100316	1013	FREE CHLORINE	301	1.07	022720	804		022720	D	1230	32382	0022155-01	BROWNKA_1330



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04834

24 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0021653
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0021653-01	Drinking Water	02/20/2020 13:15	2/20/20 15:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/24/2020 08:00

Lab Sample ID#: 0021653-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 02/20/2020 13:15
Receipt Date: 02/20/2020 15:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.07	mg/L		0.200	PFS	02/20/20 13:15	02/20/20 13:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benlleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(870) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 5



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0021653	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 853	01	Date: 2008 Time: 1310	DW	Field	Field	Free Chlorine 1.07 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
Sampled By: (Signature)	2008 1315	Date/ Time	Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly			
Relinquished By: (Signature)	2008 1327	Date/ Time	Company/Name: MONITEAU SCHOOL DISTRICT			
Relinquished By: (Signature)		Date/ Time	Address: 391 HOOKER ROAD			
Relinquished By: (Signature)		Date/ Time	WEST SUNBURY, PA 16061			
Relinquished By: (Signature)		Date/ Time	Contact Person: JEFFREY CAMPBELL			
Relinquished By: (Signature)		Date/ Time	Phone Number: 724-406-4426			
Relinquished By: (Signature)		Date/ Time	Cell Phone: jcampbell@moniteau.k12.pa.us			
Relinquished By: (Signature)		Date/ Time	Billing Address: 5100316			
Relinquished By: (Signature)		Date/ Time	PWSID:			

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.00103	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_853
5100316	2451	DICHLOROACETIC ACID	206	0.00327	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_856
5100316	2452	TRICHLOROACETIC ACID	206	0.00156	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_857
5100316	2453	MONOBROMOACETIC ACID	206	0.0	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_859
5100316	2454	DIBROMOACETIC ACID	206	0.0	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_861
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00586	021920	703		021020	D	0830	32382	0020703-01	BROWNKA_864
5100316	2941	CHLOROFORM (THM)	221	0.0097	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_865
5100316	2942	BROMOFORM (THM)	221	0.0	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_867
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00464	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_869
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00158	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_871
5100316	2950	TRICHLOROMETHANES	221	0.0159	021220	703		021020	D	0830	32382	0020703-01	BROWNKA_873
5100316	2450	MONOCHLOROACETIC ACID	206	0.00103	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_854
5100316	2451	DICHLOROACETIC ACID	206	0.00317	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_855
5100316	2452	TRICHLOROACETIC ACID	206	0.00162	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_858
5100316	2453	MONOBROMOACETIC ACID	206	0.0	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_860
5100316	2454	DIBROMOACETIC ACID	206	0.0	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_862
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00582	021920	704		021020	D	0815	32382	0020703-02	BROWNKA_863
5100316	2941	CHLOROFORM (THM)	221	0.0102	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_866
5100316	2942	BROMOFORM (THM)	221	0.0	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_868

E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL													
SDWA1													
PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00484	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_870
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00164	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_872
5100316	2950	TRIHALOMETHANES	221	0.0166	021220	704		021020	D	0815	32382	0020703-02	BROWNKA_874
5100316	1013	FREE CHLORINE	301	0.7	020620	801		020620	D	1245	32382	0020557-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	801		020620	D	1245	32382	0020557-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.68	021320	802		021320	D	1250	32382	0021202-01	BROWNKA_417
5100316	1013	FREE CHLORINE	301	1.07	022020	803		022020	D	1315	32382	0021653-01	BROWNKA_910



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0021202
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0021202-01	Drinking Water	02/13/2020 12:50	2/14/20 10:58	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpshville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/14/2020 14:19

Lab Sample ID#: 0021202-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 02/13/2020 12:50
Receipt Date: 02/14/2020 10:58

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.680	mg/L		0.200	PFS	02/13/20 12:50	02/13/20 12:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 483-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NOF 435
Mon (570)
FAX



VISION
6
4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>0021202</u>	<u>7/15/00</u>	<u>10:58</u>	DW	Field	Field	Free Chlorine <u>1.68</u> mg/L
	<u>01</u>						

ROTATION
 Wk 1 - 801 Kitchen Sink
 Wk 2 - 802 Room 617 Sink
 Wk 3 - 803 Room 606 Sink
 Wk 4 - 804 Room 408 Sink
 Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Sampled By: (Signature) [Signature] Date/ Time 7/15/00 1:50
 Relinquished By: (Signature) [Signature] Date/ Time 7/15/00 1:45
 Relinquished By: (Signature) [Signature] Date/ Time 2/11/02 10:58
 Relinquished By: (Signature) [Signature] Date/ Time [Signature] Date/ Time [Signature]
 Relinquished By: (Signature) [Signature] Date/ Time [Signature] Date/ Time [Signature]

Correct Preservations Y/N NA Correct Containers Y/N NA Receipt Temperature —

Company Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.k12.pa.us**
 Billing Address: **5100316**
 PWSID: **5100316**

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.7	020620	801		020620	D	1245	32382	0020557-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	801		020620	D	1245	32382	0020557-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.68	021320	802		021320	D	1250	32382	0021202-01	BROWNKA_417



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0020557
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0020557-01	Drinking Water	02/06/2020 12:45	2/6/20 14:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/11/2020 11:38

Lab Sample ID#: 0020557-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 02/06/2020 12:45
Receipt Date: 02/06/2020 14:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.700	mg/L		0.200	PFS	02/06/20 12:45	02/06/20 12:45
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	ANP	02/06/20 15:19	02/07/20 15:52
E. Coli	Absent	per 100 mL		1	ANP	02/06/20 15:19	02/07/20 15:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benileville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0020557	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	801 KITCHEN SINK					
Notes/Special Instructions: Drinking Water Dassa McKinney - Monthly						
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (16% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.						
Sampled By: (Signature)	<i>[Signature]</i>	Date/ Time	2/6/20 1455	Received By: (Signature)	<i>[Signature]</i>	Date/ Time
Relinquished By: (Signature)	<i>[Signature]</i>	Date/ Time	2/6/20 1455	Received By: (Signature)	<i>[Signature]</i>	Date/ Time
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)	<i>[Signature]</i>	Date/ Time
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)	<i>[Signature]</i>	Date/ Time
Correct Preservations	Y / N / NA	Correct Containers	Y / N / NA	Receipt Temperature	4.301 JCE	
Company Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.k12.pa.us Billing Address: PWSID: 5100316						



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.7	020620	801		020620	D	1245	32382	0020557-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	801		020620	D	1245	32382	0020557-01	BROWNKA_49

Moniteau School District
Moniteau High School
Wastewater Treatment Facility
Monthly Operations and
Testing Report for February
2020

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 02/01/2020
 DMR Effective To: 02/29/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	02	01	2020	02	29

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.42	***	1/week/day	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.50	8.48	1/week/day	Grab
	PERMIT REQUIREMENT	***		6.0 Min	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		12.97	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		2.7	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		4.49	***	1/week/day	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	003577		***	***	1/week/day	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	M/GD	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0	<1.0		2/month	Grab
	PERMIT REQUIREMENT	***		***	2000	10000	No./100 ml	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	Geo Mean	***		2/month	Grab
	PERMIT REQUIREMENT	***		***	4.45	25	mg/L	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME Jeff Campbell	OPERATOR CERTIFICATION NUMBER S12696	OPERATOR CONTACT NUMBER (724)406-4426
----------	--------------------------------	---	--

Moniteau High School
WASTEWATER TREATMENT PLANT
Monthly DMR Work Sheet for FEB 2020

Flow $103,744 \div 29 = 3,577.38$ Daily Avg.

UV $89.7 \div 20 = 4.485$ Daily Avg.

PH High 8.48 #2 BASIN 2/12/20

Low 7.51 #2 BASIN 2/7/20

D.O. High 11.69 #2 BASIN 2/28/20

Low 7.42 #2 BASIN 2/3/20

Total Nitrogen = $23.2 + 2.74 = 25.94 \div 2 = 12.97$

Total Suspended Solids = $< 5 + < 5 = < 5$

Nitrate / Nitrite = $23.2 + 2.74 = 25.94 \div 2 = 12.97$

Phosphorus = $2.4 + 3.0 = 5.4 \div 2 = 2.7$

CBOD = $5.89 + < 3.00 = 8.89 \div 2 = 4.45$

Fecal Coliforms = $< 1 + < 1 = < 1$

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Friday, March 6, 2020, 09:25 AM EST

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 02/01/2020-02/29/2020

Report Due Date: 03/28/2020

Submitted By: Jeffrey Campbell

Submission Id: 196666

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau High School Sewage Treatment Plant
Permit # PA0091341

Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month		Time	Operator
						UV	Meter Reading		
2/13	Mon.	8.07	7.95	7.65	7.47	3.5	FEB 2020	16:00	JEFF C
2/14	Tues	8.14	7.96	7.60	7.51	5.0		14:00	JEFF C
2/15	Ned	7.78	11.02	7.70	8.70	4.0		08:00	JEFF C
2/16	Thurs	7.90	8.45	7.81	8.31	5.0		11:15 A	JEFF R.
2/17	FRI	7.62	8.87	7.51	8.55	3.4		12:30 P	JEFF R.
2/18	Mon.	8.03	9.22	8.08	9.02	4.5		9:00 A	JEFF C
2/19	Tues	8.39	10.58	8.44	9.65	4.6		10:30 A	JEFF C
2/20	Wed.	8.42	10.61	8.48	9.89	4.4		9:30 A	JEFF C
2/21	Thurs	8.40	10.59	8.42	9.90	4.5		08:00 A	JEFF C
2/22	FRI	8.40	10.57	8.40	9.93	4.3		1:00 P	JEFF C
2/23	Mon.	8.19	6.87	8.04	6.13	4.3		1:15 P	JEFF C
2/24	Tues	8.16	7.41	7.90	8.64	4.5		09:00 A	JEFF C
2/25	wed	8.10	9.23	7.83	9.28	4.5		08:30 A	JEFF C
2/26	Thurs	8.01	10.55	7.77	10.29	4.5		10:30 AM	JEFF C
2/27	FRI	7.99	10.52	7.83	10.32	4.5		11:00 AM	JEFF C
2/28	Mon.	7.99	10.40	7.70	10.34	5.3		10:30 AM	JEFF C
2/29	Tues	7.98	10.38	7.69	10.35	5.0		11:00 AM	JEFF C
2/30	wed.	7.96	10.35	7.65	10.38	4.9		2:00 PM	JEFF C
2/31	Thurs	7.95	10.43	7.62	10.83	4.5		09:30 AM	JEFF C
2/32	FRI	7.9-1	10.45	7.57	11.69	4.5		08:00 AM	JEFF C
						89.7			

KB AM
Hauled 1 Load
Sludge 3500gal.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0020482
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0020482-01	Waste Water	02/06/2020 10:15	2/6/20 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Summit Environmental Technologies, Inc., PA-DEP ID 68-01335; please see attached subcontract laboratory Report of Analysis for results.

Definitions

BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/19/2020 16:14

Lab Sample ID#: 0020482-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/06/2020 10:15
Receipt Date: 02/06/2020 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	23.2	mg/L		2.60	TLL	02/18/20 16:39	02/18/20 16:39
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	02/12/20 11:48	02/12/20 13:40
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	23.2	mg/L		2.60	TLL	02/18/20 16:39	02/18/20 16:39
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	2.4	mg/L		0.40	JPD	02/15/20 13:22	02/15/20 14:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	5.89	mg/L	BB	3.00	AW	02/07/20 13:50	02/12/20 09:00
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	ANP	02/06/20 16:44	02/07/20 11:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-9376



NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



NORTHWEST DIVIS
950 Main Street
Sharpsville, PA 1811
(724) 463-TEST
FAX: (724) 465-4206



0020482

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	0020462			2/6/20	10:15 AM	WW	1 ✓	Poly 1000mL None Poly 1000mL H2SO4 Sterile Plastic 125mL Na2S2O3	CBOD, TSS Total Nitrogen, Total Phosphorus 4.3 ile (3) 1455 AM 2/6/20 ✓

Project Notes:
Wastewater

Company/Name:
MONITEAU SCHOOL DISTRICT

Contact Person:
JEFFREY CAMPBELL
1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
724-406-4426
jcampbell@moniteau.k12.pa.us

1. THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
2. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (16% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
3. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) _____ Date/ Time 2-6-20 1300
Received By: (Signature) _____ Date/ Time 2/6/20 1500
Received By: (Signature) _____ Date/ Time _____
Received By: (Signature) _____ Date/ Time _____

Correct/Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature

Jeffrey Campbell
Jeffrey Campbell
Jeffrey Campbell
Jeffrey Campbell
Jeffrey Campbell

Jeffrey Rosellini 2/6/20



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



0020482

Client: <u>Moniteau School</u>		Work Order: _____	
Received by: <u>[Signature]</u>	Date/Time Received: <u>2/6/20 1500</u>	Date Sampled: <u>2/6/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>1.9</u>	Samples Received on Ice: <u>YES</u> NO		
IR Gun # Used: 1 <u>2</u> 3 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of:	TCMPN ECMPN	Fecal Coliform TC/EC
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>		

PART B: Receipt Details

Completed (if different from above): _____ / ____ / ____
Signature Date Time

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1	Chain of custody documents included with samples?	Yes No N/A	Comments:	YES NO
2	COC form is properly signed in relinquished/received sections?	Yes No N/A	Comments:	YES NO
3	Sample containers intact and sealed?	Yes No N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other:	YES NO
4	Number of containers received match number indicated on COC?	Yes No N/A	Sample ID's affected:	YES NO
5	Sample ID's on COC match ID's on bottles?	Yes No N/A	Sample ID's and containers affected:	YES NO
6	Date and time on COC match date and time on bottles?	Yes No N/A	Sample ID's affected:	YES NO
7	Samples received within holding time?	Yes No N/A	ID's and tests affected:	YES NO
8	Samples received at appropriate pH for analysis requested?	Yes No N/A	Sample ID's, containers affected and observed pH:	YES NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes No N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES NO
11	Adequate sample volume received?	Yes No N/A	Analyses Affected:	YES NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes No <u>N/A</u>	Sample ID's and containers affected:	YES NO
Other Comments:				Deficiency Log Created: Yes <u>No</u>



Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

February 17, 2020

Rebecca Erwin
Environmental Service Laboratories Inc
1803 Philadelphia Street
Indiana, PA 15701

TEL:

FAX:

RE: 0020482

Dear Rebecca Erwin:

Order No.: 20020639

Summit Environmental Technologies, Inc. received 1 sample(s) on 2/10/2020 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative.

Quality control data is within laboratory defined or method specified acceptance limits except where noted.

If you have any questions regarding these tests results, please feel free to call the laboratory.

Sincerely,

Holly Florea

Project Manager

3310 Win St.

Cuyahoga Falls, Ohio 44223

Arkansas 88-0735, California 07256CA, Colorado, Connecticut PH-0108, Delaware, Florida NELAC E87688, Georgia E87688, Idaho OH00923, Illinois 200061, Indiana C-OH-13, Kansas E-10347, Kentucky (Underground Storage Tank) 3, Kentucky 90146, Louisiana 04061, Maryland 339, Minnesota 409711, New Hampshire 2996, New Jersey OH006, New York 11777, North Carolina 39705 and 631, North Dakota R-201, Ohio DW, Ohio VAP CL0052, Oklahoma 9940, Oregon OH200001, Pennsylvania 010, Rhode Island LA000317, South Carolina 92016001, Texas T104704466-11-5, Utah OH009232011-1, Virginia VELAP 9456, Washington C891



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Case Narrative

WO#: 20020639
Date: 2/17/2020

CLIENT: Environmental Service Laboratories Inc
Project: 0020482

This report in its entirety consists of the following documents: Cover Letter, Case Narrative, Analytical Results, QC Summary Report, Applicable Accreditation Information, Chain-of-Custody, Cooler Receipt Form, and other applicable forms as necessary. All documents contain the Summit Environmental Technologies, Inc., Work Order Number assigned to this report.

Summit Environmental Technologies, Inc., holds the accreditations/certifications listed at the bottom of the cover letter that may or may not pertain to this report. Please refer to the "Accreditation Program Analytes Report" for accredited analytes list.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the customer. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the customer for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.

All results for Solid Samples are reported on an "as received" or "wet weight" basis unless indicated as "dry weight" using the "-dry" designation on the reporting units.

This report is believed to meet all of the requirements of the accrediting agency, where applicable. Any comments or problems with the analytical events associated with this report are noted below.

Original



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Workorder
Sample Summary
WO#: 20020639
17-Feb-20

CLIENT: Environmental Service Laboratories Inc
Project: 0020482

Lab SampleID	Client Sample ID	Tag No	Date Collected	Date Received	Matrix
20020639-001	0020482-01		2/6/2020 10:15:00 AM	2/10/2020 6:40:00 PM	Non-Potable Water



SUMMIT
 ENVIRONMENTAL TECHNOLOGIES, INC.
 Analytical Laboratories

Summit Environmental Technologies, Inc.
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: **20020639**

Date Reported: **2/17/2020**

CLIENT: Environmental Service Laboratories Inc

Collection Date: 2/6/2020 10:15:00 AM

Project: 0020482

Lab ID: 20020639-001

Matrix: NON-POTABLE WATER

Client Sample ID: 0020482-01

Analyses	Result	PQL	Qual	Units	DF	Date Analyzed
TOTAL KJELDAHL NITROGEN (4500-NH3-D) 2011					A4500-NH3-D A4500-NOR	Analyst: DNS
Nitrogen, Total Kjeldahl	ND	0.500		mg/L	1	2/14/2020 4:20:00 PM

Qualifiers:
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 RL Reporting Detection Limit

M Manual Integration used to determine area response
 PL Permit Limit
 W Sample container temperature is out of limit as specified at testcode

Original



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 20020639
17-Feb-20

Client: Environmental Service Laboratories Inc
Project: 0020482

BatchID: 42040

Sample ID: **MB-42040** SampType: **MBLK** TestCode: **TKN_NPW(45)** Units: **mg/L** Prep Date: **2/13/2020** RunNo: **109367**
Client ID: **PBW** Batch ID: **42040** TestNo: **A4500-NH3-D A4500-NorgC** Analysis Date: **2/14/2020** SeqNo: **2628276**
Analyte Result **ND** PQL **0.500** SPK value **0** SPK Ref Val **0** %REC **0** LowLimit **0** HighLimit **0** RPD Ref Val **0** %RPD **0** RPDLimit **0**
Nitrogen, Total Kjeldahl

Sample ID: **LCS-42040** SampType: **LCS** TestCode: **TKN_NPW(45)** Units: **mg/L** Prep Date: **2/13/2020** RunNo: **109367**
Client ID: **LCSW** Batch ID: **42040** TestNo: **A4500-NH3-D A4500-NorgC** Analysis Date: **2/14/2020** SeqNo: **2628277**
Analyte Result **12.6** PQL **0.500** SPK value **12.50** SPK Ref Val **0** %REC **101** LowLimit **85** HighLimit **115** RPD Ref Val **0** %RPD **0** RPDLimit **0**
Nitrogen, Total Kjeldahl

Sample ID: **RLC-42040** SampType: **RLC** TestCode: **TKN_NPW(45)** Units: **mg/L** Prep Date: **2/13/2020** RunNo: **109367**
Client ID: **BatchQC** Batch ID: **42040** TestNo: **A4500-NH3-D A4500-NorgC** Analysis Date: **2/14/2020** SeqNo: **2628278**
Analyte Result **ND** PQL **0.500** SPK value **0.5000** SPK Ref Val **0** %REC **99.6** LowLimit **50** HighLimit **150** RPD Ref Val **0** %RPD **0** RPDLimit **0**
Nitrogen, Total Kjeldahl

Sample ID: **20020632-001ADUP** SampType: **DUP** TestCode: **TKN_NPW(45)** Units: **mg/L** Prep Date: **2/13/2020** RunNo: **109367**
Client ID: **BatchQC** Batch ID: **42040** TestNo: **A4500-NH3-D A4500-NorgC** Analysis Date: **2/14/2020** SeqNo: **2628839**
Analyte Result **0.838** PQL **0.500** SPK value **0.7450** SPK Ref Val **0** %REC **11.7** LowLimit **0** HighLimit **20** RPD Ref Val **0** %RPD **0** RPDLimit **0**
Nitrogen, Total Kjeldahl

Qualifiers: B Analyte detected in the associated Method Blank H Holding times for preparation or analy
J Analyte detected below quantitation limits MC Value is below Minimum Compound
ND Not Detected PL Permit Limit
R RPD outside accepted recovery limits S Spike Recovery outside accepted reco



Summit Environmental Technologies, Inc.
 3310 Win St.
 Cayahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 20020639
 17-Feb-20

Client: Environmental Service Laboratories Inc
Project: 0020482

BatchID: 42040

Sample ID: 20020632-001ADUP	SampType: DUP	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/13/2020	RunNo: 109367
Client ID: BatchQC	Batch ID: 42040	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/14/2020	SeqNo: 2628839
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC
				LowLimit	HighLimit
				RPD Ref Val	%RPD
				RPDLimit	Qual

Sample ID: 20020365-001AMS	SampType: MS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/13/2020	RunNo: 109367
Client ID: BatchQC	Batch ID: 42040	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/14/2020	SeqNo: 2628860
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC
				LowLimit	HighLimit
				RPD Ref Val	%RPD
				RPDLimit	Qual

Nitrogen, Total Kjeldahl 183 5.00 125.0 67.40 92.5 80 120

Sample ID: 20020365-001AMSD	SampType: MSD	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/13/2020	RunNo: 109367
Client ID: BatchQC	Batch ID: 42040	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/14/2020	SeqNo: 2628861
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC
				LowLimit	HighLimit
				RPD Ref Val	%RPD
				RPDLimit	Qual

Nitrogen, Total Kjeldahl 193 5.00 125.0 67.40 100 80 120 183.0 5.32 20

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range	H	Holding times for preparation or analy
	J	Analyte detected below quantitation limits	M	Manual Integration used to determine area response	MC	Value is below Minimum Compound
	ND	Not Detected	P	Second column confirmation exceeds	PL	Permit Limit
	R	RPD outside accepted recovery limits	RL	Reporting Detection Limit	S	Spike Recovery outside accepted reco



Qualifiers and Acronyms

WO#: 20020639
Date: 2/17/2020

These commonly used Qualifiers and Acronyms may or may not be present in this report.

Qualifiers

U	The compound was analyzed for but was not detected above the MDL.
J	The reported value is greater than the Method Detection Limit but less than the Reporting Limit.
H	The hold time for sample preparation and/or analysis was exceeded. Not Clean Water Act compliant.
D	The result is reported from a dilution.
E	The result exceeded the linear range of the calibration or is estimated due to interference.
MC	The result is below the Minimum Compound Limit.
*	The result exceeds the Regulatory Limit or Maximum Contamination Limit.
m	Manual integration was used to determine the area response.
d	Manual integration in which peak was deleted
N	The result is presumptive based on a Mass Spectral library search assuming a 1:1 response.
P	The second column confirmation exceeded 25% difference.
C	The result has been confirmed by GC/MS.
X	The result was not confirmed when GC/MS Analysis was performed.
B	The analyte was detected in the Method Blank at a concentration greater than the RL.
MB+	The analyte was detected in the Method Blank at a concentration greater than the MDL.
G	The ICB or CCB contained reportable amounts of analyte.
QC-/+	The CCV recovery failed low (-) or high (+).
R/QDR	The RPD was outside of accepted recovery limits.
QL-/+	The LCS or LCSD recovery failed low (-) or high (+).
QLR	The LCS/LCSD RPD was outside of accepted recovery limits.
QM-/+	The MS or MSD recovery failed low (-) or high (+).
QMR	The MS/MSD RPD was outside of accepted recovery limits.
QV-/+	The ICV recovery failed low (-) or high (+).
S	The spike result was outside of accepted recovery limits.
W	Samples were received outside temperature limits (0° – 6° C). Not Clean Water Act compliant.
Z	Deviation; A deviation from the method was performed; Please refer to the Case Narrative for additional information

Acronyms

ND	Not Detected	RL	Reporting Limit
QC	Quality Control	MDL	Method Detection Limit
MB	Method Blank	LOD	Level of Detection
LCS	Laboratory Control Sample	LOQ	Level of Quantitation
LCSD	Laboratory Control Sample Duplicate	PQL	Practical Quantitation Limit
QCS	Quality Control Sample	CRQL	Contract Required Quantitation Limit
DUP	Duplicate	PL	Permit Limit
MS	Matrix Spike	RegLvl	Regulatory Limit
MSD	Matrix Spike Duplicate	MCL	Maximum Contamination Limit
RPD	Relative Percent Different	MinCL	Minimum Compound Limit
ICV	Initial Calibration Verification	RA	Reanalysis
ICB	Initial Calibration Blank	RE	Recextraction
CCV	Continuing Calibration Verification	TIC	Tentatively Identified Compound
CCB	Continuing Calibration Blank	RT	Retention Time
RLC	Reporting Limit Check	CF	Calibration Factor

This list of Qualifiers and Acronyms reflects the most commonly utilized Qualifiers and Acronyms for reporting. Please refer to the Analytical Notes in the Case Narrative for any Qualifiers or Acronyms that do not appear in this list or for additional information regarding the use of these Qualifiers on reported data.

Original



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

DATES REPORT

WO#: 20020639
17-Feb-20

Client: Environmental Service Laboratories Inc
Project: 0020482

Sample ID	Client Sample ID	Collection Date	Matrix	Test Name	Leachate Date	Prep Date	Analysis Date
20020639-001A	0020482-01	2/6/2020 10:15:00 AM	Non-Potable Water	Total Kjeldahl Nitrogen (4500-NH3-D		2/13/2020 11:15:00 AM	2/14/2020 4:20:00 PM

Original



SUMMIT
 ENVIRONMENTAL TECHNOLOGIES, INC
 Analytical Laboratories

Summit Environmental Technologies, Inc.
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

**Accreditation Program
 Analytes Report**

WO#: 20020639
 17-Feb-20

Client: Environmental Service Laboratories Inc
Project: 0020482

State: PA
Program Name: Pennsylvanis DEP

Test Name	Matrix	Analyte	Status
Total Kjeldahl Nitrogen (4500-NH3-D) 2011	Non-Potable Water	Nitrogen, Ammonia	A

Original #1

SUBCONTRACT ORDER

Environmental Service Laboratories, Inc.

0020482

Please report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Summit Environmental Technologies, Inc.
3310 Win Street
Cuyahoga Falls, OH 44223
Phone : (330) 253-8211
Fax: (330) 253-4489

20020639

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0020482-01			
Matrix: Water	Sampled: 02/06/2020 10:15	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen		02/18/2020 23:00 03/05/2020 10:15	
Containers Supplied: Poly 250mL, H2SO4 (D) ✓			1

Handwritten note: Set with 100 D. 6-11-20 = 1cc

Released By: *[Signature]* Date: 2/8/20
 Received By: *[Signature]* Date: 2-10-20
 Released By: *[Signature]* Date: 2-10-20
 Received By: *[Signature]* Date: 2-10-20 6:40 P





Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Sample Log-In Check List

Client Name: **ENV-PA-15701** Work Order Number: **20020639** RcptNo: **1**

Logged by:	Jessica E. Westfall	2/10/2020 6:40:00 PM	
Completed By:	Jessica E. Westfall	2/11/2020 4:31:03 PM	
Reviewed By:	Holly Florea	2/12/2020 2:24:18 PM	

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? Summit

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
- (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
- (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	1.6	Good	Not Present			



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

03 March 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0021656
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0021656-01	Waste Water	02/20/2020 10:30	2/20/20 15:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Summit Environmental Technologies, Inc., PA-DEP ID 68-01335; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/03/2020 21:11

Lab Sample ID#: 0021656-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 02/20/2020 10:30
 Receipt Date: 02/20/2020 15:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	2.74	mg/L		0.104	TLL	03/02/20 14:30	03/03/20 14:30
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	02/25/20 10:58	02/25/20 11:40
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	2.74	mg/L		0.104	TLL	03/02/20 14:30	03/03/20 14:30
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	3.0	mg/L		0.30	JPD	02/28/20 15:53	02/28/20 16:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB, C	3.00	AW	02/21/20 13:10	02/26/20 09:20
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	ANP	02/20/20 15:57	02/21/20 11:16

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

SAMPLE REQUEST & CHAIN OF CUSTODY



NORTHWEST DIVISION
850 Main Street
Sharpville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	0021656	2/20/20	10:30 AM	2/20/20	10:30 AM	WW	1 ✓	Poly 1000mL None	CBOD, TSS
	01					WW	1 ✓	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL Na2S2O3	2.9 iu (3) Fecal Coliform 1540 AMP 2/20/20
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>									
Sampled By: (Signature)			Date/ Time		2/20/20 10:30 AM				
Relinquished By: (Signature)			Date/ Time		2/20/20 1330				
Relinquished By: (Signature)			Date/ Time		2/20/20 15:40				
Relinquished By: (Signature)			Date/ Time		2/20/20 1537				
Relinquished By: (Signature)			Date/ Time						
<p>Project Notes: Wastewater</p>									
Company/Name: MONITEAU SCHOOL DISTRICT									
Contact Person: JEFFREY CAMPBELL									
Address: 1810 WEST SUNBURY ROAD									
WEST SUNBURY, PA 16061									
Phone / Cell: 724-406-4426									
Email: icampbell@moniteau.k12.pa.us									
Correct Preservations		Y / N / NA		Correct Containers		Y / N / NA		Receipt Temperature	



SAMPLE RECEIPT AND REVIEW FORM



PART A: General Information

Client: <u>Monteau School</u>		Work Order: _____	
Received by: <u>AND</u>	Date/Time Received: <u>2/20/20 15:40</u>	Date Sampled: <u>2/20/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>2.9</u>		Samples Received on Ice: <input checked="" type="radio"/> YES NO	
IR Gun # Used: 1 2 <u>3</u> 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)		Containers removed by Satellite Lab for analysis of: TCMPN Fecal Coliform TC/EC ECMPN	
Sample State of Collection: <input checked="" type="radio"/> PA NY OH WV Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <input checked="" type="radio"/> NO	

PART B: Receipt Details

Completed (if different from above): _____
Signature Date Time

Sample Receipt Criteria					Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required	
1	Chain of custody documents included with samples?	Yes	No	N/A	Comments:	YES	NO
2	COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments:	YES	NO
3	Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES	NO
4	Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected:	YES	NO
5	Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected:	YES	NO
6	Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected:	YES	NO
7	Samples received within holding time?	Yes	No	N/A	ID's and tests affected:	YES	NO
8	Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES	NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES	NO
11	Adequate sample volume received?	Yes	No	N/A	Analyses Affected:	YES	NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<input checked="" type="radio"/> N/A	Sample ID's and containers affected:	YES	NO
Other Comments:						Deficiency Log Created: Yes <input checked="" type="radio"/> No	



Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

March 02, 2020

Rebecca Erwin
Environmental Service Laboratories Inc
1803 Philadelphia Street
Indiana, PA 15701
TEL:
FAX:
RE: 0021656

Dear Rebecca Erwin:

Order No.: 20021476

Summit Environmental Technologies, Inc. received 1 sample(s) on 2/21/2020 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative.

Quality control data is within laboratory defined or method specified acceptance limits except where noted.

If you have any questions regarding these tests results, please feel free to call the laboratory.

Sincerely,

Holly Florea
Project Manager
3310 Win St.
Cuyahoga Falls, Ohio 44223

Arkansas 88-0735, California 07256CA, Colorado, Connecticut PH-0108, Delaware, Florida NELAC E87688, Georgia E87688, Idaho OH00923, Illinois 200061, Indiana C-OH-13, Kansas E-10347, Kentucky (Underground Storage Tank) 3, Kentucky 90146, Louisiana 04061, Maryland 339, Minnesota 409711, New Hampshire 2996, New Jersey OH006, New York 11777, North Carolina 39705 and 631, North Dakota R-201, Ohio DW, Ohio VAP CL0052, Oklahoma 9940, Oregon OH200001, Pennsylvania 010, Rhode Island LA000317, South Carolina 92016001, Texas T104704466-11-5, Utah OH009232011-1, Virginia VELAP 9456, Washington C891



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Case Narrative

WO#: 20021476
Date: 3/2/2020

CLIENT: Environmental Service Laboratories Inc
Project: 0021656

This report in its entirety consists of the following documents: Cover Letter, Case Narrative, Analytical Results, QC Summary Report, Applicable Accreditation Information, Chain-of-Custody, Cooler Receipt Form, and other applicable forms as necessary. All documents contain the Summit Environmental Technologies, Inc., Work Order Number assigned to this report.

Summit Environmental Technologies, Inc., holds the accreditations/certifications listed at the bottom of the cover letter that may or may not pertain to this report. Please refer to the "Accreditation Program Analytes Report" for accredited analytes list.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the customer. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the customer for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.

All results for Solid Samples are reported on an "as received" or "wet weight" basis unless indicated as "dry weight" using the "-dry" designation on the reporting units.

This report is believed to meet all of the requirements of the accrediting agency, where applicable. Any comments or problems with the analytical events associated with this report are noted below.

Original



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Workorder Sample Summary

WO#: 20021476
02-Mar-20

CLIENT: Environmental Service Laboratories Inc
Project: 0021656

Lab SampleID	Client Sample ID	Tag No	Date Collected	Date Received	Matrix
20021476-001	0021656-01		2/20/2020 10:30:00 AM	2/21/2020 11:00:00 AM	Non-Potable Water



SUMMIT
 ENVIRONMENTAL TECHNOLOGIES, INC
 Analytical Laboratories

Summit Environmental Technologies, Inc.
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

Analytical Report

(consolidated)

WO#: 20021476

Date Reported: 3/2/2020

CLIENT: Environmental Service Laboratories Inc

Collection Date: 2/20/2020 10:30:00 AM

Project: 0021656

Lab ID: 20021476-001

Matrix: NON-POTABLE WATER

Client Sample ID: 0021656-01

Analyses	Result	PQL	Qual	Units	DF	Date Analyzed
TOTAL KJELDAHL NITROGEN (4500-NH3-D) 2011		A4500-NH3-D	A4500-NOR	Analyst: DNS		
Nitrogen, Total Kjeldahl	ND	0.500		mg/L	1	2/27/2020 8:18:00 PM

Qualifiers:
 H Holding times for preparation or analysis exceeded
 ND Not Detected
 RL Reporting Detection Limit

M Manual Integration used to determine area response
 PL Permit Limit
 W Sample container temperature is out of limit as specified at testcode

Original



Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 20021476
02-Mar-20

Client: Environmental Service Laboratories Inc
Project: 0021656

BatchID: 42284

Sample ID: MB-42284	SampType: MBLK	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: PBW	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2655017						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	ND	0.500									

Sample ID: LCS-42284	SampType: LCS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: LCSW	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2655018						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	13.2	0.500	12.50	0	106	85	115				

Sample ID: RLC-42284	SampType: RLC	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: BatchQC	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2655019						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	0.537	0.500	0.5000	0	107	50	150				

Sample ID: 20021475-001AMS	SampType: MS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: BatchQC	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2656862						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	12.6	0.500	12.50	0	101	80	120				

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range	H	Holding times for preparation or analy
	J	Analyte detected below quantitation limits	M	Manual Integration used to determine area response	MC	Value is below Minimum Compound
	ND	Not Detected	P	Second column confirmation exceeds	PL	Permit Limit
	R	RPD outside accepted recovery limits	RL	Reporting Detection Limit	S	Spike Recovery outside accepted reco



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

QC SUMMARY REPORT

WO#: 20021476
02-Mar-20

Client: Environmental Service Laboratories Inc
Project: 0021656

BatchID: 42284

Sample ID: 20021475-001AMS	SampType: MS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: BatchQC	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2656862						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Sample ID: 20021475-001AMSD	SampType: MSD	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: BatchQC	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2656863						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	12.4	0.500	12.50	0	99.2	80	120	12.60	1.60	20	

Sample ID: 20021529-001ADUP	SampType: DUP	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 2/26/2020	RunNo: 109926						
Client ID: BatchQC	Batch ID: 42284	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 2/27/2020	SeqNo: 2656867						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	1.87	0.500						2.170	14.9	20	

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range	H	Holding times for preparation or analy
J	Analyte detected below quantitation limits	M	Manual Integration used to determine area response	MC	Value is below Minimum Compound	
ND	Not Detected	P	Second column confirmation exceeds	PL	Permit Limit	Original
R	RPD outside accepted recovery limits	RL	Reporting Detection Limit	S	Spike Recovery outside accepted reco	

These commonly used Qualifiers and Acronyms may or may not be present in this report.

Qualifiers

U	The compound was analyzed for but was not detected above the MDL.
J	The reported value is greater than the Method Detection Limit but less than the Reporting Limit.
H	The hold time for sample preparation and/or analysis was exceeded. Not Clean Water Act compliant.
D	The result is reported from a dilution.
E	The result exceeded the linear range of the calibration or is estimated due to interference.
MC	The result is below the Minimum Compound Limit.
*	The result exceeds the Regulatory Limit or Maximum Contamination Limit.
m	Manual integration was used to determine the area response.
d	Manual integration in which peak was deleted
N	The result is presumptive based on a Mass Spectral library search assuming a 1:1 response.
P	The second column confirmation exceeded 25% difference.
C	The result has been confirmed by GC/MS.
X	The result was not confirmed when GC/MS Analysis was performed.
B	The analyte was detected in the Method Blank at a concentration greater than the RL.
MB+	The analyte was detected in the Method Blank at a concentration greater than the MDL.
G	The ICB or CCB contained reportable amounts of analyte.
QC-/+	The CCV recovery failed low (-) or high (+).
R/QDR	The RPD was outside of accepted recovery limits.
QL-/+	The LCS or LCSD recovery failed low (-) or high (+).
QLR	The LCS/LCSD RPD was outside of accepted recovery limits.
QM-/+	The MS or MSD recovery failed low (-) or high (+).
QMR	The MS/MSD RPD was outside of accepted recovery limits.
QV-/+	The ICV recovery failed low (-) or high (+).
S	The spike result was outside of accepted recovery limits.
W	Samples were received outside temperature limits (0° – 6° C). Not Clean Water Act compliant.
Z	Deviation; A deviation from the method was performed; Please refer to the Case Narrative for additional information

Acronyms

ND	Not Detected	RL	Reporting Limit
QC	Quality Control	MDL	Method Detection Limit
MB	Method Blank	LOD	Level of Detection
LCS	Laboratory Control Sample	LOQ	Level of Quantitation
LCSD	Laboratory Control Sample Duplicate	PQL	Practical Quantitation Limit
QCS	Quality Control Sample	CRQL	Contract Required Quantitation Limit
DUP	Duplicate	PL	Permit Limit
MS	Matrix Spike	RegLvl	Regulatory Limit
MSD	Matrix Spike Duplicate	MCL	Maximum Contamination Limit
RPD	Relative Percent Different	MinCL	Minimum Compound Limit
ICV	Initial Calibration Verification	RA	Reanalysis
ICB	Initial Calibration Blank	RE	Reextraction
CCV	Continuing Calibration Verification	TIC	Tentatively Identified Compound
CCB	Continuing Calibration Blank	RT	Retention Time
RLC	Reporting Limit Check	CF	Calibration Factor

This list of Qualifiers and Acronyms reflects the most commonly utilized Qualifiers and Acronyms for reporting. Please refer to the Analytical Notes in the Case Narrative for any Qualifiers or Acronyms that do not appear in this list or for additional information regarding the use of these Qualifiers on reported data.



Summit Environmental Technologies, Inc.
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

SUMMIT
 ENVIRONMENTAL TECHNOLOGIES, INC.
 Analytical Laboratories

DATES REPORT

WO#: 20021476
 02-Mar-20

Client: Environmental Service Laboratories Inc
Project: 0021656

Sample ID	Client Sample ID	Collection Date	Matrix	Test Name	Leachate Date	Prep Date	Analysis Date
20021476-001A	0021656-01	2/20/2020 10:30:00 AM	Non-Potable Water	Total Kjeldahl Nitrogen (4500-NH3-D		2/26/2020 1:25:00 PM	2/27/2020 8:18:00 PM

Original



SUMMIT
 ENVIRONMENTAL TECHNOLOGIES, INC
 Analytical Laboratories

Summit Environmental Technologies, Inc.
 3310 Win St.
 Cuyahoga Falls, Ohio 44223
 TEL: (330) 253-8211 FAX: (330) 253-4489
 Website: <http://www.settek.com>

**Accreditation Program
 Analytes Report**

WO#: 20021476
 02-Mar-20

Client: Environmental Service Laboratories Inc

State: PA

Project: 0021656

Program Name: Pennsylvanis DEP

Test Name	Matrix	Analyte	Status
Total Kjeldahl Nitrogen (4500-NH3-D) 2011	Non-Potable Water	Nitrogen, Ammonia	A

Key

PA-NELAP A Accredited

Original #1

SUBCONTRACT ORDER

Environmental Service Laboratories, Inc.

0021656

20021476

Please report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Summit Environmental Technologies, Inc.
3310 Win Street
Cuyahoga Falls, OH 44223
Phone : (330) 253-8211
Fax: (330) 253-4489

State of Origin: PA

Analysis	Due	Expires	Comments	
Sample ID: 0021656-01			ph	
Matrix: Water	Sampled: 02/20/2020 10:30	Sample Type: Grab		Sampled By: Client
Total Kjeldahl Nitrogen Containers Supplied. Poly 250mL, H2SO4 (D)	03/03/2020 23:00	03/19/2020 10:30		

DBPix Evaluation

Released By: [Signature] Date: 2/20/20

Received By: Jackie Resil Date: 2/20/20

Released By: [Signature] Date: 2/1/20





Summit Environmental Technologies, Inc.
3310 Win St.
Cuyahoga Falls, Ohio 44223
TEL: (330) 253-8211 FAX: (330) 253-4489
Website: <http://www.settek.com>

Sample Log-In Check List

Client Name: **ENV-PA-15701** Work Order Number: **20021476** RcptNo: **1**

Logged by:	Jacqueline Rasile	2/21/2020 11:00:00 AM	<i>Jacqueline Rasile</i>
Completed By:	John A. Semenik	2/24/2020 1:43:20 PM	<i>John A. Semenik</i>
Reviewed By:	Jessica E. Westfall	2/24/2020 1:44:03 PM	<i>Jessica E. Westfall</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
2. How was the sample delivered? UPS

Log In

3. Coolers are present? Yes No NA
4. Shipping container/cooler in good condition? Yes No
- Custody seals intact on shipping container/cooler? Yes No Not Present
- No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes No NA
6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
7. Sample(s) in proper container(s)? Yes No
8. Sufficient sample volume for indicated test(s)? Yes No
9. Are samples (except VOA and ONG) properly preserved? Yes No
10. Was preservative added to bottles? Yes No NA
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
12. Were any sample containers received broken? Yes No
13. Does paperwork match bottle labels? Yes No
- (Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes No
15. Is it clear what analyses were requested? Yes No
16. Were all holding times able to be met? Yes No
- (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	_____	Date:	_____
By Whom:	_____	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	_____		
Client Instructions:	_____		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	2.1	Good	Not Present			

**Moniteau School District
Moniteau High School
Water Treatment Facility
Monthly Operations and
Testing Report for February
2020**

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	SAT										
2	SUN										
3	Mon	53.1	3,111, 785	0.92	1.04	7.3	0.00	0	1.35	Jeff C	09:00 A
4	Tues	57.1	3,122, 420	0.92	0.99	7.3	0.00	0	1.22	Jeff C	08:30 A
5	Wed	54.1	3,122, 420	0.90	0.99	7.3	0.00	0	1.18	Jeff C	09:00
6	Thurs	55.0	3,134, 532	0.83	0.94	7.1	0.02	0	0.86	Jeff R	11:00 A
7	FRI	50.7	3,134, 532	0.81	0.91	7.0	0.00	0	1.12	Jeff R.	12:45 P
8	SAT										
9	SUN										
10	Mon	51.4	3,141, 445	0.75	0.88	7.2	0.02	0	2.10	Jeff C	09:00
11	Tues	51.1	3,146, 977	0.73	0.84	7.1	0.00	0	2.12	Jeff C	2:00 PM
12	Wed	49.0	3,146, 977	0.75	0.84	7.2	0.00	0	2.13	Jeff C	08:00
13	Thurs	52.4	3,160, 019	0.69	0.80	7.1	0.02	0	2.35	Jeff C	08:30
14	FRI	48.0	3,160, 019	0.70	0.80	7.1	0.01	0	2.32	Jeff C	09:15
15	SAT										
16	SUN										
17	Mon	45.0	3,167, 047	0.73	0.83	7.0	0.00	0	1.48	Jeff C	10:30 A
18	Tues	45.5	3,167, 047	0.75	0.83	7.1	0.00	0	1.45	Jeff C	09:00 A
19	Wed	51.7	3,179, 737	0.62	0.76	7.1	0.03	0	2.09	Jeff C	1:00 PM
20	Thurs	49.0	3,179, 737	0.63	0.74	7.1	0.01	0	2.02	Jeff C	10:00 AM
21	Fri	51.1	3,191, 355	0.72	0.84	7.1	0.02	0	2.07	Jeff C	09:00 A
22	SAT										
23	SUN										
24	Mon	47.7	3,191, 355	0.72	0.79	7.1	0.01	0	2.02	Jeff C	08:00 AM
25	Tues	55.2	3,204, 541	0.69	0.82	7.0	0.00	0	2.10	Jeff C	08:30 AM
26	Wed	54.5	3,204, 541	0.71	0.82	7.0	0.00	0	2.08	Jeff C	11:00 AM
27	Thurs	52.4	3,211, 542	0.77	0.91	7.1	0.00	0	2.02	Jeff C	08:15 AM
28	FRI	46.7	3,211, 542	0.85	0.89	7.1	0.00	0	2.00	Jeff C	08:15 AM
29	SAT.										
30											
31											

Meter Reading on 1/31/20 3,107, 798



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 18150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

28 February 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0022156
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0022156-01	Drinking Water	02/27/2020 13:00	2/27/20 14:56	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/28/2020 09:39

Lab Sample ID#: 0022156-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 02/27/2020 13:00
Receipt Date: 02/27/2020 14:56

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.910	mg/L		0.200	PFS	02/27/20 13:00	02/27/20 13:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



DRTHWEST DIVISION
0 Main Street
Parsippany, PA 18
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>0022156</u>		<u>1300</u>	DW	Field	Field	Free Chlorine <u>91</u> mg/L

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin-Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 2-27-20 1300
 Relinquished By: (Signature) [Signature] Date/ Time 2-27-20 1405

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____
 Correct Preservations Y/N NA Correct Containers Y/N NA Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Call Phone: **jcampbell@moniteau.k12.pa.us**
 Billing Address: **5100324**
 PWSID: **5100324**

**5100324: MONITEAU JR/SR HIGH SCHOOL
 SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	020620	802		020620	D	1305	32382	0020556-01	BROWNKA_50
5100324	1013	FREE CHLORINE	301	0.63	021320	802		021320	D	1305	32382	0021171-01	BROWNKA_416
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	802		020620	D	1305	32382	0020556-01	BROWNKA_51
5100324	1013	FREE CHLORINE	301	0.82	022020	803		022020	D	1335	32382	0021657-01	BROWNKA_911
5100324	1013	FREE CHLORINE	301	0.91	022720	804		022720	D	1300	32382	0022156-01	BROWNKA_1331



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0021657
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0021657-01	Drinking Water	02/20/2020 13:35	2/20/20 15:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/24/2020 08:00

Lab Sample ID#: 0021657-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 02/20/2020 13:35
Receipt Date: 02/20/2020 15:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.820	mg/L		0.200	PFS	02/20/20 13:35	02/20/20 13:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1903 Philadelphia St.
Indiana, PA 15701
(724) 483-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benileyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 483-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Page 3 of 4



Sample Identification	ESL# 6021657	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 803	01	Grab Date: 2/20/20 Time: 1335	DW	Field	Field	Free Chlorine, 82 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804-400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>						
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>		<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Email Address: 5100324</p> <p>Billing Address:</p> <p>PWSID:</p>				
<p>Sampled By: (Signature)</p> <p>Relinquished By: (Signature)</p> <p>Relinquished By: (Signature)</p> <p>Relinquished By: (Signature)</p>	<p>2/20/20 1335</p> <p>2/20/20 1537</p>	<p>Received By: (Signature)</p> <p>Received By: (Signature)</p> <p>Received By: (Signature)</p>	<p>2/20/20 1545</p>	<p>Date/ Time</p> <p>Date/ Time</p> <p>Date/ Time</p>	<p>Correct Preservations Y / N / NA</p> <p>Correct Containers Y / N / NA</p> <p>Receipt Temperature</p>	

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	020620	802		020620	D	1305	32382	0020556-01	BROWNKA_50
5100324	1013	FREE CHLORINE	301	0.63	021320	802		021320	D	1305	32382	0021171-01	BROWNKA_416
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	802		020620	D	1305	32382	0020556-01	BROWNKA_51
5100324	1013	FREE CHLORINE	301	0.82	022020	803		022020	D	1335	32382	0021657-01	BROWNKA_911



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 February 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0021171
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0021171-01	Drinking Water	02/13/2020 13:05	2/14/20 10:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/14/2020 14:19

Lab Sample ID#: 0021171-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 02/13/2020 13:05
Receipt Date: 02/14/2020 10:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.630	mg/L		0.200	PFS	02/13/20 13:05	02/13/20 13:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

WEST DIVISION
Street
PA 16
-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE ___ OF ___

<p>Sample Identification</p> <p>Distribution: <u>802</u></p>		<p>ESL# <u>0021171</u></p> <p><u>01</u></p>	<p>Sample Type</p> <p>Grab</p> <p>Date <u>2/13/08</u> Time <u>13:50</u></p>	<p>Matrix</p> <p>DW</p>	<p># of Bottles</p> <p>Field</p>	<p>Container Type</p> <p>Preservative</p> <p>Field</p>	<p>Analysis Requested</p> <p>Free Chlorine <u>63</u> mg/L</p>
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time <u>2/13/08 14:05</u></p>		<p>Received By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time <u>2/13/08 10:10</u></p>		<p>Relinquished By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time</p>	
<p>Relinquished By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p><u>[Signature]</u></p> <p>Date/ Time</p>		<p>Correct Preservations Y / N / (NA)</p> <p>Correct Containers Y / N / (NA)</p> <p>Receipt Temperature <u> </u></p>	
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD</p> <p>WEST SUNBURY, PA 18061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>							

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	020620	802		020620	D	1305	32382	0020556-01	BROWNKA_50
5100324	1013	FREE CHLORINE	301	0.63	021320	802		021320	D	1305	32382	0021171-01	BROWNKA_416
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	802		020620	D	1305	32382	0020556-01	BROWNKA_51



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 February 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0020556
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0020556-01	Drinking Water	02/06/2020 13:05	2/6/20 13:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/11/2020 11:39

Lab Sample ID#: 0020556-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 02/06/2020 13:05
Receipt Date: 02/06/2020 13:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field			
Chlorine, Free	0.940	mg/L		0.200	PFS	02/06/20 13:05	02/06/20 13:05
Microbiology		Analytical Method: SM9223 B-04		Prep Method: No Prep - Micro			
Total Coliform	Absent	per 100 mL		1	ANP	02/06/20 15:19	02/07/20 15:52
E. Coli	Absent	per 100 mL		1	ANP	02/06/20 15:19	02/07/20 15:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER

1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION

1276 Benileville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION

435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION

950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL# 0020556

CIRCLE ONE:
704 KITCHEN MAIN SINK
802 ROOM 204 SINK

Sample Type

Date: 2-6-20
Grab: 1305

Matrix

DW

of Bottles

1

Container Type
Preservative

STERILE PLASTIC
NA THIO

Analysis Requested

TC/EC ✓, 94
Free Chlorine

4.3 ice ③ 1455
AMP 2/6/20

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)

Date/Time: 2-6-20 1305

Relinquished By: (Signature)

Date/Time: 2-6-20 1450

Relinquished By: (Signature)

Date/Time: _____

Relinquished By: (Signature)

Date/Time: _____

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

43
32.1°C

2/7/20
MWE

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 18061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.k12.pa.us

Billing Address: 5100324

PWSID: 5100324



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	020620	802		020620	D	1305	32382	0020556-01	BROWNKA_50
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020720	802		020620	D	1305	32382	0020556-01	BROWNKA_51