

Moniteau School District
Maintenance Department
Moniteau High School
SOC May 2023



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

08 May 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23D1323
Project: Drinking Water Moniteau Jr/Sr - SOC
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101 - SOCs	23D1323-01	Drinking Water	04/13/2023 11:20	4/13/23 13:40	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

SOCs subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By


Kirsten Conoran

Kirsten Conoran
Project Manager

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

ENVIRONMENTAL SERVICE LABORATORIES, INC. HEADQUARTERS 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209		SOUTHERN DIVISION 1276 Bentleyville Road Van Vorthis, PA 15366 (724) 258-TEST FAX: (724) 258-8376		NORTHWEST DIVISION 1 Street Alle, PA 16150 3-TEST (24) 465-4209	
--	--	---	--	---	--



23D1323

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Composite	Grab				
		Date on/off	Time on/off	Date	Time		
Entry Point 101	23D1323					40 ml CLEAR VIAL Na2S2O3	SOC 504
						40 ml CLEAR VIAL Na2S2O3	SOC 505
						AMBER GLASS Na2S2O3	SOC 515 / SOC 548
						AMBER GLASS	SOC 525
						Sodium Sulfite/HCL	SOC 531.1
						250 ML AMBER GLASS Na2S2O3, C6H7K07	SOC 547
						250 ML AMBER GLASS Na2S2O3	SOC 549
						1 L HDPE AMBER Na2S2O3 & H2SO4	SOC 1613
						AMBER GLASS Na2S2O3	

Project Notes:
Drinking Water Moniteau Jr/Sr - SOC

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**
 Contact Person:
 Phone Number:
 Cell Phone:
 Email Address: **jcampbell@moniteau.org**
 Billing Address:
 PWSID: **5100324**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) *[Signature]* Date/ Time **4/13/23 1340**
 Received By: (Signature) *[Signature]* Date/ Time **4/13/23 0852**
 Relinquished By: (Signature) *[Signature]* Date/ Time **4/13/23 1304**
 Relinquished By: (Signature) *[Signature]* Date/ Time
 Relinquished By: (Signature) *[Signature]* Date/ Time
 Relinquished By: (Signature) *[Signature]* Date/ Time



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Mon. Tenn</u>	Work
--------------------------	------

23D1323 (g)

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>Jm 100382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>4/13/22 1340</u>	Date Sampled: <u>4/13/22</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> ESL courier Other: _____	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details

Completed (if different from above): _____ Signature _____ Date / / Time

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO	Comments:
COC form is properly signed in relinquished/received sections?	YES NO	Comments:
Sample containers intact and sealed?	YES NO	Circle Applicable: Damaged Container _____ Leaking Container _____ Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES NO	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: NO

Effective Date:

SUBCONTRACT ORDER

Environmental Service Laboratories, Inc.

23D1323

Please report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.

Suburban Water Testing Labs - Reading

1803 Philadelphia Street

1037F MacArthur Road

Indiana, PA 15701

Reading, PA 19605

Phone: 724-463-8378

Phone: (610) 375-8378

Fax: 724-465-4209

Fax: 1610-375-4090

Project Manager: Kirsten Conoran

State of Origin: PA

Client: Monticau School District

PWSID: 5100324

Analysis

Sample ID: 23D1323-01 Sample Name: Entry Point 101 - SOC

Matrix: Drinking Water Sampled: 04/13/2023 11:20 Sample Type: Grab Sampled By: Paul Somogyi

SOC 1613 2,3,7,8 TCDD Dioxin

04/25/2023 23:00 04/12/2024 11:20

SOC 504

04/25/2023 23:00 04/27/2023 11:20

SOC 505

04/25/2023 23:00 04/27/2023 11:20

SOC 515

04/25/2023 23:00 04/27/2023 11:20

SOC 525 Pesticides

04/25/2023 23:00 04/27/2023 11:20

SOC 531.1

04/25/2023 23:00 05/11/2023 11:20

SOC 547 Glyphosate

04/25/2023 23:00 04/27/2023 11:20

SOC 548.1 Endothal

04/25/2023 23:00 04/20/2023 11:20

SOC 549 Diquat

04/25/2023 23:00 04/20/2023 11:20

Containers Supplied:

Amber Glass, 1000mL,

VOA Vial, 40mL, Na2SO3 (A)

Na2SO3 (B)

Amber Glass, 1000mL,

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3 (C)

(F)

Amber Glass, 250mL,

Amber Glass, 1000mL,

Amber HDPE, 1000mL,

Na2SO3 and HCL (K)

Na2SO3 & C6H7K07 (L)

Na2SO3 (M)

Na2SO3 & H2SO4 (N)

Amber Glass, 500mL,

Na2SO3 (I)

Amber Glass, 1000mL,

Na2SO3 and HCL (J)

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

VOA Vial, 40mL, Na2SO3

Released By

Date

Received By

Date

Released By

Date

Received By

Date





Results Report

Order ID: 3D04059

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: Moniteau School District

Attn: Accounts Payable

Sample Number: 3D04059-01
Collector: Paul Somogyi
Sample Regulatory ID: 5100324

Site: EP 101
Collect Date: 04/13/2023 11:20 am
SDWA Reporting IDs: (101 / R / E)

Sample ID: 23D1323-01
Sample Type: E

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Dioxins and Furans by Isotope Dilution HRGC/HRMS

EPA1613B

2,3,7,8-TCDD	< 10	pg/L	EPA1613B	10	1	05/04/23		05/05/23 18:10	SUB*
--------------	------	------	----------	----	---	----------	--	----------------	------

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 1,2,3,4-TCDD-13C	10000	pg/L	EPA1613B	503%	1	0.0-0.0	05/05/23 18:10
Surrogate: 2,3,7,8-TCDD-13C	1300	pg/L	EPA1613B	63%	1	31.0-137.0	05/05/23 18:10
Surrogate: 2,3,7,8-TCDD-37Cl4	140	pg/L	EPA1613B	68%	1	42.0-164.0	05/05/23 18:10

Semivolatiles

SOC 504.1, Analysis

1,2-Dibromoethane (EDB)	< 0.0197	µg/L	EPA 504.1	0.0197	1	04/17/23	MAG	04/18/23 9:23	MAG
1,2-Dibromo-3-chloropropane (DBCP)	< 0.0197	µg/L	EPA 504.1	0.0197	1	04/17/23	MAG	04/18/23 9:23	MAG

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 1,1,1,2-Tetrachloroethane	0.2360	µg/L	EPA 504.1	96%	1	70-130	04/18/23 9:23

SOC 505

PCBs (as Aroclors)	< 0.1994	µg/L	EPA 505	0.1994	1	04/19/23	MAG	04/20/23 12:41	MAG
Toxaphene	< 1.994	µg/L	EPA 505	1.994	1	04/19/23	MAG	04/20/23 12:41	MAG

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Tetrachloro-m-xylene	0.9972	µg/L	EPA 505	100%	1	70-130	04/20/23 12:41

SOC 515.3

Dalapon	< 1.25	µg/L	EPA 515.3	1.25	1	04/20/23	AMAA	04/21/23 20:30	MWS
2,4-D	< 1.25	µg/L	EPA 515.3	1.25	1	04/20/23	AMAA	04/21/23 20:30	MWS
Pentachlorophenol	< 0.12	µg/L	EPA 515.3	0.12	1	04/20/23	AMAA	04/21/23 20:30	MWS
2,4,5-TP (Silvex)	< 0.31	µg/L	EPA 515.3	0.31	1	04/20/23	AMAA	04/21/23 20:30	MWS
Picloram	< 1.25	µg/L	EPA 515.3	1.25	1	04/20/23	AMAA	04/21/23 20:30	MWS
Dinoseb	< 1.25	µg/L	EPA 515.3	1.25	1	04/20/23	AMAA	04/21/23 20:30	MWS

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: 2,4-Dichlorophenylacetic Acid (DCAA)	21.5	µg/L	EPA 515.3	86%	1	70-130	04/21/23 20:30

Report Generated On: 05/08/2023 12:44 pm

3D04059

STL_Results Revision #2.1

Effective: 09/01/2022





SUBURBAN TESTING LABS

Sample Number: 3D04059-01	Site: EP 101	Sample ID: 23D1323-01
Collector: Paul Somogyi	Collect Date: 04/13/2023 11:20 am	Sample Type: E
Sample Regulatory ID: 5100324	SDWA Reporting IDs: (101 / R / E)	

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Semivolatiles (Continued)

SOC 525.2

Alachlor	< 0.49	µg/L	EPA 525.2	0.49	1	04/24/23	NDK	04/24/23 14:44	DWL
Atrazine	< 0.25	µg/L	EPA 525.2	0.25	1	04/24/23	NDK	04/24/23 14:44	DWL
Benzo(a)pyrene	< 0.05	µg/L	EPA 525.2	0.05	1	04/24/23	NDK	04/24/23 14:44	DWL
Chlordane	< 0.05	µg/L	EPA 525.2	0.05	1	04/24/23	NDK	04/24/23 14:44	DWL
di(2-Ethylhexyl) adipate	< 1.47	µg/L	EPA 525.2	1.47	1	04/24/23	NDK	04/24/23 14:44	DWL
di(2-Ethylhexyl) phthalate	< 1.47	µg/L	EPA 525.2	1.47	1	04/24/23	NDK	04/24/23 14:44	DWL
Endrin	< 0.25	µg/L	EPA 525.2	0.25	1	04/24/23	NDK	04/24/23 14:44	DWL
Gamma-BHC (Lindane)	< 0.05	µg/L	EPA 525.2	0.05	1	04/24/23	NDK	04/24/23 14:44	DWL
Heptachlor	< 0.10	µg/L	EPA 525.2	0.10	1	04/24/23	NDK	04/24/23 14:44	DWL
Heptachlor epoxide	< 0.05	µg/L	EPA 525.2	0.05	1	04/24/23	NDK	04/24/23 14:44	DWL
Hexachlorobenzene	< 0.25	µg/L	EPA 525.2	0.25	1	04/24/23	NDK	04/24/23 14:44	DWL
Hexachlorocyclopentadiene	< 0.25	µg/L	EPA 525.2	0.25	1	04/24/23	NDK	04/24/23 14:44	DWL
Methoxychlor	< 0.25	µg/L	EPA 525.2	0.25	1	04/24/23	NDK	04/24/23 14:44	DWL
Simazine	< 0.17	µg/L	EPA 525.2	0.17	1	04/24/23	NDK	04/24/23 14:44	DWL

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: Pyrene-d10	4.51	µg/L	EPA 525.2	92%	1	50-150	04/24/23 14:44
Surrogate: Triphenylphosphate	5.36	µg/L	EPA 525.2	109%	1	50-150	04/24/23 14:44
Surrogate: 1,3-Dimethyl-2-Nitrobenzene	5.15	µg/L	EPA 525.2	105%	1	50-150	04/24/23 14:44
Surrogate: Perylene-d12	4.50	µg/L	EPA 525.2	92%	1	50-150	04/24/23 14:44

SOC 531.2

Oxamyl (vydate)	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 1:13	SCD
Carbofuran	< 5.0	µg/L	EPA 531.2	5.0	1	04/25/23	ENB	04/28/23 1:13	SCD

Surrogate Recoveries	Results	Units	Method	%Recovery	DF	Limits (%Recovery)	Analysis Date
Surrogate: BDMC (surr)	56.0	µg/L	EPA 531.2	112%	1	70-130	04/28/23 1:13

Glyphosate	< 50.0	µg/L	EPA 547	50.0	1	04/24/23	SCD	04/25/23 15:23	ENB
Endothall	< 20.0	µg/L	EPA 548.1	20.0	1	04/18/23	AMAA	04/20/23 16:16	LAS
Diquat	< 2.0	µg/L	EPA 549.2	2.0	1	04/18/23	HSK	04/20/23 1:03	ENB

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Work Order Memo

SUB: EPA1613B performed by LAB ID# 68-00563

Report Generated On: 05/08/2023 12:44 pm 3D04059
STL_Results Revision #2.1 Effective: 09/01/2022

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lauren Ulle
Project Manager I

Report Generated On: 05/08/2023 12:44 pm 3D04059
STL_Results Revision #2.1 Effective: 09/01/2022





3D04059
Lauren Ulle

CONTRACT ORDER

Environmental Service Laboratories, Inc.

23D1323

@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Kirsten Conoran

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone : (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Client: Moniteau School District

PWSID: 5100324

Analysis	Due	Expires	Comments
----------	-----	---------	----------

Sample ID: 23D1323-01 Sample Name: Entry Point 101 - SOCs

Matrix: Drinking Water Sampled: 04/13/2023 11:20 Sample Type: Grab Sampled By: Paul Somogyi

SOC 1613 2,3,7,8 TCDD Dioxin	04/25/2023 23:00	04/12/2024 11:20	
SOC 504	04/25/2023 23:00	04/27/2023 11:20	
SOC 505	04/25/2023 23:00	04/27/2023 11:20	
SOC 515	04/25/2023 23:00	04/27/2023 11:20	
SOC 525 Pesticides	04/25/2023 23:00	04/27/2023 11:20	
SOC 531.1	04/25/2023 23:00	05/11/2023 11:20	
SOC 547 Glyphosate	04/25/2023 23:00	04/27/2023 11:20	
SOC 548.1 Endothall	04/25/2023 23:00	04/20/2023 11:20	
SOC 549 Diquat	04/25/2023 23:00	04/20/2023 11:20	

Containers Supplied:

Amber Glass, 1000mL, Na2S2O3 (A)	Amber Glass, 1000mL, Na2S2O3 (B)	VOA Vial, 40mL, Na2S2O3 (C)	VOA Vial, 40mL, Na2S2O3 (D)	VOA Vial, 40mL, Na2S2O3 (E)
VOA Vial, 40mL, Na2S2O3 (F)	VOA Vial, 40mL, Na2S2O3 (G)	VOA Vial, 40mL, Na2S2O3 (H)	Amber Glass, 500mL, Na2S2O3 (I)	Amber Glass, 1000mL, Na2SO3 and HCL (J)
Amber Glass, 1000mL, Na2SO3 and HCL (K)	Amber Glass, 250mL, Na2S2O3 & C6H7KO7 (L)	Amber Glass, 250mL, Na2S2O3 (M)	Amber HDPE, 1000mL, Na2S2O3 & H2SO4 (N)	

Suburban Testing Labs

Lab Date/Time: 4-14-23 1222 Lab Temp: 1-9.0°C

Number of containers/coolers match number on COC?
Sample labels and COC are free of discrepancies?
All containers intact?
Received in lab within acceptable temperature limits?
40 mL VOA vials free of headspace?

Relinquished by: [Signature]
Received in lab by: GB 4-14-23 1825
Ice

Released By: [Signature] Date: 4/13/23
 Received By: [Signature] Date: 04/14/23 0630
 Released By: [Signature] Date: 04/14/23 0815
 Received By: [Signature] Date: 4-14-23 0855





3D04059
Lauren Ulle

CONTRACT ORDER

Environmental Service Laboratories, Inc.

23D1323

@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Kirsten Conoran

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Client: Moniteau School District

PWSID: 5100324

Analysis	Due	Expires	Comments
----------	-----	---------	----------

Sample ID: 23D1323-01 Sample Name: Entry Point 101 - SOCs

Matrix: Drinking Water Sampled: 04/13/2023 11:20 Sample Type: Grab Sampled By: Paul Somogyi

SOC 1613 2,3,7,8 TCDD Dioxin	04/25/2023 23:00	04/12/2024 11:20	
SOC 504	04/25/2023 23:00	04/27/2023 11:20	
SOC 505	04/25/2023 23:00	04/27/2023 11:20	
SOC 515	04/25/2023 23:00	04/27/2023 11:20	
SOC 525 Pesticides	04/25/2023 23:00	04/27/2023 11:20	
SOC 531.1	04/25/2023 23:00	05/11/2023 11:20	
SOC 547 Glyphosate	04/25/2023 23:00	04/27/2023 11:20	
SOC 548.1 Endothall	04/25/2023 23:00	04/20/2023 11:20	
SOC 549 Diquat	04/25/2023 23:00	04/20/2023 11:20	

Containers Supplied:

Amber Glass, 1000mL, Na2S2O3 (A)	Amber Glass, 1000mL, Na2S2O3 (B)	VOA Vial, 40mL, Na2S2O3 (C)	VOA Vial, 40mL, Na2S2O3 (D)	VOA Vial, 40mL, Na2S2O3 (E)
VOA Vial, 40mL, Na2S2O3 (F)	VOA Vial, 40mL, Na2S2O3 (G)	VOA Vial, 40mL, Na2S2O3 (H)	Amber Glass, 500mL, Na2S2O3 (I)	Amber Glass, 1000mL, Na2SO3 and HCL (J)
Amber Glass, 1000mL, Na2SO3 and HCL (K)	Amber Glass, 250mL, Na2S2O3 & C6H7KO7 (L)	Amber Glass, 250mL, Na2S2O3 (M)	Amber HDPE, 1000mL, Na2S2O3 & H2SO4 (N)	

Suburban Testing Labs

Lab Date/Time: 4-14-23 1222 Lab Temp: 1-8.0C

Number of containers/coolers match number on COC?
Sample labels and COC are free of discrepancies?
All containers intact?
Received in lab within acceptable temperature limits?
40 mL VOA vials free of headspace?

Relinquished by: [Signature]
Received in lab by: CTB 4-14-23 1825
ICE

Released By: [Signature] Date: 4/14/23

Received By: [Signature] Date: 04/14/23 0630

Released By: [Signature] Date: 04/14/23 0845

Received By: [Signature] Date: 4-14-23 0855



