

Moniteau School District  
Maintenance Department  
Moniteau High School  
Water Treatment Facility  
Monthly Report for October 2022

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	2022	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Sat										
2	Sun										
3	Mon	61.0	7,167,342	0.57	0.63	7.2	0.03	0	1.22	JEFFR	11:30 AM
4	Tues										
5	Wed	61.9	7,180,202	0.57	0.61	7.1	0.04	0	1.52	JEFFR	11:45 AM
6	Thurs	62.0	7,180,202	0.54	0.61	7.1	0.03	0	1.50	JEFFR	11:30 AM
7	Fri	63.4	7,192,969	0.63	0.68	7.3	0.04	0	1.28	JEFFR	12:00 PM
8	Sat										
9	Sun										
10	Mon	60.9	7,202,953	0.68	0.70	7.2	0.01	0	1.12	JEFF C	4:00 PM
11	Tues	60.8	7,202,953	0.70	0.73	7.2	0.01	0	1.10	JEFFC	11:00 AM
12	Wed	60.7	7,202,953	0.70	0.73	7.2	0.01	0	1.11	JEFFC	9:00 AM
13	Thurs	63.2	7,214,315	0.73	0.76	7.1	0.00	0	0.99	JEFF C	8:00 AM
14	Fri										
15	Sat										
16	Sun										
17	Mon	62.1	7,214,315	0.70	0.73	7.1	0.00	0	1.01	Seth C	5:30 PM
18	Tues	59.6	7,237,791	0.66	0.73	7.2	0.03	0	1.15	JEFFR	11:30 AM
19	Wed	56.1	7,237,791	0.65	0.70	7.2	0.02	0	1.11	JEFFC	6:00 PM
20	Thurs	54.2	7,237,791	0.64	0.68	7.2	0.02	0	1.09	JEFF C	9:00 AM
21	Fri	56.6	7,250,647	0.68	0.73	7.1	0.01	0	1.17	JEFF C	10:30 AM
22	Sat										
23	Sun										
24	Mon	62.5	7,259,701	0.61	0.66	7.1	0.00	0	1.12	JEFFC	4:00 PM
25	Tues	61.8	7,263,352	0.63	0.66	7.1	0.00	0	1.10	JEFFC	2:00 PM
26	Wed	62.4	7,263,352	0.64	0.68	7.0	0.00	0	1.10	JEFFC	11:00 AM
27	Thurs	62.7	7,263,352	0.64	0.68	7.0	0.00	0	1.11	JEFFC	2:00 PM
28	Fri	59.7	7,277,654	0.65	0.70	7.1	0.01	0	1.27	JEFF C	4:00 PM
29	Sat										
30	Sun										
31	Mon	60.0	7,277,859	0.61	0.65	7.0	0.00	0	1.25	JEFFC	11:00 AM



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

28 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22J2416**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	22J2416-01	Drinking Water	10/27/2022 11:00	10/27/22 13:25	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/28/2022 11:27

**Lab Sample ID#:** 22J2416-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 10/27/2022 11:00  
**Receipt Date:** 10/27/2022 13:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.650	mg/L		0.200	PS	10/27/22 11:00	10/27/22 11:00

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**



2212416

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	22-57416	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	Distribution:	804				
Sample Type		Date	Time			
Grab		10-27-07	1100			

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 10-27-07 1100  
 Relinquished By: (Signature) Date/ Time 10-27-07 1306

Received By: (Signature) Date/ Time 10/29/07  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Notes/Special Instructions:  
**Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
 Contact Person: **JEFFREY CAMPBELL**  
 Phone Number: **724-406-4426**  
 Cell Phone: **jcambell@moniteau.org**  
 Email Address: **jcambell@moniteau.org**  
 Billing Address: **5100324**  
 PWSID: **5100324**

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.61	101322	704		101322	D	1120	32382	22J1303-01	BROWNKA_669
5100324	1013	FREE CHLORINE	301	0.54	100622	802		100622	D	1110	32382	22J0649-01	BROWNKA_72
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1110	32382	22J0649-01	BROWNKA_73
5100324	1013	FREE CHLORINE	301	0.59	102022	803		102022	D	0000	32382	22J1855-01	BROWNKA_961
5100324	1013	FREE CHLORINE	301	0.65	102722	804		102722	D	1100	32382	22J2416-01	BROWNKA_1556



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 83-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

21 October 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 22J1855  
 Project: Drinking Water Moniteau Jr/Sr - Weekly  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	22J1855-01	Drinking Water	10/20/2022 11:20	10/20/22 13:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- H Analyzed out of recommended hold time. Sample does not meet hold time requirements of 40 CFR Part 136.
- RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager



1503 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 33-00182

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/21/2022 13:43

Lab Sample ID#: 22J1855-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: S03 Admin Sink

Sample Date: 10/20/2022 11:20  
 Receipt Date: 10/20/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.590	mg/L	H	0.200	PS	10/20/22 00:00	10/20/22 00:00





22J1855

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

**HEADQUARTER**  
 1803 Philadelphia St  
 Indiana, PA 15701  
 (724) 463-1EST  
 FAX: (724) 466-4209

**SOUTHERN DIVISION**  
 1276 Bartleyville Road  
 Van Vleet, PA 15366  
 (724) 288-1EST  
 FAX: (724) 258-8376

**NORTHERN DIVISION**  
 430 Broad Street  
 Monaca, PA 17754  
 (570) 321-8903  
 FAX: (570) 321-1957

**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 15  
 (724) 463-TEST  
 FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

**SAMPLE REQUEST & CHAIN OF CUSTODY**

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>803</u>	22J1855	Grab	DW	Field	Preservative	Free Chlorine <u>0.59</u> mg/L
	01	Date: <u>10/20/22</u> Time: <u>1130</u>				
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						

Notes/Special Instructions: *Drinking Water Moniteau Jr/Sr - Weekly*

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (14% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.

2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/Time: 10/20/22 1130

Relinquished By: (Signature) [Signature] Date/Time: 10/20/22 1130

Relinquished By: (Signature) \_\_\_\_\_ Date/Time: \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/Time: \_\_\_\_\_

Correct Preservations: Y / N / N A      Correct Containers: Y / N / N A      Receipt Temperature: \_\_\_\_\_

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL

Contact Person: \_\_\_\_\_  
 Phone Number: 724-406-4425  
 Cell Phone: \_\_\_\_\_  
 Email Address: jcampbell@moniteau.org  
 Billing Address: \_\_\_\_\_  
 PWSID: 5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.61	101322	704		101322	D	1120	32382	22J1303-01	BROWNKA_669
5100324	1013	FREE CHLORINE	301	0.54	100622	802		100622	D	1110	32382	22J0649-01	BROWNKA_72
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1110	32382	22J0649-01	BROWNKA_73
5100324	1013	FREE CHLORINE	301	0.59	102022	803		102022	D	0000	32382	22J1855-01	BROWNKA_961



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

17 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22J1303**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Distribution 704	22J1303-01	Drinking Water	10/13/2022 11:20	10/13/22 13:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/17/2022 10:59

**Lab Sample ID#:** 22J1303-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** Distribution 704

**Sample Date:** 10/13/2022 11:20  
**Receipt Date:** 10/13/2022 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.610	mg/L		0.200	PS	10/13/22 11:20	10/13/22 11:20

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957



## SAMPLE REQUEST & CHAIN OF CUSTODY

Æ 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 704	22J1303		1:20	DW	Field	Field	Free Chlorine <i>CeCel</i> mg/L
	01						

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

Notes/Special Instructions:  
*Drinking Water Moniteau Jr/Sr - Weekly*

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**  
Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**  
Contact Person: **724-406-4426**  
Phone Number: **jcampbell@moniteau.org**  
Cell Phone:  
Email Address:  
Billing Address:  
PWSID: **5100324**

Sampled By: (Signature) *[Signature]* Date/ Time **10-13-22 11:18**  
Relinquished By: (Signature) *[Signature]* Date/ Time **10-13-22 13:15**  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) *[Signature]* Date/ Time **10/13/22 15:15**  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations *Y/N/NA* Correct Containers *Y/N/NA* Receipt Temperature \_\_\_\_\_  
*10/13/22 AMB*



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.61	101322	704		101322	D	1120	32382	22J1303-01	BROWNKA_669
5100324	1013	FREE CHLORINE	301	0.54	100622	802		100622	D	1110	32382	22J0649-01	BROWNKA_72
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1110	32382	22J0649-01	BROWNKA_73



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 October 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22J0649**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 802**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	22J0649-01	Drinking Water	10/06/2022 11:10	10/6/22 15:05	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/11/2022 14:05

**Lab Sample ID#:** 22J0649-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 10/06/2022 11:10  
**Receipt Date:** 10/06/2022 15:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.540	mg/L		0.200	PS	10/06/22 11:10	10/06/22 11:10
<b>Microbiology</b>		<b>Analytical Method: SM 9223 B-16</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	AMB	10/06/22 16:00	10/07/22 16:44
E. Coli	Absent	per 100 mL		1	AMB	10/06/22 16:00	10/07/22 16:44

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



22J0649

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# <u>2250649</u>	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
CIRCLE ONE: 704-KITCHEN-MAIN SINK 802 ROOM 204 SINK	<u>01</u>	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine <u>0.54</u>
	Sample Type				
	Grab				
	Date				
	Time				
	<u>10-6-07</u>				
	<u>11:00</u>				
704: Jan, Mar, May, Jul, Sept, Nov					
802: Feb, Apr, Jun, Aug, Oct, Dec					
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.					
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)					
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.					
Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>10-6-07</u>	<u>11:00</u>	
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>10-6-07</u>	<u>11:05</u>	
Relinquished By: (Signature)		Date/ Time			
Relinquished By: (Signature)		Date/ Time			
Correct Preservations (Y/N/NA)	<u>(Y)N/NA</u>	Correct Containers (Y/N/NA)	<u>(Y)N/NA</u>	Receipt Temperature	<u>48°C</u>
Notes/Special Instructions: <b>Drinking Water Moniteau Jr/Sr - Monthly</b>					
Company/Name: <b>MONITEAU SCHOOL DISTRICT</b>					
Address: <b>1810 WEST SUNBURY ROAD</b>					
<b>WEST SUNBURY, PA 16061</b>					
Contact Person: <b>JEFFREY CAMPBELL</b>					
Phone Number: <b>724-406-4426</b>					
Cell Phone: <b>jcampbell@moniteau.org</b>					
Billing Address: <b>5100324</b>					
PWSID: <b>5100324</b>					



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.54	100622	802		100622	D	1110	32382	22J0649-01	BROWNKA_72
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1110	32382	22J0649-01	BROWNKA_73

Moniteau School District  
Maintenance Department  
Moniteau High School  
Wastewater Treatment Facility  
Monthly Report for October 2022



JEFFREY CAMPBELL <jcampbell@moniteau.org>

## Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Tue, Nov 1, 2022 at 2:26 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 10/01/2022-10/31/2022  
**Report Due Date:** 11/28/2022

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 358137  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 10/01/2022  
 DMR Effective To: 10/31/2022  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	10	01	2022	10	31

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		6.12	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.05	***	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		11.5	***	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		1.28	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		.17	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		6.90	***	1/week	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.003565		***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	***	***	1/week	Measured

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	<1.0	<1.0	10000	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***	Geo Mean	IMAX	***		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***	<2.00	25	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***	Avg Mo	***	***		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER

Moniteau School District  
 Moniteau High School - WASTE WATER PLANT  
 Monthly Work Sheet for OCT. 2022

FLOW  $110,517 \div 31 = 3,565$  Daily Avg.  
 U.V Light TOTAL  $144.9 \div 21 = 6.9$  Daily Avg.  
 PH Low 6.05 BASIN #1 10/4/22  
 High 7.30 BASIN #2 10/27/22  
 D.O. Low 6.12 BASIN #2 10/10/22  
 High 9.07 BASIN #1 10/31/22

Total Nitrogen	< 0.729	1.83	2.559	1.2795	1.28
TKN	< 0.625	< 0.625	1.25	0.625	0.625
TSS	18	< 5	23	11.5	11.5
Nitrate/Nitrite	0.613	1.83	2.443	1.2215	1.22
Phos	0.13	0.20	0.33	0.165	0.17
CBOD	< 2.00	< 2.00	< 4.00	< 2.00	< 2.00
Fecal	< 1	< 1.00	< 2.00	< 1.00	< 1.00
	10/13/22	10/20/22	TOTAL	$\div 2$	TOTAL REPORT

Moniteau High School Sewage Treatment Plant				Daily Operations Worksheet					
Permit # PA0091341				OCT. 2022					
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Meter Reading	Time	Operator
10/13	Mon	6.08	8.42	AERATION		5.4		10:30 AM	JR
10/14	Tues	6.05	7.21	6.52	7.88	6.7		12:00	JR
10/15	Wed	6.08	6.48	6.46	7.71	6.7		4:15 PM	JR
10/16	Thurs	AERATION		6.74	8.88	5.7		11:00 AM	JR
10/17	FRI	6.25	7.73	6.69	8.02	5.8		11:00 AM	JR
10/18	Mon	6.29	7.71	6.71	6.12	5.8		2:00 PM	JC
10/19	Tues	6.31	7.64	6.74	6.18	5.8		8:00 AM	JC
10/20	Wed	6.48	7.70	6.81	6.40	5.6		10:00 AM	JC
10/21	Thurs	6.46	7.41	6.99	7.10	8.0	Cleaned	10:00 AM	JC
10/22	FRI	7.00	7.22	7.05	7.17	8.0	UV bulbs	10:00 AM	JC
10/23	Mon	7.05	7.28	7.05	7.12	8.0		5:00 PM	SC
10/24	Tues	6.99	7.39	7.08	7.08	8.0		5:00 PM	SC
10/25	Wed	6.95	7.77	7.08	6.98	8.5		5:00 PM	SC
10/26	Thurs	6.80	8.10	7.10	7.01	9.1		10:00 AM	JC
10/27	FRI	6.83	8.05	7.11	7.05	9.0		10:00 AM	JC
10/28	Mon	7.01	7.75	7.22	7.11	7.0		2:00 PM	JR
10/29	Tues	7.10	7.71	AERATION		7.0		9:00 AM	JC
10/30	Wed	7.12	7.90	7.23	7.15	5.9		10:00 AM	JC
10/31	Thurs	AERATION		7.30	7.12	6.3		8:00 AM	JR
	FRI	7.15	8.01	AERATION		6.5		9:00 AM	JC
	Mon	7.21	9.07	7.17	9.68	6.1		8:00 AM	JR

\* TEST DAY

\* TEST DAY





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

31 October 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22J1844**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22J1844-01	Waste Water	10/20/2022 10:30	10/20/22 13:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/31/2022 09:34

**Lab Sample ID#:** 22J1844-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 10/20/2022 10:30  
**Receipt Date:** 10/20/2022 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: *** DEFAULT SPECIFIC METHOD</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	1.83	mg/L		0.729	DAA	10/26/22 06:30	10/26/22 19:02
<b>General Chemistry</b>	<b>Analytical Method: EPA 351.2 2.0</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	10/26/22 06:30	10/26/22 19:02
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-15</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	TLL	10/27/22 09:40	10/27/22 16:25
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-16 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	1.83	mg/L		0.104	AW	10/21/22 11:22	10/21/22 11:22
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.20	mg/L		0.10	AW	10/21/22 14:25	10/21/22 14:25
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-16</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	TJC	10/21/22 14:15	10/26/22 10:46
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	10/20/22 15:00	10/21/22 11:24

**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTERS  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SC 12 Vc (7 F

22J1844

NORTHERN DIVISION  
950 Main Street  
Sharpshville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

NORTHWEST DIVISION  
950 Main Street  
Sharpshville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/off	Date	Time			
Effluent Outfall 001	22J1844		10/20/22	10:30 AM	1	Poly 1000mL	CBOD, TSS
	01				1	None	Total Nitrogen, Total Phosphorus
					1	Poly 1000mL H2SO4	Fecal Coliform
						Sterile Plastic 125mL Na2S2O3	

**Project Notes:**  
Wastewater

MONTEAU SCHOOL DISTRICT

Company/Name: JEFFREY CAMPBELL  
Contact Person: 1810 WEST SUNBURY ROAD  
Address: WEST SUNBURY, PA 16061  
Phone / Cell: 724-406-4426  
Email: icampbell@montiteau.org

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 10/20/22 10:30 AM  
Relinquished By: (Signature) Date/ Time 10/20/22 11:30  
Relinquished By: (Signature) Date/ Time 10/20/22 11:30  
Relinquished By: (Signature) Date/ Time 10/20/22 11:30  
Received By: (Signature) Date/ Time 10/20/22 11:30  
Received By: (Signature) Date/ Time 10/20/22 11:30  
Received By: (Signature) Date/ Time 10/20/22 11:30  
Received By: (Signature) Date/ Time 10/20/22 11:30

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Woi	 22J1844	ere)
-------------------------	-----	-------------	------

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SPM (00382)</u>	Samples Received on Ice? <input checked="" type="radio"/> YES NO
Date/Time Received: <u>10/20/22 1330</u>	Date Sampled: <u>10/29/22</u>
Method of Delivery: FedEx UPS Client Drop off <input checked="" type="radio"/> ESL courier Other: _____	
Sample Receipt Temperature: <u>4.6</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="radio"/> PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="radio"/> NO

## PART C: Receipt Details Completed (if different from above): \_\_\_\_\_

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/>	<input type="radio"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/>	<input type="radio"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/>	<input type="radio"/>	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <input checked="" type="radio"/> NO

Effective Date: \_\_\_\_\_

GP.25.A-1 Sample Receipt Log



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

25 October 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 22J1185**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab Outfall 001	22J1185-01	Waste Water	10/13/2022 10:00	10/13/22 13:33	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/25/2022 15:23

**Lab Sample ID#:** 22J1185-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Grab Outfall 001

**Sample Date:** 10/13/2022 10:00  
**Receipt Date:** 10/13/2022 13:33

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: *** DEFAULT SPECIFIC METHOD</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	<0.729	mg/L		0.729	DAA	10/19/22 06:30	10/20/22 15:14
<b>General Chemistry</b>	<b>Analytical Method: EPA 351.2 2.0</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	10/19/22 06:30	10/20/22 15:14
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-15</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	18	mg/L		5	TLL	10/20/22 10:57	10/20/22 17:30
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-16 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	0.613	mg/L		0.104	AW	10/17/22 11:19	10/17/22 11:19
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.13	mg/L		0.10	AW	10/17/22 12:55	10/17/22 12:55
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-16</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS	2.00	MJS	10/14/22 13:35	10/19/22 09:50
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	10/13/22 15:29	10/14/22 12:50





# SAMPLE RECEIPT AND REVIEW FORM

Client: MONTEAU SCHOOL DISTRICT Work Order: \_\_\_\_\_



## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: \_\_\_\_\_ Date/Time Received:    /    /     
 Method of Delivery: Client Drop-Off  ESL Courier  Other: \_\_\_\_\_ Received on Ice? YES  NO   
 Sample Receipt Temperature: \_\_\_\_\_ °C IR Gun ID: \_\_\_\_\_  
 Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: MKE (00382) Samples Received on Ice?  YES  NO  
 Date/Time Received: 10/13/22 1333 Date Sampled: 10/13/22  
 Method of Delivery: FedEx  UPS  Client Drop off  ESL courier Other: \_\_\_\_\_  
 Sample Receipt Temperature: 2.1 °C IR Gun ID: 3  
 Sample State of Collection:  PA  NY  OH  WV Other: \_\_\_\_\_ PWSID Compliance Drinking Water Samples: YES  NO

## PART C: Receipt Details Completed (if different from above): \_\_\_\_\_

Sample Receipt Criteria		Signature _____	Date _____	Time _____
Chain of custody documents included with samples?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Comments/Qualifiers (Required for Non-Conforming Items)		
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Comments:		
Sample containers intact and sealed?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Circle Applicable: Damaged Container _____ Leaking Container _____ Custody Seal Broken Other: _____		
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected:		
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected:		
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected:		
Samples received within holding time?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected:		
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected and Observed pH:		
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/> YES <input type="radio"/> NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.		
Adequate sample volume received?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Analyses Affected:		
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="radio"/> YES <input type="radio"/> NO	Sample IDs and Containers Affected:		
Other Comments:		Deficiency Log Created:		
		YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		

Effective Date: \_\_\_\_\_



Moniteau School District  
Maintenance Department  
Dassa McKinney School  
Water Treatment Facility  
Monthly Report for October 2022

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Oct	Sat									
1	Sat									
2	Sun									
3	Mon	8.7	0.02	0.60	0.66	1.84	13616900	Jeff R	4:30P	4000
4	Tues									
5	Wed	8.7	0.00	0.78	0.87	1.38	13624900	Jeff R	4:30P	8000
6	Thurs	8.7	0.00	0.80	0.88	1.45	13629100	Jeff R	4:30P	4200
7	Fri	8.7	0.02	0.75	0.82	1.51	13633000	Jeff R	4:30P	3900
8	Sat									
9	Sun									
10	Mon	8.7	0.00	0.70	0.78	1.62	13633900	Jeff R	7:00P	900
11	Tues	8.7	0.00	0.58	0.66	1.78	13637800	Jeff R	4:30P	3900
12	Wed	8.7	0.04	0.68	0.75	2.03	13641200	Jeff R	3:00P	3400
13	Thurs	8.7	0.02	0.59	0.68	2.05	13645000	Jeff R	3:30P	3800
14	Fri		Vacation							
15	Sat									
16	Sun									
17	Mon	8.7	0.00	0.75	0.85	1.34	13653200	Jeff R	4:30P	8200
18	Tues	8.7	0.00	0.82	0.93	1.44	13657100	Jeff R	4:30P	3900
19	Wed	8.7	0.01	0.61	0.69	1.56	13660400	Jeff R	3:30P	3300
20	Thurs	8.7	0.02	0.64	0.71	1.58	13664700	Jeff R	4:30P	4300
21	Fri	8.7	0.02	0.68	0.75	1.90	13668300	Jeff R	4:30P	3600
22	Sat									
23	Sun									
24	Mon									
25	Tues	8.7	0.02	SICK	Day					
26	Wed	8.7	0.04	0.63	0.70	1.34	13676000	Jeff R	4:30P	7700
27	Thurs	8.7	0.00	0.65	0.74	1.42	13679500	Jeff R	4:30P	3500
28	Fri	8.7	0.00	0.65	0.72	2.00	13683000	Jeff R	4:30P	3500
29	Sat		0.00	0.80	0.89	2.14	13686400	Jeff R	3:30P	3400
30	Sun						13690100			
31	Mon	8.7	0.02	0.72	0.80	2.27	13690100	Jeff R	3:30P	3700

Meter Reading 9/30/22 - 13612900



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

28 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22J2417**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	22J2417-01	Drinking Water	10/27/2022 10:40	10/27/22 13:25	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 10/28/2022 11:28

**Lab Sample ID#:** 22J2417-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:**  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 10/27/2022 10:40  
**Receipt Date:** 10/27/2022 13:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.820	mg/L		0.200	PS	10/27/22 10:40	10/27/22 10:40



22J2417

**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

*FOR INTERNAL LABORATORY USE ONLY*

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SU4</u>	<u>22J2417</u>			DW	Field	Field	Free Chlorine <u>0.82</u> mg/L
	<u>01</u>		<u>10/27/10</u>				
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802-Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>				<p>Company Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD</b></p> <p><b>WEST SUNBURY, PA 16061</b></p> <p><b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.org</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: <b>5100316</b></p> <p>PWSID: <b>5100316</b></p>			
<p>Sampled By: (Signature) </p> <p>Date/ Time <u>10/27/10</u> <u>1040</u></p>		<p>Received By: (Signature) </p> <p>Date/ Time <u>10/27/10</u> <u>1321</u></p>		<p>Relinquished By: (Signature) </p> <p>Date/ Time <u>10-27-10</u> <u>1300</u></p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>	
<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>	
<p>Correct Preservations Y / N / NA</p>		<p>Correct Containers Y / N / NA</p>		<p>Receipt Temperature _____</p>			




E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.66	101322	801		101322	D	1103	32382	22J1301-01	BROWNKA_670
5100316	1013	FREE CHLORINE	301	0.59	100622	802		100622	D	1050	32382	22J0648-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1050	32382	22J0648-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.56	102022	803		102022	D	1100	32382	22J1854-01	BROWNKA_960
5100316	1013	FREE CHLORINE	301	0.82	102722	804		102722	D	1040	32382	22J2417-01	BROWNKA_1557



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 33-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04680

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

21 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 22J1854  
Project: Drinking Water Dassa McKinney - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	22J1854-01	Drinking Water	10/20/2022 11:00	10/20/22 13:20	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15368  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/21/2022 13:42

Lab Sample ID#: 22J1854-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 803 Room 606 Sink

Sample Date: 10/20/2022 11:00  
 Receipt Date: 10/20/2022 13:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.560	mg/L		0.200	PS	10/20/22 11:00	10/20/22 11:00





22J1854

**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

FOR INTERNAL LABORATORY USE ONLY

<b>HEADQUARTER:</b> 1803 Philadelphia St Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<b>SOUTHERN DIVISION</b> 1276 Bentleyville Road Van Vleet, PA 15386 (724) 258-TEST FAX: (724) 258-8376	<b>NORTHERN DIVISION</b> 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1967	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 15 (724) 463-TEST FAX: (724) 465-4209
---	--	--	---

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>805</u>	<u>2231854</u>	<u>10/20/22</u>	<u>1100</u>	DW	Field	Field	Free Chlorine <u>0.56</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							

Notes/Special Instructions: *Drinking Water Dassa McKinney - Weekly*

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time <u>10/20/22 1106</u>	Received By: (Signature) Date/ Time <u>10/20/22 1330</u>
Relinquished By: (Signature) Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Correct Preservations Y / N / NA _____	Correct Containers Y / N / NA _____
Receipt Temperature _____	Receipt Temperature _____

Company/Name: **MONTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@monteateau.org**

Email Address: **jcampbell@monteateau.org**

Billing Address: **5160316**

PWSID: \_\_\_\_\_



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.66	101322	801		101322	D	1103	32382	22J1301-01	BROWNKA_670
5100316	1013	FREE CHLORINE	301	0.59	100622	802		100622	D	1050	32382	22J0648-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1050	32382	22J0648-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.56	102022	803		102022	D	1100	32382	22J1854-01	BROWNKA_960



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

17 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22J1301**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Distribution 801	22J1301-01	Drinking Water	10/13/2022 11:03	10/13/22 13:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/17/2022 10:54

**Lab Sample ID#:** 22J1301-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** Distribution 801

**Sample Date:** 10/13/2022 11:03  
**Receipt Date:** 10/13/2022 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.660	mg/L		0.200	PS	10/13/22 11:03	10/13/22 11:03

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



22J1301

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 801	22J1301	151302	1103	DW	Field	Field	Free Chlorine 0.66 mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 10/13/22 1103  
 Relinquished By: (Signature) Date/ Time 10/13/22 1215

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA \_\_\_\_\_ Correct Containers Y / N / NA \_\_\_\_\_ Receipt Temperature \_\_\_\_\_

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: jcampbell@moniteau.org  
 Email Address: jcampbell@moniteau.org  
 Billing Address: 5100316  
 PWSID: 5100316



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.66	101322	801		101322	D	1103	32382	22J1301-01	BROWNKA_670
5100316	1013	FREE CHLORINE	301	0.59	100622	802		100622	D	1050	32382	22J0648-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1050	32382	22J0648-01	BROWNKA_69



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 October 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 22J0648**  
**Project: Drinking Water Dassa McKinney - Monthly 802**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	22J0648-01	Drinking Water	10/06/2022 10:50	10/6/22 15:05	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 10/11/2022 14:03

**Lab Sample ID#:** 22J0648-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 10/06/2022 10:50  
**Receipt Date:** 10/06/2022 15:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.590	mg/L		0.200	PS	10/06/22 10:50	10/06/22 10:50
<b>Microbiology</b>		<b>Analytical Method: SM 9223 B-16</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	AMB	10/06/22 16:00	10/07/22 16:44
E. Coli	Absent	per 100 mL		1	AMB	10/06/22 16:00	10/07/22 16:44

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vorthis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 11  
(724) 463-TEST  
FAX: (724) 465-4



22J0648

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
801 KITCHEN-SINK 802 ROOM 617 SINK	22J0648 01		10:50	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.59 mg/L

Rotations: 801: Jan, Mar, May, Jul, Sep, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec	Notes/Special Instructions: Drinking Water Dassa McKinney - Monthly
--	--

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.	Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcampbell@moniteau.org 5100316
---	---

Sampled By: (Signature) [Signature] Date/ Time: 10-6-02 10:50	Received By: (Signature) [Signature] Date/ Time: 10/12/05
Relinquished By: (Signature) [Signature] Date/ Time: 10-6-02 14:35	Received By: (Signature) [Signature] Date/ Time:
Relinquished By: (Signature) [Signature] Date/ Time:	Received By: (Signature) [Signature] Date/ Time:
Relinquished By: (Signature) [Signature] Date/ Time:	Received By: (Signature) [Signature] Date/ Time:
Correct Preservations <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N / NA	Receipt Temperature 48.5°C



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.59	100622	802		100622	D	1050	32382	22J0648-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100722	802		100622	D	1050	32382	22J0648-01	BROWNKA_69