

**Moniteau School District  
Dassa McKinney Elementary  
School**

**Monthly Water Treatment  
Facility Report**

**January 2021**

Dassa McKinney Elementary School Water Treatment Facility

Month	Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
	1	Fri									
	2	Sat.									
	3	Sun									
	4	Mon	8.7	0.04	0.39	0.46	1.38	12243800	Jeff R	4:30P	3900
	5	Tues.	8.7	0.03	0.38	0.42	1.45	12244200	Jeff R	3:00P	400
	6	Wed	8.7	0.02	0.80	0.86	1.51	12248500	Jeff R	4:30P	4300
	7	Thurs	8.6	0.00	0.60	0.67	1.02	12252900	Jeff R	4:30P	4400
	8	Fri	8.7	0.01	0.46	0.53	1.12	12257200	Jeff R	4:00P	4300
	9	Sat									
	10	Sun									
	11	Mon.	8.7	0.03	0.63	0.72	1.85	12261200	Jeff R	3:30P	4000
	12	Tues	8.7	0.02	0.80	0.86	1.92	12265300	Jeff R	3:30P	4100
	13	Wed	8.7	0.02	0.45	0.53	2.25	12269700	Jeff R	3:30P	4400
	14	Thurs	8.7	0.03	0.75	0.85	2.38	12274100	Jeff R	3:30P	4400
	15	Fri	8.7	0.02	0.77	0.85	1.91	12282500	Jeff R	3:30P	8400
	16	Sat									
	17	Sun									
	18	Mon	8.7	0.02	0.43	0.49	1.81	12282900	Jeff R	3:00P	400
	19	Tues	8.7	0.03	0.73	0.81	2.53	12283400	Jeff R	3:00P	500
	20	Wed	8.7	0.02	0.73	0.80	2.55	12288500	Jeff R	3:00P	5100
	21	Thurs.	8.6	0.03	0.78	0.85	2.24	12293400	Jeff R	3:00P	4900
	22	Fri	8.6	0.02	0.69	0.73	2.25	12298100			4700
	23	Sat									
	24	Sun									
	25	Mon	8.6	0.02	0.30	0.35	2.29	12302800	Jeff C	3:30AM	4700
	26	Tues	8.7	0.00	0.45	0.52	2.85	12307100	Jeff R	3:30P	4300
	27	Wed	8.7	0.01	1.27	1.35	2.55	12307300	Jeff R	2:30P	200
	28	Thurs	8.7	0.02	1.53	1.73	2.23	12311800	Jeff R	3:00P	4500
	29	Fri	8.7	0.02	1.01	1.13	2.15	12319800	Jeff R	3:00P	8000
	30	Sat									
	31	Sun									

Meter Reading 12/30/20 - 12239900



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1010477**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1010477-01	Drinking Water	01/07/2021 11:45	1/7/21 14:23	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/12/2021 14:08

**Lab Sample ID#:** 1010477-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 01/07/2021 11:45  
**Receipt Date:** 01/07/2021 14:23

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.09	mg/L		0.200	PS	01/07/21 11:45	01/07/21 11:45
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	KEL	01/07/21 14:53	01/08/21 17:00
E. Coli	Absent	per 100 mL		1	KEL	01/07/21 14:53	01/08/21 17:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376





WEST DIVISION  
Street  
ile, PA 16  
3-TEST  
(724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802-ROOM 617 SINK	1010477	1-7-21	1145	DW	8.13 10 11/12/13 14 15	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 1.09 mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>Rotation: 801: Jan, Mar, May, Jul, Sep, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) </p> <p>Date/ Time: 1-7-21 1145</p>				<p>Received By: (Signature) </p> <p>Date/ Time: 1-7-21 1415</p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>			
<p>Receipt Temperature</p>				<p>Receipt Temperature</p>			
<p>Notes/Special Instructions: <b>Drinking Water Dassa McKinney - Monthly</b></p>							
<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD</b> <b>WEST SUNBURY, PA 16061</b> <b>JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcambell@moniteau.org</b></p> <p>Email Address: <b>jcambell@moniteau.org</b></p> <p>Billing Address: <b>JEFFREY CAMPBELL</b></p> <p>PWSID: <b>5100316</b></p>							

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	1.09	010721	801		010721	D	1145	32382	1010477-01	BROWNKA_221
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	801		010721	D	1145	32382	1010477-01	BROWNKA_222



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

15 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1011069**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1011069-01	Drinking Water	01/14/2021 12:10	1/14/21 14:49	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/15/2021 11:35

**Lab Sample ID#:** 1011069-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 01/14/2021 12:10  
**Receipt Date:** 01/14/2021 14:49

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.340	mg/L		0.200	PS	01/14/21 12:10	01/14/21 12:10



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>807</u>	<u>1011069</u>	<u>1-14-21</u>	<u>12:10</u>	DW	Field	Field	Free Chlorine <u>34</u> mg/L

### ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 1-14-21 12:10  
 Relinquished By: (Signature) [Signature] Date/ Time 1-14-21 14:50  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) [Signature] Date/ Time 1/14/21 14:50  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
**JEFFREY CAMPBELL**  
 Contact Person:  
 Phone Number:  
 Cell Phone: **724-406-4426**  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address:  
 PWSID: **5100316**



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	1.09	010721	801		010721	D	1145	32382	1010477-01	BROWNKA_221
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	801		010721	D	1145	32382	1010477-01	BROWNKA_222
5100316	1013	FREE CHLORINE	301	0.34	011421	802		011421	D	1210	32382	1011069-01	BROWNKA_383



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

22 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1011644**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Distribution 803	1011644-01	Drinking Water	01/21/2021 11:25	1/21/21 15:20	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/22/2021 11:07

**Lab Sample ID#:** 1011644-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** Distribution 803

**Sample Date:** 01/21/2021 11:25  
**Receipt Date:** 01/21/2021 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.740	mg/L		0.200	PS	01/21/21 11:25	01/21/21 11:25

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



1011644

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 803	1011644	Grab	DW	Field	Field	Free Chlorine .74 mg/L
	01	Date: 12/21	Time: 1125			
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Notes/Special Instructions:		
	12/21 1125	SPM	12/21 1520	Drinking Water Dassa McKinney - Weekly		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Company Name: MONITEAU SCHOOL DISTRICT		
	12/21 1427			Address: 391 HOOKER ROAD		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Contact Person: WEST SUNBURY, PA 16061		
				Phone Number: JEFFREY CAMPBELL		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Cell Phone: 724-406-4426		
				Email Address: jcampbell@moniteau.org		
Correct Preservations Y/N/NA	Correct Containers Y/N/NA	Receipt Temperature		Billing Address: 5100316		
				PWSID: 5100316		



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	1.09	010721	801		010721	D	1145	32382	1010477-01	BROWNKA_221
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	801		010721	D	1145	32382	1010477-01	BROWNKA_222
5100316	1013	FREE CHLORINE	301	0.34	011421	802		011421	D	1210	32382	1011069-01	BROWNKA_383
5100316	1013	FREE CHLORINE	301	0.74	012121	803		012121	D	1125	32382	1011644-01	BROWNKA_669





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

28 January 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1012144**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1012144-01	Drinking Water	01/28/2021 10:30	1/28/21 13:10	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 01/28/2021 16:01

**Lab Sample ID#:** 1012144-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 01/28/2021 10:30  
**Receipt Date:** 01/28/2021 13:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	1.34	mg/L		0.200	PS	01/28/21 10:30	01/28/21 10:30

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	1.09	010721	801		010721	D	1145	32382	1010477-01	BROWNKA_221
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	801		010721	D	1145	32382	1010477-01	BROWNKA_222
5100316	1013	FREE CHLORINE	301	0.34	011421	802		011421	D	1210	32382	1011069-01	BROWNKA_383
5100316	1013	FREE CHLORINE	301	0.74	012121	803		012121	D	1125	32382	1011644-01	BROWNKA_669
5100316	1013	FREE CHLORINE	301	1.34	012821	804		012821	D	1030	32382	1012144-01	BROWNKA_939



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVIS:  
1276 Bentleyville  
Van Voorhis, PA 1  
(724) 258-TEST  
FAX: (724) 258-8



NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>SO4</u>	<u>1012144</u>	<u>1-28-21</u>	<u>1030</u>	DW	Field	Field	Free Chlorine <u>1.34</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) Date/ Time <u>1-28-21 1030</u>	Received By: (Signature) <u>SPM</u> <u>1/28/21 1310</u> Date/ Time						
Relinquished By: (Signature) Date/ Time <u>1-28-21 1207</u>	Received By: (Signature) _____ Date/ Time						
Relinquished By: (Signature) _____ Date/ Time	Received By: (Signature) _____ Date/ Time						
Relinquished By: (Signature) _____ Date/ Time	Received By: (Signature) _____ Date/ Time						
Correct Preservations Y / N / NA Correct Containers Y / N / NA	Receipt Temperature						
Notes/Special Instructions: <p style="text-align: center;"><b>Drinking Water Dassa McKinney - Weekly</b></p>							
Company Name: <b>MONITEAU SCHOOL DISTRICT</b> Address: <b>391 HOOKER ROAD</b> <b>WEST SUNBURY, PA 16061</b> Contact Person: <b>JEFFREY CAMPBELL</b> Phone Number: <b>724-406-4426</b> Cell Phone: <b>jcampbell@moniteau.org</b> Billing Address: PWSID: <b>5100316</b>							

**Moniteau School District**  
**Moniteau High School**  
**Monthly Water Treatment**  
**Facility Report**  
**January 2021**



MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Fri	Holiday	Closed	No	School						
2	SAT										
3	SUN										
4	Mon	43.4	8.16	4,148,567	0.42	0.45	7.3	0.02	1.00	Jeff C	8:45 AM
5	Tues	48.0	8.61	4,152,930	0.37	0.44	7.3	0.00	1.09	Jeff C	1:00 PM
6	Wed	45.6	8.44	4,154,005	0.41	0.47	7.3	0.00	1.08	Jeff C	7:30 AM
7	Thurs	45.0	7.09	4,154,005	0.43	0.47	7.3	0.00	1.09	Jeff C	7:30 AM
8	Fri	50.0	7.35	4,164,306	0.41	0.48	7.3	0.01	0.97	Jeff C	1:30 PM
9	SAT										
10	SUN										
11	Mon	47.1	8.00	4,168,824	0.56	0.60	7.3	0.01	0.96	Jeff C	9:00 AM
12	Tues	48.0	7.54	4,170,215	0.66	0.70	7.3	0.01	0.97	Jeff C	8:00 AM
13	Wed	48.0	7.44	4,175,172	0.68	0.72	7.3	0.01	0.95	Jeff C	8:00 AM
14	Thurs	48.0	7.15	4,179,436	0.76	0.88	7.3	0.03	0.81	Jeff C	8:00 AM
15	Fri	52.0	7.53	4,190,117	0.81	0.90	7.3	0.01	0.82	Jeff C	8:00 AM
16	SAT										
17	SUN										
18	Mon	46.1	8.21	4,195,305	0.85	0.97	7.2	0.00	1.11	Jeff C	2:30 PM
19	Tues	45.0	7.31	4,195,305	0.85	0.97	7.3	0.00	1.08	Jeff C	10:00 AM
20	Wed	48.1	8.16	4,204,750	0.75	0.91	7.1	0.00	1.11	Jeff C	1:00 PM
21	Thurs	47.7	7.20	4,205,276	0.74	0.89	7.1	0.00	1.12	Jeff C	11:30 AM
22	Fri	48.0	8.54	4,210,099	0.80	0.90	7.2	0.00	1.10	Jeff C	9:00 AM
23	SAT										
24	SUN										
25	Mon	43.0	7.09	4,210,099	0.81	0.94	7.2	0.01	1.25	Jeff C	9:00 AM
26	Tues	47.0	8.49	4,220,699	0.60	0.73	7.1	0.03	0.86	Jeff C	9:30 AM
27	Wed	45.1	7.97	4,220,699	0.62	0.75	7.1	0.02	0.87	Jeff C	9:00 AM
28	Thurs	45.4	7.96	4,225,235	0.71	0.77	7.1	0.01	0.89	Jeff C	10:30 AM
29	Fri	46.8	8.18	4,228,982	0.72	0.83	7.2	0.02	1.04	Jeff C	10:00 AM
30	SAT										
31											

SNOW DAY



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1010478**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1010478-01	Drinking Water	01/07/2021 12:10	1/7/21 14:23	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Rebecca Erwin*

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/12/2021 14:08

**Lab Sample ID#:** 1010478-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 01/07/2021 12:10  
**Receipt Date:** 01/07/2021 14:23

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.770	mg/L		0.200	PS	01/07/21 12:10	01/07/21 12:10
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	KEL	01/07/21 14:53	01/08/21 17:00
E. Coli	Absent	per 100 mL		1	KEL	01/07/21 14:53	01/08/21 17:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NO 435  
Mor (57)  
FA



1010478

DIVISION

16150

J-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802-ROOM-204-SINK	1010478 08	1-7-21	1210	DW	59 (3) 19 1716 1423 KCL	STERILE PLASTIC NA THIO	TC/EC Free Chlorine .77

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Sampled By: (Signature)	1-7-21	1210	Date/ Time	Received By: (Signature)	1-7-21	14:25	Date/ Time
Relinquished By: (Signature)	1-7-21	1415	Date/ Time	Received By: (Signature)			Date/ Time
Relinquished By: (Signature)			Date/ Time	Received By: (Signature)			Date/ Time
Relinquished By: (Signature)			Date/ Time	Received By: (Signature)			Date/ Time
Correct Preservations Y / N / NA	Y / N / NA	Correct Containers	Y / N / NA	Receipt Temperature			
Company/Name:	MONITEAU SCHOOL DISTRICT						
Address:	1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL						
Contact Person:	JEFFREY CAMPBELL						
Phone Number:	724-406-4426						
Cell Phone:	jcampbell@moniteau.org						
Email Address:							
Billing Address:							
PWSID:	5100324						



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	010721	704		010721	D	1210	32382	1010478-01	BROWNKA_223
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	704		010721	D	1210	32382	1010478-01	BROWNKA_224





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

15 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1011070**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1011070-01	Drinking Water	01/14/2021 12:30	1/14/21 14:50	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/15/2021 11:35

**Lab Sample ID#:** 1011070-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 01/14/2021 12:30  
**Receipt Date:** 01/14/2021 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.820	mg/L		0.200	PS	01/14/21 12:30	01/14/21 12:30

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN DIVISION**  
 1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-8376

**NORTHERN DIVISION**  
 435 Broad Street  
 Monitorsville, PA 17754  
 (570) 321-9003  
 FAX: (570) 321-1957

**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpville, PA 16  
 (724) 463-TEST  
 FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>1011070</u>	Date: <u>1-14-21</u>	Time: <u>1230</u>	DW	Field	Field	Free Chlorine <u>1.82</u> mg/L

**ROTATION**  
 Wk 1 - 704 Kitchen Sink  
 Wk 2 - 802 Room 204 Sink  
 Wk 3 - 803 Admin-Sink  
 Wk 4 - 804 400 Hall RR Sink  
 Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

**Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL**  
 Contact Person:  
 Phone Number: **724-406-4426**  
 Cell Phone:  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address:  
 PWSID: **5100324**

Received By: (Signature) [Signature] Date/ Time 1/14/21 1450  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Sampled By: (Signature) [Signature] Date/ Time 1-14-21 1230  
 Relinquished By: (Signature) [Signature] Date/ Time 1-14-21 1430  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA \_\_\_\_\_ Correct Containers Y / N / NA \_\_\_\_\_ Receipt Temperature \_\_\_\_\_



**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	010721	704		010721	D	1210	32382	1010478-01	BROWNKA_223
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	704		010721	D	1210	32382	1010478-01	BROWNKA_224
5100324	1013	FREE CHLORINE	301	0.82	011421	802		011421	D	1230	32382	1011070-01	BROWNKA_384



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

22 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1011645**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1011645-01	Drinking Water	01/21/2021 11:40	1/21/21 15:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/22/2021 11:07

**Lab Sample ID#:** 1011645-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 01/21/2021 11:40  
**Receipt Date:** 01/21/2021 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.790	mg/L		0.200	PS	01/21/21 11:40	01/21/21 11:40



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



SOUTHWEST DIVISION  
1276 Van Ness  
(724) 463-TEST  
FAX: (724) 465-4209

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 805	1011645	Grab	DW	Field	Preservative	Free Chlorine 1.79 mg/L
	01	Date: 12/21	Time: 1140	Field	Field	

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 12/21 1140  
 Relinquished By: (Signature) *[Signature]* Date/ Time 12/21 1427  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: jcampbell@moniteau.org  
 Billing Address: 5100324  
 PWSID: 5100324



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	010721	704		010721	D	1210	32382	1010478-01	BROWNKA_223
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	704		010721	D	1210	32382	1010478-01	BROWNKA_224
5100324	1013	FREE CHLORINE	301	0.82	011421	802		011421	D	1230	32382	1011070-01	BROWNKA_384
5100324	1013	FREE CHLORINE	301	0.79	012121	803		012121	D	1140	32382	1011645-01	BROWNKA_670



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

29 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1012143**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1012143-01	Drinking Water	01/28/2021 10:45	1/28/21 13:10	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/29/2021 07:19

**Lab Sample ID#:** 1012143-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 01/28/2021 10:45  
**Receipt Date:** 01/28/2021 13:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.750	mg/L		0.200	PS	01/28/21 10:45	01/28/21 10:45



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	010721	704		010721	D	1210	32382	1010478-01	BROWNKA_223
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	010821	704		010721	D	1210	32382	1010478-01	BROWNKA_224
5100324	1013	FREE CHLORINE	301	0.82	011421	802		011421	D	1230	32382	1011070-01	BROWNKA_384
5100324	1013	FREE CHLORINE	301	0.79	012121	803		012121	D	1140	32382	1011645-01	BROWNKA_670
5100324	1013	FREE CHLORINE	301	0.75	012821	804		012821	D	1045	32382	1012143-01	BROWNKA_940

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SC 12 V: (7 F.



1012143

FOR INTERNAL LABORATORY USE ONLY

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

EAST DIVISION  
1400 Main Street  
Sharpsville, PA 17754  
1-9003  
70) 321-1957

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>SOL</u>	<u>1012143</u>	<u>12/21</u>	<u>10:15</u>	DW	Field	Field	Free Chlorine <u>1.75</u> mg/L
<p><b>ROTATION</b></p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u></p> <p>Date/ Time <u>12/21/10</u></p>				<p>Notes/Special Instructions: <b>Drinking Water Moniteau Jr/Sr - Weekly</b></p>			
<p>Relinquished By: (Signature) <u>[Signature]</u></p> <p>Date/ Time <u>12/21/10</u></p>				<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p>			
<p>Relinquished By: (Signature) <u>[Signature]</u></p> <p>Date/ Time <u>12/21/10</u></p>				<p>Address: <b>391 HOOKER ROAD</b></p>			
<p>Relinquished By: (Signature) <u>[Signature]</u></p> <p>Date/ Time <u>12/21/10</u></p>				<p>Contact Person: <b>WEST SUNBURY, PA 16061</b></p>			
<p>Correct Preservations Y / N / NA</p>				<p>Phone Number: <b>JEFFREY CAMPBELL</b></p>			
<p>Correct Containers Y / N / NA</p>				<p>Cell Phone: <b>724-406-4426</b></p>			
<p>Receipt Temperature</p>				<p>Email Address: <b>jcampbell@moniteau.org</b></p>			
<p>Correct Preservations Y / N / NA</p>				<p>Billing Address: <b>5100324</b></p>			
<p>Correct Containers Y / N / NA</p>				<p>PWSID: <b>5100324</b></p>			



**Moniteau School District  
Moniteau High School  
Monthly WasteWater  
Treatment Facility Report  
January 2021**





COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 01/01/2021  
 DMR Effective To: 01/31/2021  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD			
YEAR	MO	DAY	TO
2021	01	01	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		6.0	***	***	mg/L	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	***		1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.17	***	8.08	S.U.	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max		1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	***		2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		31.25	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***		2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		2.3	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***		2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		5.75	***	***	µw/cm²	1/week	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	***		1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002594	MGD	***	***	***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo		***	***	***		1/week	Measured



DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		<1.0	<1.0		No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		2000	10000	IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		<3.0	***		mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		25	***			2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER

## Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Tuesday, February 2, 2021, 04:10 PM EST

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL

**Permit Number:** PA0091341

**Report Frequency:** Monthly

**Report Type:** DMR

**Reporting Period:** 01/01/2021-01/31/2021

**Report Due Date:** 02/28/2021

**Submitted By:** Jeffrey Campbell

**Submission Id:** 249892

**Submission Status:** Received

**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

# Moniteau High School Sewage PLANT

JAN-2021

FLOW	$80,415 \div 31 = 2,594$ Daily Avg.
UV Light	$126.70 \div 22 = 5.75$ Avg.
P.H. High	8.08
Low	6.17
D.O. High	12.45
Low	6.00
TOTAL Nitrogen	$22.7 + 39.8 = 62.5 \div 2 = 31.25$ Avg.
TSS	$< 5 + < 5 = < 5$ Avg.
Nitrate/Nitrite	$22.7 + 39.8 = 62.5 \div 2 = 31.25$ Avg.
Phosphorus	$1.7 + 2.9 = 4.6 \div 2 = 2.3$ Avg.
CBOD	$< 3.00 + < 3.00 = < 3.00$ Avg.
Fecal Coliforms	$< 1 + < 1 = < 1$ Avg.



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

14 January 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1010480**  
**Project: Wastewater**  
**Project Description: Wastewater**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1010480-01	Waste Water	01/07/2021 11:00	1/7/21 14:23	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

### Definitions

BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.  
RL Reporting Limit  
CFU Colony Forming Units

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

*Rebecca Erwin*

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/14/2021 19:02


**Lab Sample ID#:** 1010480-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 01/07/2021 11:00  
**Receipt Date:** 01/07/2021 14:23

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	22.7	mg/L		1.04	DAA	01/12/21 15:00	01/14/21 11:03
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	01/13/21 09:55	01/13/21 11:00
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	22.7	mg/L		1.04	DAA	01/12/21 15:00	01/14/21 11:03
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	1.7	mg/L		0.20	JPD	01/08/21 09:19	01/08/21 10:30
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB	3.00	AW	01/07/21 18:05	01/12/21 12:55
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	01/07/21 15:15	01/08/21 12:08







# SAMPLE RECEIPT AND REVIEW FORM

## PART A: General Information

1010480

Client: <u>Monteau</u>		Work Order: _____	
Received by: <u>Koz</u>		Date/Time Received: <u>1/7/2014 14:23</u>	Date Sampled: <u>1/7/2014</u>
Method of Delivery: FedEx    UPS    Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>2.5</u>		Samples Received on Ice: <input checked="" type="radio"/> YES    NO	
IR Gun # Used: 1    2 <input checked="" type="radio"/> 3    4			
Samples Removed by Satellite Lab Division: Southern(BV)    NorthWest(NW)    Northern(WP)		Containers removed by Satellite Lab for analysis of:	TCMPN    Fecal Coliform    TC/EC ECMPN
Sample State of Collection: <input checked="" type="radio"/> PA    NY    OH    WV    Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES:    YES <input checked="" type="radio"/> NO	

## PART B: Receipt Details

Completed (if different from above): \_\_\_\_\_  
 Signature: \_\_\_\_\_ Date: 1/7/2014 Time: 14:23

Sample Receipt Criteria					Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1	Chain of custody documents included with samples?	<input checked="" type="radio"/> Yes	No	N/A	Comments:	YES <input checked="" type="radio"/> NO
2	COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/> Yes	No	N/A	Comments:	YES <input checked="" type="radio"/> NO
3	Sample containers intact and sealed?	<input checked="" type="radio"/> Yes	No	N/A	Circle Applicable: Damaged container    Leaking container    Custody Seal Broken Other: _____	YES <input checked="" type="radio"/> NO
4	Number of containers received match number indicated on COC?	<input checked="" type="radio"/> Yes	No	N/A	Sample ID's affected:	YES <input checked="" type="radio"/> NO
5	Sample ID's on COC match ID's on bottles?	<input checked="" type="radio"/> Yes	No	N/A	Sample ID's and containers affected:	YES <input checked="" type="radio"/> NO
6	Date and time on COC match date and time on bottles?	<input checked="" type="radio"/> Yes	No	N/A	Sample ID's affected:	YES <input checked="" type="radio"/> NO
7	Samples received within holding time?	<input checked="" type="radio"/> Yes	No	N/A	ID's and tests affected:	YES <input checked="" type="radio"/> NO
8	Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/> Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES <input checked="" type="radio"/> NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/> Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES <input checked="" type="radio"/> NO
11	Adequate sample volume received?	<input checked="" type="radio"/> Yes	No	N/A	Analyses Affected:	YES <input checked="" type="radio"/> NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	<input checked="" type="radio"/> Yes	No	<input checked="" type="radio"/> N/A	Sample ID's and containers affected:	YES <input checked="" type="radio"/> NO
Other Comments:						Deficiency Log Created: Yes <input checked="" type="radio"/> No



### Results Report

Order ID: 1A01284

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 1A01284-01

Site: 1010480-01

Sample ID: 1010480

Collector: Client

Collect Date: 01/07/2021 11:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<b>Inorganics</b>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	01/12/21	CJ	01/13/21 11:23	ZJH

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager I

Report Generated On: 01/13/2021 2:54 pm  
STL\_Results Revision #1.9

1A01284  
Effective: 04/16/2020





**SUBCONTRACT ORE**  
**Environmental Service Labora**  
**1010480**



1A01284  
 Lisa F. Care

Please report all results to [reports@envlabs.com](mailto:reports@envlabs.com).

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
 1803 Philadelphia Street  
 Indiana, PA 15701  
 Phone: 724-463-8378  
 Fax: 724-465-4209  
 Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
 1037F MacArthur Road  
 Reading, PA 19605  
 Phone : (610) 375-8378  
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
<b>Sample ID: 1010480-01</b>			
<b>Matrix: Water</b>	<b>Sampled: 01/07/2021 11:00</b>	<b>Sample Type: Grab</b>	<b>Sampled By: Client</b>
Total Kjeldahl Nitrogen	01/19/2021 23:00	02/04/2021 11:00	
<i>Containers Supplied:</i>			
Poly 250mL, H2SO4 (D)			

*pk 42.0 ANB  
 JP 1.8.21*

**Suburban Testing Labs**

**Lab Date/Time:** 1/8/21 10:49 **Lab Temp:** 2.8°C  
 Number of containers/coolers match number on COC?  Y  N  
 Sample labels and COC are free of discrepancies?  Y  N  
 All containers in tact?  Y  N  
 Received in lab within acceptable temperature limits?  Y  N  
 40mL VOA vials free of headspace?  Y  N  
**Relinquished by:** \_\_\_\_\_  
**Received in Lab by:** JP

Released By: g Date: 1/7/21 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Released By: \_\_\_\_\_ Date: \_\_\_\_\_ Received By: \_\_\_\_\_ Date: \_\_\_\_\_





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

29 January 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1011643**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1011643-01	Waste Water	01/21/2021 11:00	1/21/21 15:20	

**Report Narrative**

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

**Definitions**

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

**Certifications**

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

**Approved By**

*Rebecca Erwin*

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 01/29/2021 11:03

**Lab Sample ID#:** 1011643-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 01/21/2021 11:00  
**Receipt Date:** 01/21/2021 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	39.8	mg/L		1.04	DAA	01/27/21 15:10	01/28/21 13:11
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	01/26/21 10:28	01/26/21 11:45
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	39.8	mg/L		1.04	DAA	01/27/21 15:10	01/28/21 13:11
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	2.9	mg/L		0.50	JPD	01/27/21 09:18	01/27/21 11:00
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB, SS	3.00	AW	01/22/21 13:30	01/27/21 08:00
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	01/21/21 15:20	01/22/21 11:45











## Results Report

Order ID: 1A03094

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 1A03094-01  
Collector: Client

Site: 1011643-01  
Collect Date: 01/21/2021 11:00 am

Sample ID: 1011643  
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

<u>Inorganics</u>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	01/25/21	CJ	01/26/21 11:44	ZJH

### Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

### Reviewed and Released By:

Lisa F. Care  
Project Manager I

Report Generated On: 01/26/2021 4:31 pm  
STL\_Results Revision #1.9

1A03094  
Effective: 04/16/2020





**SUBCONTRACT (**  
**Environmental Service La**  
**1011643**



1A03094  
 Lisa F. Care

Please report all results to [reports@envlabs.co](mailto:reports@envlabs.co)

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
 1803 Philadelphia Street  
 Indiana, PA 15701  
 Phone: 724-463-8378  
 Fax: 724-465-4209  
 Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
 1037F MacArthur Road  
 Reading, PA 19605  
 Phone : (610) 375-8378  
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1011643-01			
Matrix: Water	Sampled: 01/21/2021 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	02/02/2021 23:00	02/18/2021 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D) <i>PH2 ANB</i>			

**Suburban Testing Labs**

Lab Date/Time: 1/22/21 12:30 Lab Temp: ICE 5  
 Number of containers/coolers match number on COC? Y N  
 Sample labels and COC are free of discrepancies? Y N  
 All containers in tact? Y N  
 Received in lab within acceptable temperature limits? Y N  
 40mL VOA vials free of headspace? Y N  
 Relinquished by: Delivery  
 Received in Lab by: *[Signature]*

Released By: *[Signature]* Date: 1/21/21 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Released By: \_\_\_\_\_ Date: \_\_\_\_\_ Received By: \_\_\_\_\_ Date: \_\_\_\_\_

